MITSUBISHI ELECTRIC

GRAPHIC OPERATION TERMINAL

GOT2000 Series

Connection Manual
(Microcomputer, MODBUS Products, Peripherals)

For GT Works3 Version1



- ■MICROCOMPUTER CONNECTION
- ■MODBUS/RTU CONNECTION
- ■MODBUS/TCP CONNECTION
- ■CONNECTION TO SOUND OUTPUT UNIT
- ■CONNECTION TO EXTERNAL I/O DEVICE
- ■BAR CODE READER CONNECTION
- ■REMOTE PERSONAL COMPUTER OPERATION CONNECTION
- ■VNC(R) SERVER CONNECTION
- ■VIDEO/RGB CONNECTION
- ■PRINTER CONNECTION
- ■MULTIMEDIA CONNECTION
- ■RFID CONNECTION
- ■WIRELESS LAN CONNECTION

● SAFETY PRECAUTIONS ●

(Always read these precautions before using this equipment.)

Before using this product, please read this manual and the relevant manuals introduced in this manual carefully and pay full attention to safety to handle the product correctly.
The precautions given in this manual are concerned with this product.
In this manual, the safety precautions are ranked as "WARNING" and "CAUTION".

⚠ **WARNING**	Indicates that incorrect handling may cause hazardous conditions, resulting in death or severe injury.
⚠ **CAUTION**	Indicates that incorrect handling may cause hazardous conditions, resulting in medium or slight personal injury or physical damage.

Note that the ⚠ caution level may lead to a serious accident according to the circumstances. Always follow the instructions of both levels because they are important to personal safety.

Please save this manual to make it accessible when required and always forward it to the end user.

[DESIGN PRECAUTIONS]

⚠ WARNING

- Some failures of the GOT, communication unit or cable may keep the outputs on or off.
  Some failures of a touch panel may cause malfunction of the input objects such as a touch switch.
  An external monitoring circuit should be provided to check for output signals which may lead to a serious accident.Not doing so can cause an accident due to false output or malfunction.
- Do not use the GOT as the warning device that may cause a serious accident.
  An independent and redundant hardware or mechanical interlock is required to configure the device that displays and outputs serious warning.
  Failure to observe this instruction may result in an accident due to incorrect output or malfunction.
- The GOT backlight failure disables the operation on the touch switch(s).
  When the GOT backlight has a failure, the POWER LED blinks (orange/blue) and the display section dims. In such a case, the input by the touch switch(s) is disabled.
- The display section of the GOT is an analog-resistive type touch panel.
  [GT27]
  The GOT is multi-touch compliant; however, do not touch three points or more simultaneously on the display section. Doing so may cause an accident due to incorrect output or malfunction.
  [GT23]
  If you touch the display section simultaneously in two points or more,the switch that is located around the center of the touched point, if any, may operate.Do not touch the display section in two points or more simultaneously.Doing so may cause an accident due to incorrect output or malfunction.
- When programs or parameters of the controller (such as a PLC) that is monitored by the GOT are changed, be sure to reset the GOT, or turn on the unit again after shutting off the power as soon as possible.Not doing so can cause an accident due to false output or malfunction.

[DESIGN PRECAUTIONS]

⚠WARNING

- If a communication fault (including cable disconnection) occurs during monitoring on the GOT, communication between the GOT and PLC CPU is suspended and the GOT becomes inoperative.
  For bus connection (GT27 Only) : The CPU becomes faulty and the GOT becomes inoperative.
  For other than bus connection : The GOT becomes inoperative.
  A system where the GOT is used should be configured to perform any significant operation to the system by using the switches of a device other than the GOT on the assumption that a GOT communication fault will occur.
  Not doing so can cause an accident due to false output or malfunction.

⚠CAUTION

- Do not bundle the control and communication cables with main-circuit, power or other wiring.
  Run the above cables separately from such wiring and keep them a minimum of 100mm apart.
  Not doing so noise can cause a malfunction.
- Do not press the GOT display section with a pointed material as a pen or driver.
  Doing so can result in a damage or failure of the display section.
- When the GOT is connected to the Ethernet network, the available IP address is restricted according to the system configuration.
  - When multiple GOTs are connected to the Ethernet network :
    Do not set the IP address (192.168.3.18) for the GOTs and the controllers in the network.
  - When a single GOT is connected to the Ethernet network :
    Do not set the IP address (192.168.3.18) for the controllers except the GOT in the network.

  Doing so can cause the IP address duplication.
  The duplication can negatively affect the communication of the device with the IP address (192.168.3.18).
  The operation at the IP address duplication depends on the devices and the system.
- Turn on the controllers and the network devices to be ready for communication before they communicate with the GOT.
  Failure to do so can cause a communication error on the GOT.
- When the GOT is subject to shock or vibration, or some colors appear on the screen of the GOT, the screen of the GOT might flicker.

[MOUNTING PRECAUTIONS]

⚠WARNING

- Be sure to shut off all phases of the external power supply used by the system before mounting or removing the GOT main unit to/from the panel.
  Not doing so can cause the unit to fail or malfunction.
- Be sure to shut off all phases of the external power supply used by the system before mounting or removing the option unit onto/from the GOT.(GT27 Only)

[MOUNTING PRECAUTIONS]

⚠CAUTION

- Use the GOT in the environment that satisfies the general specifications described in this manual. Not doing so can cause an electric shock, fire, malfunction or product damage or deterioration.
- When mounting the GOT to the control panel, tighten the mounting screws in the specified torque range (0.36 N·m to 0.48 N·m) with a Phillips-head screwdriver No.2.
  Undertightening can cause the GOT to drop, short circuit or malfunction.
  Overtightening can cause a drop, short circuit or malfunction due to the damage of the screws or the GOT.
- When loading the communication unit or option unit other than wireless LAN unit to the GOT, fit it to the connection interface of the GOT and tighten the mounting screws in the specified torque range (0.36 N•m to 0.48 N•m) with a Phillips-head screwdriver No.2.
  When loading the wireless LAN unit to the GOT, fit it to the side interface of GOT and tighten the mounting screws in the specified torque range (0.10 N•m to 0.14 N•m) with a Phillips-head screwdriver No.2.
  Under tightening can cause the GOT to drop, short circuit or malfunction.
  Overtightening can cause a drop, failure or malfunction due to the damage of the screws or unit.(GT27 Only)
- When closing the USB environmental protection cover, fix the cover to the GOT by pushing the [PUSH] mark on the latch firmly to comply with the protective structure.(GT27 Only)
- Remove the protective film of the GOT.
  When the user continues using the GOT with the protective film, the film may not be removed.In addition, for the models equipped with the human sensor function, using the GOT with the protective film may cause the human sensor not to function properly
- Operate and store the GOT in environments without direct sunlight, high temperature, dust, humidity, and vibrations.
- When using the GOT in the environment of oil or chemicals, use the protective cover for oil.Failure to do so may cause failure or malfunction due to the oil or chemical entering into the GOT.

[WIRING PRECAUTIONS]

⚠WARNING

- Be sure to shut off all phases of the external power supply used by the system before wiring. Failure to do so may result in an electric shock, product damage or malfunctions.

⚠CAUTION

- Make sure to ground the FG terminal and LG terminal of the GOT power supply section to the protective ground conductors dedicated to the GOT with a ground resistance of 100 Ω or less.
- When tightening the terminal screws, use a Phillips-head screwdriver No.2.
- Terminal screws which are not to be used must be tightened always at torque 0.5 N·m to 0.8 N·m. Otherwise there will be a danger of short circuit against the solderless terminals.

[WIRING PRECAUTIONS]

⚠CAUTION

- Use applicable solderless terminals and tighten them with the specified torque.
  If any solderless spade terminal is used, it may be disconnected when the terminal screw comes loose, resulting in failure.
- Correctly wire the GOT power supply section after confirming the rated voltage and terminal arrangement of the product.
  Not doing so can cause a fire or failure.
- Tighten the terminal screws of the GOT power supply section in the specified torque range (0.5 N·m to 0.8 N·m).
  Undertightening can cause a short circuit or malfunction.
  Overtightening can cause a short circuit or malfunction due to the damage of the screws or the GOT.
- Exercise care to avoid foreign matter such as chips and wire offcuts entering the GOT.
  Not doing so can cause a fire, failure or malfunction.
- The module has an ingress prevention label on its top to prevent foreign matter, such as wire offcuts, from entering the module during wiring.
  Do not peel this label during wiring.Before starting system operation, be sure to peel this label because of heat dissipation. (GT27 Only)
- Plug the communication cable into the GOT interface or the connector of the connected unit, and tighten the mounting screws and the terminal screws in the specified torque range.
  Undertightening can cause a short circuit or malfunction.
  Overtightening can cause a short circuit or malfunction due to the damage of the screws or unit.
- Plug the QnA/ACPU/Motion controller(A series) bus connection cable by inserting it into the connector of the connected unit until it "clicks".
  After plugging, check that it has been inserted snugly.
  Not doing so can cause a malfunction due to a contact fault.(GT27 Only)

[TEST OPERATION PRECAUTIONS]

⚠WARNING

- Before performing the test operations of the user creation monitor screen (such as turning ON or OFF bit device, changing the word device current value, changing the settings or current values of the timer or counter, and changing the buffer memory current value), read through the manual carefully and make yourself familiar with the operation method.
  During test operation, never change the data of the devices which are used to perform significant operation for the system.
  False output or malfunction can cause an accident.

[STARTUP/MAINTENANCE PRECAUTIONS]

⚠WARNING

- When power is on, do not touch the terminals.
  Doing so can cause an electric shock or malfunction.
- Correctly connect the battery connector.
  Do not charge, disassemble, heat, short-circuit, solder, or throw the battery into the fire.
  Doing so will cause the battery to produce heat, explode, or ignite, resulting in injury and fire.
- Before starting cleaning or terminal screw retightening, always switch off the power externally in all phases.
  Not switching the power off in all phases can cause a unit failure or malfunction.
  Undertightening can cause a short circuit or malfunction.
  Overtightening can cause a short circuit or malfunction due to the damage of the screws or unit.

⚠CAUTION

- Do not disassemble or modify the unit.
  Doing so can cause a failure, malfunction, injury or fire.
- Do not touch the conductive and electronic parts of the unit directly.
  Doing so can cause a unit malfunction or failure.
- The cables connected to the unit must be run in ducts or clamped.
  Not doing so can cause the unit or cable to be damaged due to the dangling, motion or accidental pulling of the cables or can cause a malfunction due to a cable connection fault.
- When unplugging the cable connected to the unit, do not hold and pull from the cable portion.
  Doing so can cause the unit or cable to be damaged or can cause a malfunction due to a cable connection fault.
- Do not drop the module or subject it to strong shock. A module damage may result.
- Do not drop or give an impact to the battery mounted to the unit.
  Doing so may damage the battery, causing the battery fluid to leak inside the battery.If the battery is dropped or given an impact, dispose of it without using.
- Before touching the unit, always touch grounded metals, etc. to discharge static electricity from human body, etc.
  Not doing so can cause the unit to fail or malfunction.
- Use the battery manufactured by Mitsubishi Electric Corporation.
  Use of other batteries may cause a risk of fire or explosion.
- Dispose of used battery promptly.
  Keep away from children.Do not disassemble and do not dispose of in fire.
- Be sure to shut off all phases of the external power supply before replacing the battery or using the dip switch of the terminating resistor.
  Not doing so can cause the unit to fail or malfunction by static electricity.

[TOUCH PANEL PRECAUTIONS]

⚠CAUTION

- For the analog-resistive film type touch panels, normally the adjustment is not required.
  However, the difference between a touched position and the object position may occur as the period of use elapses.
  When any difference between a touched position and the object position occurs, execute the touch panel calibration.
- When any difference between a touched position and the object position occurs, other object may be activated.
  This may cause an unexpected operation due to incorrect output or malfunction.

[PRECAUTIONS WHEN THE DATA STORAGE IS IN USE]

⚠WARNING

- If the SD card mounted on drive A of the GOT is removed while the GOT is accessed, processing for the GOT might be interrupted about for 20 seconds.
  The GOT cannot be operated during this period.
  The functions that run in the background including a screen updating, alarm, logging, scripts, and others are also interrupted.
  Since this interruption makes an impact to the system operation, it might cause failure.After checking the light off of SD card access LED, remove the SD card.

⚠CAUTION

- If the data storage mounted on the GOT is removed while the GOT is accessed, the data storage and files are damaged.
  To remove the data storage from the GOT, check that the access to the data storage in SD card access LED, the system signal, and others is not performed.
- When inserting a SD card into the GOT, make sure to close the SD card cover.
  Failure to do so causes the data not to be read or written.
- When removing the SD card from the GOT, make sure to support the SD card by hand as it may pop out.
  Failure to do so may cause the SD card to drop from the GOT, resulting in a failure or break.
- When inserting a USB device into a USB interface of the GOT, make sure to insert the device into the interface firmly.
  Failure to do so may cause the USB device to drop from the GOT, resulting in a failure or break.
- Before removing the USB device from the GOT, follow the procedure for removal on the utility screen of the GOT.
  After the successful completion dialog is displayed, remove the USB device by hand carefully.
  Failure to do so may cause the USB device to drop from the GOT, resulting in a failure or break.

[DISPOSAL PRECAUTIONS]

⚠CAUTION

- When disposing of this product, treat it as industrial waste.
  When disposing of batteries, separate them from other wastes according to the local regulations.
  (Refer to the GOT2000 Series User's Manual (Hardware) for details of the battery directive in the EU member states.)

[TRANSPORTATION PRECAUTIONS]

⚠CAUTION

- When transporting lithium batteries, make sure to treat them based on the transport regulations.
  (Refer to the GOT2000 Series User's Manual (Hardware) for details of the regulated models.)
- Make sure to transport the GOT main unit and/or relevant unit(s) in the manner they will not be exposed to the impact exceeding the impact resistance described in the general specifications of this manual, as they are precision devices.
  Failure to do so may cause the unit to fail.
  Check if the unit operates correctly after transportation.
- When fumigants that contain halogen materials such as fluorine, chlorine, bromine, and iodine are used for disinfecting and protecting wooden packaging from insects, they cause malfunction when entering our products.
  Please take necessary precautions to ensure that remaining materials from fumigant do not enter our products, or treat packaging with methods other than fumigation (heat method).
  Additionally, disinfect and protect wood from insects before packing products.

INTRODUCTION

Thank you for choosing Mitsubishi Graphic Operation Terminal (Mitsubishi GOT).
Read this manual and make sure you understand the functions and performance of the GOT thoroughly in advance to ensure correct use.

CONTENTS

SAFETY PRECAUTIONS ..... A - 1
INTRODUCTION ..... A - 8
CONTENTS ..... A - 8
List of Manuals for GT Works3 ..... A - 14
Abbreviations and Generic Terms ..... A - 15

1. PREPARATORY PROCEDURES FOR MONITORING

1.1 Setting the Communication Interface ..... 1 - 3
1.1.1 Setting connected equipment (Channel setting) ..... 1 - 3
1.1.2 I/F communication setting ..... 1 - 7
1.1.3 Precautions ..... 1 - 9
1.2 Writing the Package Data onto the GOT ..... 1 - 10
1.2.1 Writing the Package Data onto the GOT ..... 1 - 10
1.2.2 Checking the package data writing on GOT ..... 1 - 11
1.3 Option Devices for the Respective Connection ..... 1 - 12
1.3.1 Communication module ..... 1 - 12
1.3.2 Option unit ..... 1 - 13
1.3.3 Conversion cables ..... 1 - 13
1.3.4 Serial Multi-Drop Connection Unit ..... 1 - 13
1.3.5 Installing a unit on another unit (Checking the unit installation position) ..... 1 - 14
1.4 Connection Cables for the Respective Connection ..... 1 - 17
1.4.1 GOT connector specifications ..... 1 - 17
1.4.2 Coaxial cableconnector connection method ..... 1 - 18
1.4.3 Terminating resistors of GOT ..... 1 - 19
1.5 Verifying GOT Recognizes Connected Equipment ..... 1 - 20
1.6 Checking for Normal Monitoring ..... 1 - 22
1.6.1 Check on the GOT ..... 1 - 22
1.6.2 Confirming the communication state on the GOT side (For Ethernet connection) ..... 1 - 24
1.6.3 Confirming the communication state to each station (Station monitoring function) ..... 1 - 26
1.6.4 Check on the PLC ..... 1 - 28

MICROCOMPUTER CONNECTION

2. MICROCOMPUTER CONNECTION (SERIAL)

2.1 Microcomputer Connection (Serial) ..... 2 - 2
2.2 System Configuration ..... 2 - 4
2.2.1 For the microcomputer connection (serial) ..... 2 - 4
2.3 Connection Diagram ..... 2 - 5

2.3.1 RS-232 cable ..... 2 - 5
2.3.2 RS-422 cable ..... 2 - 5
2.4 Device Data Area ..... 2 - 6
2.4.1 D devices ..... 2 - 7
2.4.2 R devices ..... 2 - 11
2.4.3 L devices ..... 2 - 12
2.4.4 M devices ..... 2 - 13
2.4.5 SD devices ..... 2 - 14
2.4.6 SM devices ..... 2 - 17
2.5 Message Formats ..... 2 - 19
2.5.1 Data format type and application ..... 2 - 19
2.5.2 List of commands ..... 2 - 21
2.5.3 Formats 1, 2 (GOT-A900 Series microcomputer connection) ..... 2 - 24
2.5.4 Formats 3 to 6 (A compatible 1C frame) ..... 2 - 37
2.5.5 Formats 7 to 10 (QnA compatible 3C/4C frame) ..... 2 - 42
2.5.6 Formats 11 to 13 (Digital Electronics Corporation's memory link method) ..... 2 - 50
2.5.7 Formats 14, 15 (GOT-F900 Series microcomputer connection) ..... 2 - 59
2.6 GOT Side Settings ..... 2 - 73
2.6.1 Setting communication interface (Communication settings) ..... 2 - 73
2.6.2 Communication detail settings ..... 2 - 73
2.7 System Configuration Examples ..... 2 - 75
2.8 Device Range that Can Be Set ..... 2 - 78
2.9 Precautions ..... 2 - 79

3. MICROCOMPUTER CONNECTION (ETHERNET)

3.1 Microcomputer connection (Ethernet) ..... 3 - 2
3.2 System Configuration ..... 3 - 2
3.2.1 For the microcomputer connection (Ethernet) ..... 3 - 2
3.3 Device Data Area ..... 3 - 3
3.3.1 D devices ..... 3 - 4
3.3.2 R devices ..... 3 - 8
3.3.3 L devices ..... 3 - 9
3.3.4 M devices ..... 3 - 10
3.3.5 SD devices ..... 3 - 11
3.3.6 SM devices ..... 3 - 14
3.4 Message Formats ..... 3 - 16
3.4.1 Data format type and application ..... 3 - 16
3.4.2 List of commands ..... 3 - 17
3.4.3 Formats 1, 2 (GOT-A900 Series microcomputer connection) ..... 3 - 19
3.4.4 Formats 3, 4 (GOT-F900 series microcomputer connection) ..... 3 - 31
3.4.5 Formats 5(Digital Electronics Corporation's memory link method) ..... 3 - 45
3.4.6 Formats 6, 7 (4E frame) ..... 3 - 50
3.4.7 Formats 8, 9 (QnA compatible 3E frame) ..... 3 - 60
3.5 GOT Side Settings ..... 3 - 69
3.5.1 Setting communication interface (Communication settings) ..... 3 - 69
3.5.2 Communication detail settings ..... 3 - 69
3.5.3 GOT Ethernet settings ..... 3 - 70
3.6 System Configuration Examples ..... 3 - 71

3.7 Device Range that Can Be Set ..... 3 - 72
3.8 Precautions ..... 3 - 73

MODBUS CONNECTIONS

4. MODBUS(R)/RTU CONNECTION

4.1 Connectable Model List ..... 4 - 2
4.2 System Configuration ..... 4 - 3
4.2.1 Connecting to MODBUS(R)/RTU equipment ..... 4 - 3
4.3 Connection Diagram ..... 4 - 4
4.3.1 RS-232 cable ..... 4 - 4
4.3.2 RS-422/485 cable ..... 4 - 5
4.4 GOT Side Settings ..... 4 - 8
4.4.1 Setting communication interface (Communication settings) ..... 4 - 8
4.4.2 Communication detail settings ..... 4 - 8
4.5 MODBUS(R)/RTU Equipment Side Setting ..... 4 - 10
4.5.1 Communication settings ..... 4 - 10
4.5.2 Station number setting ..... 4 - 13
4.6 Precautions ..... 4 - 13

5. MODBUS(R)/TCP CONNECTION

5.1 Connectable Model List ..... 5 - 2
5.2 System Configuration ..... 5 - 3
5.2.1 Connecting to MODBUS(R)/TCP equipment ..... 5 - 3
5.3 GOT Side Settings ..... 5 - 4
5.3.1 Setting communication interface (Communication settings) ..... 5 - 4
5.3.2 Communication detail settings ..... 5 - 4
5.3.3 GOT Ethernet Setting ..... 5 - 5
5.3.4 Ethernet setting ..... 5 - 6
5.4 MODBUS(R)/TCP Equipment Setting ..... 5 - 7
5.5 Device Range that Can Be Set ..... 5 - 7
5.6 Example of Connection ..... 5 - 11
5.6.1 Connecting to SCHNEIDER PLC (Modicon Premium series and Modicon Quantum series) ..... 5 - 11
5.6.2 Connecting to YOKOGAWA PLC (STARDOM) ..... 5 - 13
5.7 Precautions ..... 5 - 16

CONNECTIONS TO PERIPHERAL EQUIPMENT

6. CONNECTION TO SOUND OUTPUT UNIT

6.1 Connectable Model List ..... 6 - 2
6.2 System Configuration ..... 6 - 2
6.2.1 Connecting to sound output unit ..... 6 - 2
6.3 GOT Side Settings ..... 6 - 3
6.3.1 Setting communication interface ..... 6 - 3
6.4 Precautions ..... 6 - 4

7. CONNECTION TO EXTERNAL I/O DEVICE

7.1 Connectable Model List ..... 7 - 2
7.2 System Configuration ..... 7 - 3
7.2.1 Connecting to the external I/O device ..... 7 - 3
7.3 Connection Diagram ..... 7 - 5
7.3.1 Connection cable between external I/O unit and connector/terminal block converter module ..... 7 - 5
7.3.2 Connection diagram between connector/terminal block converter module and user-created original operation panel ..... 7 - 7
7.3.3 Connection cable between external I/O unit and operation panel ..... 7 - 11
7.4 GOT Side Settings ..... 7 - 14
7.4.1 Setting communication interface ..... 7 - 14
7.5 Precautions ..... 7 - 15

8. BAR CODE READER CONNECTION

8.1 Connectable Model List ..... 8 - 2
8.2 System Configuration ..... 8 - 2
8.2.1 Connecting to bar code reader ..... 8 - 2
8.3 GOT Side Settings ..... 8 - 3
8.3.1 Setting communication interface ..... 8 - 3
8.3.2 Communication detail settings ..... 8 - 4
8.4 System Configuration Examples ..... 8 - 5
8.5 Precautions ..... 8 - 7

9. PC REMOTE CONNECTION

9.1 Connectable Model List ..... 9 - 2
9.2 Serial Connection ..... 9 - 3
9.2.1 System Configuration ..... 9 - 3
9.2.2 Connection Diagram ..... 9 - 4
9.2.3 GOT Side Settings ..... 9 - 5
9.2.4 Communication detail settings ..... 9 - 5
9.2.5 Installing and setting up computer remote operation driver ..... 9 - 7
9.2.6 Precautions ..... 9 - 7
9.3 Ethernet Connection ..... 9 - 8
9.3.1 System Configuration ..... 9 - 8
9.3.2 GOT Side Settings ..... 9 - 9
9.3.3 Install and setting the required software ..... 9 - 9
9.3.4 Precautions ..... 9 - 9

10. VNC(R) SERVER CONNECTION

10.1 Connectable Model List ..... 10 - 2
10.2 System Configuration ..... 10 - 2
10.3 GOT Side Settings ..... 10 - 3
10.3.1 VNC(R) server function setting ..... 10 - 3
10.3.2 Setting communication interface (Communication settings) ..... 10 - 3
10.4 Setting in Personal Computer ..... 10 - 4

11. VIDEO/RGB CONNECTION

11.1 Connectable Model List ..... 11 - 2
11.2 System Configuration ..... 11 - 3
11.2.1 Displaying video image on GOT ..... 11 - 3
11.2.2 Displaying GOT screen on external monitor ..... 11 - 5
11.3 Connection Diagram ..... 11 - 6
11.3.1 Coaxial cable ..... 11 - 6
11.3.2 Analog RGB cable ..... 11 - 6
11.4 GOT Side Settings ..... 11 - 8
11.4.1 Setting communication interface ..... 11 - 8
11.4.2 Communication detail settings ..... 11 - 8
11.4.3 Setting the video/RGB function ..... 11 - 9
11.5 Precautions ..... 11 - 9

12. PRINTER CONNECTION

12.1 Connectable Model List ..... 12 - 2
12.2 System Configuration ..... 12 - 2
12.2.1 Connecting to PictBridge compatible printer ..... 12 - 2
12.2.2 Connecting to serial printer ..... 12 - 3
12.3 GOT Side Settings ..... 12 - 4
12.3.1 Setting communication interface ..... 12 - 4
12.3.2 Communication detail settings ..... 12 - 5
12.4 Precautions ..... 12 - 6

13. MULTIMEDIA CONNECTION

13.1 Connectable Model List ..... 13 - 2
13.2 System Configuration ..... 13 - 2
13.2.1 Saving video image and displaying it on GOT ..... 13 - 2
13.2.2 Sending video image to personal computer ..... 13 - 3
13.3 Connection Diagram ..... 13 - 4
13.3.1 Coaxial cable ..... 13 - 4
13.4 GOT Side Settings ..... 13 - 5
13.4.1 Setting communication interface ..... 13 - 5
13.4.2 Communication detail settings ..... 13 - 6
13.4.3 Installing and setting multimedia interaction tool onto personal computer ..... 13 - 7
13.4.4 Setting the multimedia function ..... 13 - 7
13.4.5 Set the gateway function ..... 13 - 7
13.5 Precautions ..... 13 - 8

14. RFID CONNECTION

14.1 Connectable Model List ..... 14 - 2
14.2 System Configuration ..... 14 - 2
14.2.1 Connecting to RFID ..... 14 - 2
14.3 GOT Side Settings ..... 14 - 4
14.3.1 Setting communication interface ..... 14 - 4
14.3.2 Communication detail settings ..... 14 - 5
14.4 Precautions ..... 14 - 6

15. WIRELESS LAN CONNECTION

15.1 System Configuration ..... 15 - 2
15.1.1 Connecting to wireless LAN ..... 15 - 2
15.2 GOT Side Settings ..... 15 - 3
15.2.1 Setting communication interface (Communication settings) ..... 15 - 3
15.2.2 Communication detail settings ..... 15 - 3
15.2.3 GOT wireless LAN I/F setting ..... 15 - 4
15.3 Precautions ..... 15 - 5

REVISIONS

WARRANTY

List of Manuals for GT Works3

For the manuals related to this product, install the manuals with the drawing software.
If you need a printed manual, consult your local Mitsubishi representative or branch office.

■1. List of Manuals for GT Designer3(GOT2000)

(1) Screen drawing software manuals

Manual name	Manual number (Model code)
GT Works3 Version1 Installation Procedure Manual	-
GT Designer3 (GOT2000) Help	-
GT Converter2 Version3 Operating Manual for GT Works3	SH-080862ENG (1D7MB2)
GOT2000 Series MES Interface Function Manual for GT Works3 Version1	SH-081228ENG

(2) Connection manuals

Manual name	Manual number (Model code)
GOT2000 Series Connection Manual (Mitsubishi Products) for GT Works3 Version1	SH-081197ENG (1D7MJ8)
GOT2000 Series Connection Manual (Non-Mitsubishi Products 1) for GT Works3 Version1	SH-081198ENG
GOT2000 Series Connection Manual (Non-Mitsubishi Products 2) for GT Works3 Version1	SH-081199ENG
GOT2000 Series Connection Manual (Microcomputer, MODBUS Products, Peripherals) for GT Works3 Version1	SH-081200ENG

(3) GT SoftGOT2000 manuals

Manual name	Manual number (Model code)
GT SoftGOT2000 Version1 Operating Manual	SH-081201ENG

(4) GOT2000 manuals

Manual name	Manual number (Model code)
GOT2000 Series User's Manual (Hardware)	SH-081194ENG (1D7MJ5)
GOT2000 Series User's Manual (Utility)	SH-081195ENG (1D7MJ6)
GOT2000 Series User's Manual (Monitor)	SH-081196ENG (1D7MJ7)

■2. List of Manuals for GT Designer3(GOT1000)

Refer to the Help and manuals for GT Designer3(GOT1000)

Abbreviations and Generic Terms

The following shows the abbreviations and generic terms used in Help.

■1. GOT

Abbreviations and generic terms			Description
GOT2000 Series	GT27	GT2712-S	GT2712-STBA, GT2712-STWA, GT2712-STBD, GT2712-STWD
		GT2710-S	GT2710-STBA, GT2710-STBD
		GT2710-V	GT2710-VTBA, GT2710-VTWA, GT2710-VTBD, GT2710-VTWD
		GT2708-S	GT2708-STBA, GT2708-STBD
		GT2708-V	GT2708-VTBA, GT2708-VTBD
	GT23	GT2310-V	GT2310-VTBA, GT2310-VTBD
		GT2308-V	GT2308-VTBA, GT2308-VTBD
	GT SoftGOT2000		GT SoftGOT2000 Version1
GOT1000 Series			GOT1000 Series
GOT900 Series			GOT-A900 Series, GOT-F900 Series
GOT800 Series			GOT-800 Series

■2. Communication unit

Abbreviations and generic terms	Description
Bus connection unit	GT15-QBUS, GT15-QBUS2, GT15-ABUS, GT15-ABUS2, GT15-75QBUSL, GT15-75QBUS2L, GT15-75ABUSL, GT15-75ABUS2L
Serial communication unit	GT15-RS2-9P, GT15-RS4-9S, GT15-RS4-TE
MELSECNET/H communication unit	GT15-J71LP23-25, GT15-J71BR13
CC-Link IE Controller Network communication unit	GT15-J71GP23-SX
CC-Link IE Field Network communication unit	GT15-J71GF13-T2
CC-Link communication unit	GT15-J61BT13
Wireless LAN communication unit	GT25-WLAN
Serial multi-drop connection unit	GT01-RS4-M
Connection conversion adapter	GT10-9PT5S

■3. Option unit

Abbreviations and generic terms		Description
Printer unit		GT15-PRN
Video/RGB unit	Video input unit	GT27-V4-Z (A set of GT16M-V4 and GT27-IF1000)
	RGB input unit	GT27-R2-Z (A set of GT16M-R2 and GT27-IF1000)
	Video/RGB input unit	GT27-V4R1-Z (A set of GT16M-V4R1 and GT27-IF1000)
	RGB output unit	GT27-ROUT-Z (A set of GT16M-ROUT and GT27-IF1000)
Multimedia unit		GT27-MMR-Z (A set of GT16M-MMR and GT27-IF1000)
Video signal conversion unit		GT27-IF1000
External I/O unit		GT15-DIO, GT15-DIOR
Sound output unit		GT15-SOUT

■4. Option

Abbreviations and generic terms		Description
SD card		L1MEM-2GBSD, L1MEM-4GBSD
Battery		GT11-50BAT, GT11-BAT
Protective sheet	For GT27	GT25-12PSGC, GT25-10PSGC, GT25-08PSGC, GT25-12PSCC, GT25-10PSCC, GT25-08PSCC, GT25-12PSCC-UC, GT25-10PSCC-UC, GT25-08PSCC-UC
	For GT23	GT25-10PSCC-UC, GT25-08PSCC-UC
Protective cover for oil		GT20-10PCO, GT20-08PCO
USB environmental protection cover		GT25-UCOV
Stand		GT15-90STAND, GT15-80STAND, GT15-70STAND, GT15-60STAND
Attachment		GT15-70ATT-98, GT15-70ATT-87, GT15-60ATT-97, GT15-60ATT-96, GT15-60ATT-87, GT15-60ATT-77

■5. Software

(1) Software related to GOT

Abbreviations and generic terms	Description
GT Works3	SW1DNC-GTW3-J, SW1DND-GTW3-J, SW1DNC-GTW3-E, SW1DND-GTW3-E, SW1DND-GTW3-C
GT Designer3 Version1	Screen drawing software GT Designer3 for GOT2000/GOT1000 series
GT Designer3	Screen drawing software for GOT2000 series included in GT Works3
GT Designer3 (GOT2000)	
GT Designer3 (GOT1000)	Screen drawing software for GOT1000 series included in GT Works3
GT Simulator3	Screen simulator GT Simulator3 for GOT2000/GOT1000/GOT900 series
GT SoftGOT2000	Monitoring software GT SoftGOT2000 series
GT Converter2	Data conversion software GT Converter2 for GOT1000/GOT900 series
GT Designer2 Classic	Screen drawing software GT Designer2 Classic for GOT900 series
GT Designer2	Screen drawing software GT Designer2 for GOT1000/GOT900 series
DU/WIN	Screen drawing software FX-PCS-DU/WIN for GOT-F900 series

(2) Software related to iQ Works

Abbreviations and generic terms	Description
iQ Works	Abbreviation of iQ Platform compatible engineering environment MELSOFT iQ Works
MELSOFT Navigator	Generic term for integrated development environment software included in the SW DNC-IQWK (iQ Platform compatible engineering environment MELSOFT iQ Works) (□ indicates a version.)

(3) Other software

Abbreviations and generic terms	Description
GX Works2	SW□DNC-GXW2-J (-JA, -JAZ) type programmable controller engineering software (□ indicates a version.)
GX Simulator2	GX Works2 with the simulation function
GX Simulator	SW□D5C-LLT-J (-JV) type ladder logic test tool function software package (SW5D5C-LLT (-V) or later versions) (□ indicates a version.)
GX Developer	SW□D5C-GPPW-J (-JV)/SW□D5F-GPPW (-V) type software package (□ indicates a version.)
GX LogViewer	SW□DNN-VIEWER-J type software package (□ indicates a version.)
PX Developer	SW□D5C-FBDQ-J type FBD software package for process control (□ indicates a version.)
MT Works2	Motion controller engineering environment MELSOFT MT Works2(SW□DNC-MTW2-J) (□ indicates a version.)
MT Developer	SW□RNC-GSV type integrated start-up support software for motion controller Q series (□ indicates a version.)
MR Configurator2	SW□DNC-MRC2-J type servo configuration software (□ indicates a version.)
MR Configurator	MRZJW□-SETUP type servo configuration software (□ indicates a version.)
FR Configurator	Inverter setup software (FR-SW□-SETUP-WJ) (□ indicates a version.)
NC Configurator	CNC parameter setting support tool NC Configurator
FX Configurator-FP	Parameter setting, monitoring, and testing software packages for FX3U-20SSC-H (SW□D5CFXSSCJ) (□ indicates a version.)
FX3U-ENET-L Configuration tool	FX3U-ENET-L type Ethernet module setting software (SW1D5-FXENETL-J)
RT ToolBox2	Robot program creation software (3D-11C-WINJ)
MX Component	MX Component Version□(SW□D5C-ACT-J, SW□D5C-ACT-JA) (□ indicates a version.)
MX Sheet	MX Sheet Version□(SW□D5C-SHEET-J, SW□D5C-SHEET-JA) (□ indicates a version.)
QnUDVCPU·LCPU Logging Configuration Tool	QnUDVCPU·LCPU logging configuration tool (SW1DNN-LLUTL-J)

■6. License key (for GT SoftGOT2000)

Abbreviations and generic terms	Description
License key	GT27-SGTKEY-U

■7. Others

Abbreviations and generic terms	Description
IAI	IAI Corporation
AZBIL	Azbil Corporation
OMRON	OMRON Corporation
KEYENCE	KEYENCE CORPORATION
KOYO EI	KOYO ELECTRONICS INDUSTRIES CO., LTD.
JTEKT	JTEKT Corporation
SHARP	Sharp Manufacturing Systems Corporation
SHINKO	Shinko Technos Co., Ltd.
CHINO	CHINO CORPORATION
TOSHIBA	TOSHIBA CORPORATION
TOSHIBA MACHINE	TOSHIBA MACHINE CO., LTD.
PANASONIC	Panasonic Corporation
PANASONIC IDS	Panasonic Industrial Devices SUNX Co., Ltd.
HITACHI IES	Hitachi Industrial Equipment Systems Co., Ltd.
HITACHI	Hitachi, Ltd.
FUJI ELECTRIC	FUJI ELECTRIC CO., LTD.
YASKAWA	YASKAWA Electric Corporation
YOKOGAWA	Yokogawa Electric Corporation
RKC	RKC INSTRUMENT INC.
ALLEN-BRADLEY	Allen-Bradley products manufactured by Rockwell Automation, Inc.
GE IP	GE Intelligent Platforms KK
LS IS	LS Industrial Systems Co., Ltd.
SCHNEIDER	Schneider Electric SA
SICK	SICK AG
SIEMENS	Siemens AG
PLC	Programmable controller manufactured by each corporation
Control equipment	Control equipment manufactured by each corporation
Temperature controller	Temperature controller manufactured by each corporation
Indicating controller	Indicating controller manufactured by each corporation
Controller	Controller manufactured by each corporation

1

PREPARATORY PROCEDURES FOR MONITORING

1.1 Setting the Communication Interface . . . . . 1 - 3
1.2 Writing the Package Data onto the GOT . . . . . 1 - 10
1.3 Option Devices for the Respective Connection . . . . . 1 - 12
1.4 Connection Cables for the Respective Connection . . . . . 1 - 17
1.5 Verifying GOT Recognizes Connected Equipment . . . . . 1 - 20
1.6 Checking for Normal Monitoring. . . . . 1 - 22

1. PREPARATORY PROCEDURES FOR MONITORING

The following shows the procedures to be taken before monitoring and corresponding reference sections.


Setting the communication interface
Determine the connection type and channel No. to be used, and perform the communication setting.
1.1Setting the Communication Interface
Each chapter GOT Side Settings
Writing the project data and OS
Write the standard monitor OS, communication driver, option OS, project data and communication settings onto the GOT.
1.2.1Writing the Package Data onto the GOT
Verifying the project data and OS
Verify the standard monitor OS, communication driver, option OS, project data and communication settings are properly written onto the GOT.
1.2.2Checking the package data writing on GOT
Attaching the communication unit and connecting the cable
Mount the optional equipment and prepare/connect the connection cable according to the connection type.
1.3Option Devices for the Respective Connection
1.4Connection Cables for the Respective Connection
Each chapter System Configuration
Each chapter Connection Diagram
Verifying GOT recognizes connected equipment
Verify the GOT recognizes controllers on [Communication Settings] of the Utility.
1.5Verifying GOT Recognizes Connected Equipment
Verifying the GOT is monitoring normally
Verify the GOT is monitoring normally using Utility, Developer, etc.
1.6Checking for Normal Monitoring

1.1 Setting the Communication Interface

Set the communication interface of GOT and the connected equipment.
When using the GOT at the first time, make sure to set the channel of communication interface and the communication driver before writing to GOT.
Set the communication interface of the GOT at [Controller Setting] and [I/F Communication Setting] in GT Designer3.

1.1.1 Setting connected equipment (Channel setting)

Set the channel of the equipment connected to the GOT.

■ Setting



1. Select [Common] → [Controller Setting] from the menu.
2. The Controller Setting dialog box appears. Select the channel No. to be used from the list menu.
3. Refer to the following explanations for the setting.

POINT

Channel No.2 to No.4

Use the channel No.2 to No.4 when using the Multi-channel function.
For details of the Multi-channel function, refer to the following.

☞ Mitsubishi Products 20. MULTI-CHANNEL FUNCTION

■ Setting item

This section describes the setting items of the Manufacturer, Controller Type, Driver and I/F.
When using the channel No.2 to No.4, put a check mark at [Use CH*].



Item	Description
Use CH*	Select this item when setting the channel No.2 to No.4.
Manufacturer	Select the manufacturer of the equipment to be connected to the GOT.
Type	Select the type of the equipment to be connected to the GOT. For the settings, refer to the following. ☞ (2)Setting [Controller Type]
I/F	Select the interface of the GOT to which the equipment is connected. For the settings, refer to the following. ☞ (3)Setting [I/F]
Driver	Select the communication driver to be written to the GOT. For the settings, refer to the following. ☞ (1)Setting [Driver]
Detail Setting	Make settings for the transmission speed and data length of the communication driver. ☞ Refer to each chapter of the equipment to be connected to the GOT.

(1) Setting [Driver]

The displayed items for a driver differ according to the settings [Manufacturer], [Controller Type] and [I/F].
When the driver to be set is not displayed, confirm if [Manufacturer], [Controller Type] and [I/F] are correct.
For the settings, refer to the following.

☞ [Setting the communication interface] section in each chapter

(2) Setting [Controller Type]

The types for the selection differs depending on the PLC to be used.
For the settings, refer to the following.

Type	Model name	Manufacturer
MODBUS	NFCP100	YOKOGAWA
	NFJT100	
	TSX P57 203M	Schneider Electric
	TSX P57 253M	
	TSX P57 303M	
	TSX P57 353M	
	TSX P57 453M	
	140 CPU 311 10	
	140 CPU 434 12U	
	140 CPU 534 14U	
	140 CPU 651 50	
	140 CPU 651 60	
	140 CPU 671 60	
	140 CPU 113 02	
	140 CPU 113 03	
	140 CPU 434 12A	
	140 CPU 534 14A	
Microcomputer connection	Microcomputer	-

(3) Setting [I/F]

The interface differs depending on the GOT to be used.

Set the I/F according to the connection and the position of communication unit to be mounted onto the GOT.



(Example: In the case of the GT27)

1.1.2 I/F communication setting

This function displays the list of the GOT communication interfaces.
Set the channel and the communication driver to the interface to be used.

■ Setting



1. Select [Common] → [I/F Communication Setting] from the menu.
2. The I/F Communication Setting dialog box appears. Make the settings with reference to the following explanation.

■ Setting item

The following describes the setting items for the standard I/F setting and extension I/F setting.



Item		Description
Standard I/F setting		Set channel No. and drivers to the GOT standard interfaces.
	CH No.	Set the CH No. according to the intended purpose. 0: Not used 1 to 4: Used for connecting a controller of channel No. 1 to 4 set in Setting connected equipment (Channel setting) 5 to 8: Used for barcode function, RFID function, remote personal computer operation function (serial) 9: Used for connecting Host (PC), Ethernet download A: Used for the report function (with a serial printer), hard copy function (with a serial printer), remote personal computer operation function (Ethernet), VNC server function, gateway function, and MES interface function. Multi: Used for multi-channel Ethernet connection
	I/F	The communication type of the GOT standard interface is displayed.
	Driver	Set the driver for the device to be connected. • None • Host (Personal computer) • Each communication driver for connected devices
	Detail Setting	Make settings for the transmission speed and data length of the communication driver. ☞ Refer to each chapter of the equipment to be connected to the GOT.
	RS232 Setting	To validate the 5V power supply function in RS232, mark the [Enable the 5V power supply] checkbox. The RS232 setting is invalid when the CH No. of [I/F-1: RS232] is [9].
Extension I/F setting		Set the communication unit attached to the extension interface of the GOT.
	CH No.	Set the CH No. according to the intended purpose. The number of channels differs depending on the GOT to be used. 0: Not used 1 to 4: Used for connecting a controller of channel No. 1 to 4 set in Setting connected equipment (Channel setting) 5 to 8: Used for barcode function, RFID function, remote personal computer operation (serial) A: Used for the video/RGB display function, multimedia function, external I/O function, operation panel function, RGB output function, report function, hard copy function (with a printer), sound output function, gateway function, MES interface function, and wireless LAN connection.

POINT

Channel No., drivers, [RS232 Setting]

(1) Channel No.2 to No.4
Use the channel No.2 to No.4 when using the Multi-channel function.
For details of the Multi-channel function, refer to the following.

☞ Mitsubishi Products 19. MULTI-CHANNEL FUNCTION

(2) Drivers
The displayed items for a driver differ according to the settings [Manufacturer], [Controller Type] and [I/F].
When the driver to be set is not displayed, confirm if [Manufacturer], [Controller Type] and [I/F] are correct.

☞ [Setting the communication interface] section in each chapter

1.1.3 Precautions

(1) When using the multiple CPU system
When using the GOT to monitor the multiple CPU system of other stations, select [MELSEC-Q(Multi)/Q-Motion] or [MELSEC-QnU/DC, Q17nD/M/NC/DR, CRnD-700] for the type, regardless of the host PLC CPU type (QCPU, QnACPU, ACPU).
When other models are selected, the setting of the CPU No. becomes unavailable.

(2) Precautions for changing model

(a) When devices that cannot be converted are included.
When setting of [Manufacturer] or [Controller Type] is changed, GT Designer3 displays the device that cannot be converted (no corresponding device type, or excessive setting ranges) as [??]. In this case, set the device again.

(b) When the changed Manufacturer or Controller Type does not correspond to the network.
The network will be set to the host station.

(c) When the Manufacturer or Controller Type is changed to [None]
The GT Designer3 displays the device of the changed channel No. as [??]. In this case, set the device again.
Since the channel No. is retained, the objects can be reused in other channel No. in a batch by using the [Device Bach Edit], [CH No. Batch Edit] or [Device List].

1.2 Writing the Package Data onto the GOT

Write the package data onto the GOT.
For details on writing to GOT, refer to the following manual.

GT Designer3 (GOT2000) Help

1.2.1 Writing the Package Data onto the GOT



1. Select [Communication] → [Write to GOT…] from the menu.
2. The [Communication configuration] dialog box appears.
   Set the communication setting between the GOT and the personal computer.
   Click the OK button when settings are completed.
3. The [GOT Write] tab appears on the [Communicate with GOT] dialog box.
   Select the [Project data, OS] radio button of the Write Data.
4. Check-mark a desired standard monitor OS, communication driver, option OS, extended function OS, and Communication Settings and click the [GOT Write] button.

1.2.2 Checking the package data writing on GOT

Confirm if the package data is properly written onto the GOT by reading from GOT using GT Designer3.
For reading from the GOT, refer to the following manual.

GT Designer3 (GOT2000) Help



1. Select [Communication] → [Read from GOT…] from the menu.
2. The [Communication configuration] dialog box appears.
   Set the communication setting between the GOT and the personal computer.
   Click the OK button when settings are completed.
3. The [GOT Read] tab appears on the [Communicate with GOT] dialog box.
   Select the [Drive information] radio button of the Read Data.
4. Click the [Info Reception] button.
5. Confirm that the project data and OS are written correctly onto the GOT.

1.3 Option Devices for the Respective Connection

The following shows the option devices to connect in the respective connection type.
For the specifications, usage and connecting procedure on option devices, refer to the respective device manual.

1.3.1 Communication module

Product name	Model	Specifications
Bus connection unit	GT15-QBUS	For QCPU (Q mode), motion controller CPU (Q series) Bus connection (1ch) unit standard model
	GT15-QBUS2	For QCPU (Q mode), motion controller CPU (Q series) Bus connection (2ch) unit standard model
	GT15-ABUS	For A/QnACPU, motion controller CPU (A series) Bus connection (1ch) unit standard model
	GT15-ABUS2	For A/QnACPU, motion controller CPU (A series) Bus connection (2ch) unit standard model
	GT15-75QBUSL	For QCPU (Q mode), motion controller CPU (Q series) Bus connection (1ch) unit slim model
	GT15-75QBUS2L	For QCPU (Q mode), motion controller CPU (Q series) Bus connection (2ch) unit slim model
	GT15-75ABUSL	For A/QnACPU, motion controller CPU (A series) Bus connection (1ch) unit slim model
	GT15-75ABUS2L	For A/QnACPU, motion controller CPU (A series) Bus connection (1ch) unit slim model
Serial communication unit	GT15-RS2-9P	RS-232 serial communication unit (D-sub 9-pin (male))
	GT15-RS4-9S	RS-422/485 serial communication unit (D-sub 9-pin (female))
	GT15-RS4-TE	RS-422/485 serial communication unit (terminal block)
MELSECNET/H communication unit	GT15-J71LP23-25	Optical loop unit
	GT15-J71BR13	Coaxial bus unit
MELSECNET/10 communication unit	GT15-J71LP23-25	Optical loop unit (MELSECNET/H communication unit used in the MNET/10 mode)
	GT15-J71BR13	Coaxial bus unit (MELSECNET/H communication unit used in the MNET/10 mode)
CC-Link IE Controller Network communication unit	GT15-J71GP23-SX	Optical loop unit
CC-Link IE Field Network communication unit	GT15-J71GF13-T2	CC-Link IE Field Network (1000BASE-T) unit
CC-Link communication unit	GT15-J61BT13	Intelligent device station unit CC-LINK Ver. 2 compatible
Ethernet communication unit	Built into GOT	Ethernet (100Base-TX)
Wireless LAN communication unit	GT25-WLAN	For the connection to personal computer IEEE802.11b/g/n compatible, built-in antenna, station (wireless LAN adapter), for Japanese domestic use

1.3.2 Option unit

Product name	Model	Specifications
Multimedia unit	GT27-MMR-Z	For video input signal (NTSC/PAL) 1 ch, playing movie
Video input unit	GT27-V4-Z	For video input signal (NTSC/PAL) 4 ch
RGB input unit	GT27-R2-Z	For analog RGB input signal 2 ch
Video/RGB input unit	GT27-V4R1-Z	For video input signal (NTSC/PAL) 4 ch, for analog RGB mixed input signal 1 ch
RGB output unit	GT27-ROUT-Z	For analog RGB output signal 1 ch
Sound output unit	GT15-SOUT	For sound output
External I/O unit	GT15-DIOR	For the connection to external I/O device or operation panel (Negative Common Input/Source Type Output)
	GT15-DIO	For the connection to external I/O device or operation panel (Positive Common Input/Sink Type Output)

1.3.3 Conversion cables

Product name	Model	Specifications
RS-485 terminal block conversion modules	FA-LTBGT2R4CBL05	RS-422/485 (Connector) ⟷ RS-485 (Terminal block) Supplied connection cable dedicated for the conversion unit
	FA-LTBGT2R4CBL10	
	FA-LTBGT2R4CBL20	

1.3.4 Serial Multi-Drop Connection Unit

Product name	Model	Specifications
Serial multi-drop connection unit	GT01-RS4-M	GOT multi-drop connection module ☞ Mitsubishi Products18. CNC CONNECTION

1.3.5 Installing a unit on another unit (Checking the unit installation position)

This section describes the precautions for installing units on another unit.
For the installation method of each unit, refer to the following manual.

GOT2000 Series User's Manual (Hardware)

■ When using a bus connection unit

The installation position varies depending on the bus connection unit to be used.

(1) Wide bus units (GT15-75QBUS(2)L, GT15-75ABUS(2)L, GT15-QBUS2, GT15-ABUS2)

Install a bus connection unit in the 1st stage of the extension interface.
If a bus connection unit is installed in the 2nd stage or above, the unit cannot be used.

Example: Installing a bus connection unit and serial communication units



(2) Standard size bus connection unit (GT15-QBUS and GT15-ABUS)
A bus connection unit can be installed in any position (1st to 3rd stage) of the extension interface.

Example: Installing a bus connection unit and serial communication units



■ When using a MELSECNET/H communication unit, CC-Link IE Controller Network communication unit, or CC-Link communication unit (GT15-J61BT13)

Install a MELSECNET/H communication unit, CC-Link IE Controller Network communication unit, or CC-Link communication unit in the 1st stage of an extension interface.
If a bus connection unit is installed in the 2nd stage or above, the unit cannot be used.

Example: When installing a MELSECNET/H communication unit and a serial communication unit



■ When using a serial communication unit

A serial communication unit can be installed in any position (1st to 3rd stage) of the extension interface.



■ When using the sound output unit or external I/O unit

The sound output unit or external I/O unit can be installed in any position (1st to 3rd stage) of the extension interface.

Example: When installing a sound output unit



■ When using the video input unit, RGB input unit, video/RGB input unit, RGB output unit, or multimedia unit

Install the video input unit, RGB input unit, video/RGB input unit, RGB output unit, or multimedia unit at the 1st stage of the extension interface. These communication units cannot be used if installed in the 2nd or higher stage.
When any of these units is used, the communication units indicated below must be installed in the 2nd stage of the extension interface.

Communication unit	Model
Bus connection unit	GT15-QBUS2, GT15-ABUS2
MELSECNET/H communication unit	GT15-J71LP23-25, GT15-J71BR13
CC-Link IE Controller Network connection	GT15-J71GP23-SX
CC-Link communication unit	GT15-J61BT13

Example: When installing a video input unit and a MELSECNET/H communication unit



1.4 Connection Cables for the Respective Connection

To connect the GOT to a device in the respective connection type, connection cables between the GOT and a device are necessary.
For cables needed for each connection, refer to each chapter for connection.

1.4.1 GOT connector specifications

The following shows the connector specifications on the GOT side.
Refer to the following table when preparing connection cables by the user.

■ RS-232 interface

Use the following as the RS-232 interface and the RS-232 communication unit connector on the GOT. For the GOT side of the connection cable, use a connector and connector cover applicable to the GOT connector.

(1) Connector specifications

GOT	Hardware Version	Connector type	Connector model	Manufacturer
GT27 GT23	-	9-pin D-sub (male) inch screw fixed type	17LE-23090-27(D4C□)	DDK Ltd.
GT15-RS2-9P	-	9-pin D-sub (male) inch screw fixed type	17LE-23090-27(D3CC)	DDK Ltd.
GT01-RS4-M	-			

(2) Connector pin arrangement

GT27, GT15-RS2-9P, GT01-RS4-M
GOT main part connector see from the front    9-pin D-sub (male)

■ RS-422/485 interface

Use the following as the RS-422/485 interface and the RS-422/485 communication unit connector on the GOT.
For the GOT side of the connection cable, use a connector and connector cover applicable to the GOT connector.

(1) Connector model

GOT	Connector type	Connector model	Manufacturer
GT27 GT23	9-pin D-sub (female) M2.6 millimeter screw fixed type	17LE-13090-27(D2AC)	DDK Ltd.
GT15-RS4-9S	9-pin D-sub (female) M2.6 millimeter screw fixed type	17LE-13090-27(D3AC)	DDK Ltd.
GT01-RS4-M			
GT15-RS4-TE	-	-	SL-SMT3.5/10/90F BOX

(2) Connector pin arrangement

GT27, GT15-RS4-9P, GT01-RS4-M
GOT main part connector see from the front    9-pin D-sub (female)

1.4.2 Coaxial cableconnector connection method

The following describes the method for connecting the BNC connector (connector plug for coaxial cable) and the cable.

⚠CAUTION

- Solder the coaxial cable connectors properly.
  Insufficient soldering may result in malfunctions.





1. Remove the external sheath of the coaxial cable with dimensions as shown below.

Cable in use	A
3C-2V	15mm
5C-2V, 5C-2V-CCY	10mm



2. Pass the nut, washer, gasket, and clamp through the coaxial cable as shown on the left and loosen the external conductor.



3. Cut the external conductor, insulting material, and internal conductor with the dimensions as shown below.
   Note that the external conductor should be cut to the same dimension as the tapered section of the clamp and smoothed down to the clamp.

Cable in use	B	C
3C-2V	6 mm	3 mm
5C-2V, 5C-2V-CCY	7 mm	5 mm



4. Solder the contact to the internal conductor.



5. 4. Insert the connector assembly shown in ### into the plug shell and screw the nut into the plug shell.

Precautions for soldering

Note the following precautions when soldering the internal conductor and contact.

- Make sure that the solder does not bead up at the soldered section.
- Make sure there are no gaps between the connector and cable insulator or they do not cut into each other.
- Perform soldering quickly so the insulation material does not become deformed.

1.4.3 Terminating resistors of GOT

The following shows the terminating resistor specifications on the GOT side.
When setting the terminating resistor in each connection type, refer to the following.

■ RS-422/485 communication unit

Set the terminating resistor using the terminating resistor setting switch.

Terminating resistor*1	Switch No.	
	1	2
100 OHM	ON	ON
Disable	OFF	OFF



*1 The default setting is "Disable".

• For RS422/485 communication unit



Terminating resistor setting switch

Rear view of RS-422/485 communication unit.

■ GT27

Set the terminating resistor using the terminating resistor setting switch.

Terminating resistor*1	Switch No.	
	1	2
100 OHM	ON	ON
Disable	OFF	OFF



*1 The default setting is "Disable".

• For GT2710-V



Terminating resistor setting switch
(inside the cover)

• For GT2310-V



Terminating resistor setting switch
(inside the cover)

1.5 Verifying GOT Recognizes Connected Equipment

Verify the GOT recognizes controllers on [Communication Settings] of the Utility.

- Channel number of communication interface, communication drivers allocation status
- Communication unit installation status

For details on the Utility, refer to the following manual.

GOT2000 Series User's Manual (Utility)





1. After powering up the GOT, touch [GOT basic set] → [Controller] from the Utility.

2. The [Communication Settings] appears.

3. Verify that the communication driver name to be used is displayed in the communication interface box to be used.

4. When the communication driver name is not displayed normally, carry out the following procedure again.
1.1Setting the Communication Interface

POINT

Utility

(1) How to display Utility (at default)

Utility call key
1-point press on GOT screen
upper-left corner



Utility display



(2) Utility call

When setting [Pressing time] to other than 0 second on the setting screen of the utility call key, press and hold the utility call key until the buzzer sounds. For the setting of the utility call key, refer to the following.

☞ GOT2000 Series User's Manual (Utility)

(3) Communication interface setting by the Utility

The communication interface setting can be changed on the Utility's [Communication setting] after writing [Communication Settings] of project data.
For details on the Utility, refer to the following manual.

☞ GOT2000 Series User's Manual (Utility)

(4) Precedence in communication settings

When settings are made by GT Designer3 or the Utility, the latest setting is effective.

1.6 Checking for Normal Monitoring

1.6.1 Check on the GOT

■ Check for errors occurring on the GOT

Presetting the system alarm to project data allows you to identify errors occurred on the GOT, PLC CPU, servo amplifier and communications.
For details on the operation method of the GOT Utility screen, refer to the following manual.

GOT2000 Series User's Manual (Utility)



HINT

Alarm popup display

With the alarm popup display function, alarms are displayed as a popup display regardless of whether an alarm display object is placed on the screen or not (regardless of the display screen).
Since comments can be flown from right to left, even a long comment can be displayed all.
For details of the alarm popup display, refer to the following manual.

GT Designer3 (GOT2000) Help

■ Write data to virtual devices inside GOT (For microcomputer connection)

Send a message from the host to the GOT, and confirm that the values are stored in the virtual devices inside the GOT.

(☞ 2.7 System Configuration Examples)



1.6.2 Confirming the communication state on the GOT side (For Ethernet connection)

■ Confirming the communication state on Windows®, GT Designer3

(1) When using the Command Prompt of Windows®

Execute a Ping command at the Command Prompt of Windows®.

(a) When normal communication

C:\>Ping 192.168.3.18

Reply from 192.168.3.18: bytes=32 time<1ms TTL=64

(b) When abnormal communication

C:\>Ping 192.168.3.18

Request timed out.

(2) When using the [PING Test] of GT Designer3

Select [Communication] → [Communication configuration] → [Ethernet] and → [Connection Test].



1. Specify the [GOT IP Address] of the [PING Test] and click the [PING Test] button.
2. The [Test Result] is displayed after the [PING Test] is finished.

(3) When abnormal communication

At abnormal communication, check the followings and execute the Ping command again.

- Mounting condition of Ethernet communication unit
- Cable connecting condition
- Confirmation of [Communication Settings]
- IP address of GOT specified by Ping command

■ Confirming the communication state on the GOT

The Ping test can be confirmed by the Utility screen of the GOT.
For the operation method of GOT Utility, refer to the following.

☞ GOT2000 Series User's Manual (Utility)



1.6.3 Confirming the communication state to each station (Station monitoring function)

The station monitoring function detects the faults (communication timeout) of the stations monitored by the GOT. When detecting the abnormal state, it allocates the data for the faulty station to the GOT special register (GS).

(1) No. of faulty stations

(a) Ethernet connection (Except for Ethernet multiple connection)

Total No. of the faulty CPU is stored.

Device	b15 to b8	b7 to b0
GS230	(00H fixed)	No. of faulty stations

(b) Ethernet multiple connection

Total No. of the faulty connected equipment is stored.

Channel	Device	b15 to b8	b7 to b0
Ch1	GS280	(00H fixed)	No. of faulty stations
Ch2	GS300	(00H fixed)	No. of faulty stations
Ch3	GS320	(00H fixed)	No. of faulty stations
Ch4	GS340	(00H fixed)	No. of faulty stations

POINT

When monitoring GS230 on Numerical Display

When monitoring GS230 on Numerical Display, check [mask processing] with data operation tab as the following. For the data operation, refer to the following manual.

GT Designer3 (GOT2000) Help

Numerical Display (Data Operation tab)



(2) Faulty station information

The bit corresponding to the faulty station is set. (0: Normal, 1: Abnormal)
The bit is reset after the fault is recovered.

(a) Ethernet connection (Except for Ethernet multiple connection)



Device	Station number															
	b15	b14	b13	b12	b11	b10	b9	b8	b7	b6	b5	b4	b3	b2	b1	b0
GS231	16	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1
GS232	32	31	30	29	28	27	26	25	24	23	22	21	20	19	18	17
GS233	48	47	46	45	44	43	42	41	40	39	38	37	36	35	34	33
GS234	64	63	62	61	60	59	58	57	56	55	54	53	52	51	50	49
GS235	80	79	78	77	76	75	74	73	72	71	70	69	68	67	66	65
GS236	96	95	94	93	92	91	90	89	88	87	86	85	84	83	82	81
GS237	112	111	110	109	108	107	106	105	104	103	102	101	100	99	98	97
GS238	128	127	126	125	124	123	122	121	120	119	118	117	116	115	114	113

(b) For the Ethernet multiple connection or the temperature controller connection

The station number to which each device corresponds changes according to the connection/non connection with Ethernet.
With Ethernet connection: 1 to 128
With other than Ethernet connection: 0 to 127
Example) With Ethernet connection, when PC No. 100 CPU connecting to Ch3 is faulty, GS327.b3 is set.
The following table shows the case with Ethernet connection.

Device				Station number															
Ch1	Ch2	Ch3	Ch4	b15	b14	b13	b12	b11	b10	b9	b8	b7	b6	b5	b4	b3	b2	b1	b0
GS281	GS301	GS321	GS341	16	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1
GS282	GS302	GS322	GS342	32	31	30	29	28	27	26	25	24	23	22	21	20	19	18	17
GS283	GS303	GS323	GS343	48	47	46	45	44	43	42	41	40	39	38	37	36	35	34	33
GS284	GS304	GS324	GS344	64	63	62	61	60	59	58	57	56	55	54	53	52	51	50	49
GS285	GS305	GS325	GS345	80	79	78	77	76	75	74	73	72	71	70	69	68	67	66	65
GS286	GS306	GS326	GS346	96	95	94	93	92	91	90	89	88	87	86	85	84	83	82	81
GS287	GS307	GS327	GS347	112	111	110	109	108	107	106	105	104	103	102	101	100	99	98	97
GS288	GS308	GS328	GS348	128	127	126	125	124	123	122	121	120	119	118	117	116	115	114	113

For details on the GS Device, refer to the following manual.

☞ GT Designer3 Screen Design Manual (Fundamentals) Appendix.2.3 GOT special register (GS)

(3) Network No., station No. notification

The network No. and station No. of the GOT in Ethernet connection are stored at GOT startup.
If connected by other than Ethernet, 0 is stored.

Device				Description
CH1	CH2	CH3	CH4	
GS376	GS378	GS380	GS382	Network No. (1 to 239)
GS377	GS379	GS381	GS383	Station No. (1 to 64)

1.6.4 Check on the PLC

■ Read IC tag (For RFID connection)

Read IC tag with a RFID reader/writer and check that the read data are written into the PLC CPU.
Detailed settings including sequence programs, device settings and other settings required for monitoring, refer to the following manual.

☞ GT Designer3 (GOT2000) Help

MICROCOMPUTER CONNECTION

2. MICROCOMPUTER CONNECTION (SERIAL) . . . . . 2 - 1
3. MICROCOMPUTER CONNECTION (ETHERNET). . . . . 3 - 1


MEMO

2

MICROCOMPUTER CONNECTION (SERIAL)

2.1 Microcomputer Connection (Serial) . . . . . 2 - 2
2.2 System Configuration . . . . . 2 - 4
2.3 Connection Diagram . . . . . 2 - 5
2.4 Device Data Area . . . . . 2 - 6
2.5 Message Formats . . . . . 2 - 19
2.6 GOT Side Settings . . . . . 2 - 73
2.7 System Configuration Examples . . . . . 2 - 75
2.8 Device Range that Can Be Set . . . . . 2 - 78
2.9 Precautions . . . . . 2 - 79

2. MICROCOMPUTER CONNECTION (SERIAL)

2.1 Microcomputer Connection (Serial)

The "microcomputer connection (Serial)" is a function by which data can be written or read from a PC, microcomputer board, PLC, etc. (hereinafter referred to as "host") to virtual devices of the GOT.

Interrupt output is also available from the GOT to the host.



■ Flow of data processing

(1) When reading or writing data



1. The host sends a request message (the read/write command) to the GOT.
2. The GOT performs a read/write processing to its virtual devices according to the request from the host.
3. Upon completion of the processing, the GOT sends a response message (processing result) to the host.
4. Creating the following objects on the screen allows you to use the data read/written to the virtual devices:
   - Numerical Display that displays data written by the write command
   - Numerical Input that is used to input data to be upload to the host

POINT

Virtual devices inside the GOT

The devices inside the GOT are used in the microcomputer connection.
(PLC devices are not used)

2.4 Device Data Area

(2) When outputting interrupts



1. Data are written to the virtual devices for interrupt output from the touch switches on the GOT.

2. The GOT sends the written data (interrupt output) to the host.

*1 2.5 Message Formats

*2 2.4 Device Data Area

2.2 System Configuration

2.2.1 For the microcomputer connection (serial)

■ When connecting one GOT





Host		Connection cable	GOT		Number of connectable equipment
Communication Type	Max. distance	Connection diagram number	Option device	Model	
RS-232	Differs according to host side specifications	User preparing RS-232 connection diagram 1)	- (Built into GOT)	GT27 GT23 GS	1 GOT for 1 host
			GT15-RS2-9P	GT27 GT23 GS	
RS-422	Differs according to host side specifications	User preparing RS-422 connection diagram 1)	- (Built into GOT)	GT27 GT23 GS	
			GT15-RS4-9S	GT27 GT23 GS	

2.3 Connection Diagram

The following diagram shows the connection between the GOT and the microcomputer.

2.3.1 RS-232 cable

■ Connection diagram

(1) RS-232 connection diagram 1)

Example of the case where the DTR/DSR signal is not used



Example of the case where the DTR/DSR signal is used



■ Precautions when preparing a cable

(2) Cable length

The length of the RS-232 cable must be 15m or less.

(3) GOT side connector

For the GOT side connector, refer to the following.

☞ 1.4.1 GOT connector specifications

2.3.2 RS-422 cable

■ Connection diagram

(1) RS-422 connection diagram 1)



POINT

The polarity A and B in signal names may be reversed depending on the microcomputer to be used.
Prepare a cable according to the microcomputer to be used.

■ Precautions when preparing a cable

(2) Cable length

The distance between the GOT and the PLC of connection diagram 1), 2) and 3) must be 1200 m or less.
The length of the RS-422 connection diagram 4) or RS-422 connection diagram 5) must be 30m or less.

(3) GOT side connector

For the GOT side connector, refer to the following.

☞ 1.4.1 GOT connector specifications

■ Connecting terminating resistors

(1) GOT side

Set the terminating resistor setting switch of the GOT main unit to "Disable".
For the procedure to set the terminating resistor, refer to the following.

☞ 1.4.3 Terminating resistors of GOT

2.4 Device Data Area

The following shows a list of virtual devices inside the GOT available in the microcomputer connection (serial), and the address specification values for each data format.

The address specification of the virtual devices differs depending on the data format.*1

Model	Virtual device*2			Address specification value					Refer to
	Name	Device range (decimal)	Device type	Format 1, 2	Format 3 to 6	Format 7 to 10	Format 11 to 13	Format 14, 15	
	D	0 to 4095	Word	0 to 4095	D0 to 4095	D0 to 4095	0000 to 0FFFH	8000 to 9FFFH	2.4.1
	R	0 to 4095	Word	4096 to 8191	R0 to 4095	R0 to 4095	1000 to 1FFFH	0000 to 1FFFH	2.4.2
	L	0 to 2047	Bit	8192 to 8319	L0 to 2047	L0 to 2047	2000 to 207FH	A000 to A0FFH	2.4.3
	M	0 to 2047	Bit	8320 to 8447	M0 to 2047	M0 to 2047	2080 to 20FFH	2000 to 20FFH	2.4.4
	SD	0 to 15	Word	8448 to 8463	D9000 to 9015	SD0 to 15	2100 to 210FH	2100 to 211FH (3000 to 300DH)*3	2.4.5
	SM	0 to 63	Bit	8464 to 8467	M9000 to 9063	SM0 to 63	2110 to 2113H	2200 to 2207H	2.4.6

*1 For the address specification method for each data format, refer to the following.

2.5 Message Formats

- Formats 1, 2 : GOT-A900 Series microcomputer connection
- Formats 3 to 6 : A compatible 1C frame
- Formats 7 to 10 : QnA compatible 3C/4C frame
- Formats 11 to 13 : Digital Electronics Corporation's memory link method
- Formats 14, 15 : GOT-F900 Series microcomputer connection

*2 When reusing GOT900 Series project data

- GOT-A900 Series virtual devices (D0 to 2047)
  Can be used as they are without changing the assignments.
- GOT-F900 Series virtual devices
  Since some of the assigned virtual device values differ as indicated below, change the assignment using device batch edit of GT Designer3.
  Refer to the following manual for device batch edit of GT Designer3.

GT Designer3 (GOT2000) Help

GOT1000 Series virtual devices	GOT-F900 Series virtual devices
D0 to 2047	—
D2048 to 4095	—
R0 to 4095	D0 to 4095
L0 to 2047	—
M0 to 2047	M0 to 2047
SD0 to 15	D8000 to 8015 GD0 to 6
SM0 to 63	M8000 to 8063

*3 Access to SD3 to 9 can also be made by the specification of the addresses (3000 to 300DH) of GD0 to 6 on the GOT-F900 Series.

POINT

Values of virtual devices inside the GOT

When the GOT is turned OFF or reset, values are cleared to their defaults (bit devices: OFF, word devices: 0).

Values are held in the memory when project data are written to the GOT.

2.4.1 D devices

The D devices are word devices into which GOT communication errors, clock data or other information are stored. The user can also store data using the user area.

■ List of D devices

The following lists the D devices (virtual devices inside the GOT).

<table>
<tr><th>Address</th><th>Description</th><th>Set side</th></tr>
<tr><td>D0 to 2</td><td>Unused</td><td>—</td></tr>
<tr><td>D3</td><td>Communication error status
Stores the communication error details of GOT.
 

• b4 to 6 turn ON when an SIO error occurs, and turn OFF when an request message from the host is received successfully after the error occurrence.
• b7 turns ON about 3 seconds after the host side DTR becomes OFF, and turns OFF when transmission is performed successfully to the host after the error occurrence.</td><td rowspan="4">System</td></tr>
<tr><td>D4</td><td>Clock data (year)
 
</td></tr>
<tr><td>D5</td><td>Clock data (month)
 
</td></tr>
<tr><td>D6</td><td>Clock data (day)
 
</td></tr>
</table>

(Continued to next page)

(From previous page)

Address	Description	Set side
D7	Clock data (hour) 	System
D8	Clock data (minute) 	
D9	Clock data (second) 	
D10	Clock data (day of week)*1 	
D11, D12	Unused	—

(Continued to next page)

*1 If a wrong day of the week is set by the clock data setting commands, the clock data will differ from the time displayed on the utility.

Example: When June 1, 2004 (Thursday) is set by the clock data setting command (the actual day of the week is Tuesday), "04" is stored to D10 although Tuesday (TUE) will be displayed on the utility time display.

Address	Description	Set side
D13	Interrupt output When data are written to D13 and D14 from a GOT touch switch, for example, the data of D13 and D14 are transmitted (interrupt output) to the host side.*1*2 The data amount (number of bytes) to be interrupt-output is set at "Interrupt Data Byte" in "Communication Detail Settings".(☞ 2.6.1 Setting communication interface (Communication settings)) • Output value when 1 is set to "Interrupt Data Byte" in "Communication Detail Settings" 	User
D14	• Output value when 2 is set to "Interrupt Data Byte" in "Communication Detail Settings"  • Output value when 4 is set to "Interrupt Data Byte" in "Communication Detail Settings "(1) When setting the LH order to [32bit Storage] for the communication detail settings  (2) When setting the HL order to [32bit Storage] for the communication detail settings 	
D15 to 19	Unused	—
D20 to 2031	User area	User
D2032 to 2034	Unused	—
D2035	1-second binary counter The counter is incremented at 1-second intervals after the GOT is turned ON. (The time elapsed after GOT is turned ON is stored in 1-second units.) Data are stored in binary format.	System
D2036 to 4095	User area	User

*1 After writing data, the interrupt data is output within a period of 1 to 10ms.
*2 When data are written to D13 and D14 from the host side, interrupt output is not performed.

POINT

(1) The side where virtual devices are set
System : Set on the system side.
User : Set on the user side (by sending request messages from host or using the touch switches, etc. on the GOT).

(2) Interrupt output (D13, D14)
- To disable the interrupt output, turn ON SM52 (interrupt code output disable flag). (☞ 2.4.6 SM devices)
- To enable the interrupt output, set 8 bits to the data length at "Communication Detail Settings". (☞ 2.6.1 Setting communication interface (Communication settings))
- When "7 bits" is set, the MSB (8th bit) is ignored. (Example: FFH→7FH)

■ Differences in address specifications by data format

The address specification of devices varies depending on the data format.*1
The following shows the address specification values for each data format.

Model	Address	Address specification value				
		Format 1, 2	Format 3 to 6	Format 7 to 10	Format 11 to 13	Format 14, 15
	D0	0	D0	D0	0000H	8000H / 8001H — 8000H (Upper 8 bits), 8001H (Lower 8 bits)
	D1	1	D1	D1	0001H	8002H / 8003H — 8002H (Upper 8 bits), 8003H (Lower 8 bits)
	:	:	:	:	:	:
	D4095	4095	D4095	D4095	0FFFH	9FFEH / 9FFFH — 9FFEH (Upper 8 bits), 9FFFH (Lower 8 bits)

*1 For the address specification method for each data format, refer to the following.

☞ 2.5 Message Formats

- Formats 1, 2 : GOT-A900 Series microcomputer connection
- Formats 3 to 6 : A compatible 1C frame
- Formats 7 to 10 : QnA compatible 3C/4C frame
- Formats 11 to 13 : Digital Electronics Corporation's memory link method
- Formats 14, 15 : GOT-F900 Series microcomputer connection

2.4.2 R devices

The R devices are word devices into which user data are stored.
All of these devices can be used as a user area.

■ List of R devices and differences in address specification by data format

The following shows the R devices (virtual devices inside the GOT).

The address specification values different depending on the data format are also given below.*1

Model	Address	Address specification value				
		Format 1, 2	Format 3 to 6	Format 7 to 10	Format 11 to 13	Format 14, 15
	R0	4096	R0	R0	1000H	0000H: 0000H (Upper 8 bits) / 0001H (Lower 8 bits)
	R1	4097	R1	R1	1001H	0002H: 0002H (Upper 8 bits) / 0003H (Lower 8 bits)
	:	:	:	:	:	:
	R4095	8191	R4095	R4095	1FFFH	1FFEH: 1FFEH (Upper 8 bits) / 1FFFH (Lower 8 bits)

*1 For the address specification method for each data format, refer to the following.

2.5 Message Formats

- Formats 1, 2 : GOT-A900 Series microcomputer connection
- Formats 3 to 6 : A compatible 1C frame
- Formats 7 to 10 : QnA compatible 3C/4C frame
- Formats 11 to 13 : Digital Electronics Corporation's memory link method
- Formats 14, 15 : GOT-F900 Series microcomputer connection

2.4.3 L devices

The L devices are bit devices into which user data are stored.
All of these devices can be used as a user area.

■ List of L devices and differences in address specification by data format

The following shows the L devices (virtual devices inside the GOT).

The address specification values different depending on the data format are also given below.*1

Model	Address								Address specification value				
	b7	b6	b5	b4	b3	b2	b1	b0	Format 1, 2	Format 3 to 6	Format 7 to 10	Format 11 to 13	Format 14, 15
	L7	L6	L5	L4	L3	L2	L1	L0	8192	Same as address column on left *2		2000H	A000H
	L15	L14	L13	L12	L11	L10	L9	L8					A001H
	L23	L22	L21	L20	L19	L18	L17	L16	8193			2001H	A002H
	L31	L30	L29	L28	L27	L26	L25	L24					A003H
	:								:			:	:
	L2039	L2038	L2037	L2036	L2035	L2034	L2033	L2032	8319			207FH	A0FEH
	L2047	L2046	L2045	L2044	L2043	L2042	L2041	L2040					A0FFH

*1 For the address specification method for each data format, refer to the following.

2.5 Message Formats

- Formats 1, 2 : GOT-A900 Series microcomputer connection
- Formats 3 to 6 : A compatible 1C frame
- Formats 7 to 10 : QnA compatible 3C/4C frame
- Formats 11 to 13 : Digital Electronics Corporation's memory link method
- Formats 14, 15 : GOT-F900 Series microcomputer connection

*2 For reading or writing data in word units, specify the addresses in 16-point units. (Example: L0, L16, L32, etc.)

2.4.4 M devices

The M devices are bit devices into which user data are stored.
All of these devices can be used as a user area.

■ List of M devices and differences in address specification by data format

The following shows the M devices (virtual devices inside the GOT).

The address specification values different depending on the data format are also given below.*1

Model	Address								Address specification value				
	b7	b6	b5	b4	b3	b2	b1	b0	Format 1, 2	Format 3 to 6	Format 7 to 10	Format 11 to 13	Format 14, 15
	M7	M6	M5	M4	M3	M2	M1	M0	8320	Same as address column on left *2		2080H	2000H
	M15	M14	M13	M12	M11	M10	M9	M8					2H001H
	M23	M22	M21	M20	M19	M18	M17	M16	8321			2081H	2002H
	M31	M30	M29	M28	M27	M26	M25	M24					2003H
	:								:			:	:
	M2039	M2038	M2037	M2036	M2035	M2034	M2033	M2032	8447			20FFH	20FEH
	M2047	M2046	M2045	M2044	M2043	M2042	M2041	M2040					20FFH

*1 For the address specification method for each data format, refer to the following.

2.5 Message Formats

- Formats 1, 2 : GOT-A900 Series microcomputer connection
- Formats 3 to 6 : A compatible 1C frame
- Formats 7 to 10 : QnA compatible 3C/4C frame
- Formats 11 to 13 : Digital Electronics Corporation's memory link method
- Formats 14, 15 : GOT-F900 Series microcomputer connection

*2 For reading or writing data in word units, specify the addresses in 16-point units.(Example: M0, M16, M32, and others)

2.4.5 SD devices

The SD devices are word devices into which GOT communication errors (error codes), clock data and other information are stored.

■ List of SD devices

The following lists the SD devices (virtual devices inside the GOT).

Address	Description	Set side
SD0 SD1	100ms counter (32bits) The counter is incremented at 100ms intervals after GOT is turned ON. (The time elapsed after GOT is turned ON is stored in 100ms units.) (1) When setting the LH order to [32bit Storage] for the communication detail settings The lower and upper bits are stored in SD0 and SD1 respectively.  (2) When setting the HL order to [32bit Storage] for the communication detail settings The upper and lower bits are stored in SD0 and SD1 respectively. 	System
SD2*1	Communication error status An error data (error code) occurred during communication is stored. •Host Address (Communication error that occurred on the request destination GOT) 0: No error 1: Parity error 2: Framing error 3: Overrun error 4: Communication message error 5: Command error 6: Clock data setting error •Other station (Communication error that occurred on another GOT when multiple GOTs are connected) 101: Parity error 102: Framing error 103: Overrun error 104: Communication message error 105: Timeout error (No station of the specified address exists.) 106: Multiple units not connectable 107: Clock data setting error	
SD3	Clock data (second) Second data of 00 to 59 is stored.	
SD4	Clock data (minute) Minute data of 00 to 59 is stored.	
SD5	Clock data (hour) Hour data of 00 to 23 is stored.	
SD6	Clock data (day) Day data of 00 to 31 is stored.	
SD7	Clock data (month) Month data of 01 to 12 is stored.	

(Continued to next page)

*1 For details and corrective actions for the errors (error codes) that are stored into SD2, refer to the following:

■ Details and actions for errors (error codes) stored into SD2

Address	Description	Set side
SD8	Clock data (year) 4-digit year data is stored.	System
SD9	Clock data (day of week)*1 Day-of-the-week data is stored. 0: Sunday 1: Monday 2: Tuesday 3: Wednesday 4: Thursday 5: Friday 6: Saturday	
SD10 to 15	Unused	—

*1 If a wrong day of the week is set by the clock data setting commands, the clock data will differ from the time displayed on the utility.
Example: When June 1, 2004 (Thursday) is set by the clock data setting command (the actual day of the week is Tuesday), "4" is stored to SD9 although Tuesday (TUE) will be displayed on the utility time display.

POINT

The side where virtual devices are set

System : Set on the system side.
User : Set on the user side (by sending request messages from host or using the touch switches, etc. on the GOT).

■ Details and actions for errors (error codes) stored into SD2

Error code	Description	Action
0	No error	—
1, 101	Parity error The parity bit does not match.	• Check the communication cable and communication module attachment. • Check the settings of "Communication Detail Settings". • Match the GOT and host transmission settings.
2, 102	Framing error The data bit and/or stop bit are not correct.	
3, 103	Overrun error The next data was transmitted from the host before GOT completes the processing of the data received.	• Check the settings of "Communication Detail Settings". • Decrease the transmission speed.
4, 104	Communication message error EXT/CR could not be found before the upper limit of the receive buffer was exceeded.	• Check the communication cable and communication module attachment. • Check the settings of "Communication Detail Settings". • Review the contents of the message to transmit.
5	Command error An unsupported command was used.	• Review the contents of the message to transmit. • Check the commands in the message. (☞ 2.5.2 List of commands)
105	Timeout error There is no response from the GOT, or the station of the specified address does not exist.	• Check the communication cable and communication module attachment. • Check the settings of "Communication Detail Settings". • Review the contents of the message to transmit.
106	Multiple units not connectable The RS-232 port is occupied.	• Check the communication cable and communication module attachment. • Check the settings of "Communication Detail Settings". • Check to see if the RS-232 port is occupied.
6, 107	Clock data setting error The setting value of the clock data has error.	• Review the contents of the message to transmit. • Check whether the non-existent data is set (e.g. setting "07" at the day of the week) as clock data.

■ Differences in address specifications by data format

The address specification of devices varies depending on the data format.[*1]
The following shows the address specification values for each data format.

Address	Address specification value				
	Formats 1, 2	Formats 3 to 6	Formats 7 to 10	Formats 11 to 13	Formats 14, 15[*2]
SD0	8448	D9000	SD0	2100H	2100H: 2100H (Upper 8 bits) / 2101H (Lower 8 bits) 2101H
SD1	8449	D9001	SD1	2101H	2102H: 2102H (Upper 8 bits) / 2103H (Lower 8 bits) 2103H
SD2	8450	D9002	SD2	2102H	2104H: 2104H (Upper 8 bits) / 2105H (Lower 8 bits) 2105H
SD3	8451	D9003	SD3	2103H	2106H (3000H): 2106H(3000H) (Upper 8 bits) / 2107H(3001H) (Lower 8 bits) 2107H (3001H)
SD4	8452	D9004	SD4	2104H	2108H (3002H): 2108H(3002H) (Upper 8 bits) / 2109H(3003H) (Lower 8 bits) 2109H (3003H)
SD5	8453	D9005	SD5	2105H	210AH (3004H): 210AH(3004H) (Upper 8 bits) / 210BH(3005H) (Lower 8 bits) 210BH (3005H)
SD6	8454	D9006	SD6	2106H	210CH (3006H): 210CH(3006H) (Upper 8 bits) / 210DH(3007H) (Lower 8 bits) 210DH (3007H)
SD7	8455	D9007	SD7	2107H	210EH (3008H): 210EH(3008H) (Upper 8 bits) / 210FH(3009H) (Lower 8 bits) 210FH (3009H)
SD8	8456	D9008	SD8	2108H	2110H (300AH): 2110H(300AH) (Upper 8 bits) / 2111H(300BH) (Lower 8 bits) 2111H (300BH)
SD9	8457	D9009	SD9	2109H	2112H (300CH): 2112H(300CH) (Upper 8 bits) / 2113H(300DH) (Lower 8 bits) 2113H (300DH)

*1 For the address specification method for each data format, refer to the following.

2.5 Message Formats

- Formats 1, 2 : GOT-A900 Series microcomputer connection
- Formats 3 to 6 : A compatible 1C frame
- Formats 7 to 10 : QnA compatible 3C/4C frame
- Formats 11 to 13 : Digital Electronics Corporation's memory link method
- Formats 14, 15 : GOT-F900 Series microcomputer connection

*2 SD3 to 9 correspond to GD0 to 6 on the GOT-F900 Series.
Access to SD3 to 9 can be also made by the specification of the addresses (3000 to 300DH) of GD0 to 6 on the GOT-F900 Series.

2.4.6 SM devices

The SM devices are bit devices into which interrupt outputs and clock data that turn ON/OFF at 1-second cycles.

■ List of SM devices

The following shows the SM devices (virtual devices inside the GOT).

<table>
<tr><th>Address</th><th>Description</th><th>Set side</th></tr>
<tr><td>SM0 to 49</td><td>Interrupt output
When the ON/OFF state of SM0 to 49 is changed by a touch switch on the GOT, for example, the interrupt codes shown below are transmitted (interrupt output) to the host side.*1*2
The data amount (number of bytes) to be interrupt-output is set at "Interrupt Data Byte" in "Communication Detail Settings". (☞ 2.6.1 Setting communication interface (Communication settings))
<table>
<tr><th>Address</th><th>Event type</th><th>Interrupt code</th></tr>
<tr><td rowspan="2">SM0</td><td>Changed from OFF to ON</td><td>50H</td></tr>
<tr><td>Changed from ON to OFF</td><td>51H</td></tr>
<tr><td rowspan="2">SM1</td><td>Changed from OFF to ON</td><td>52H</td></tr>
<tr><td>Changed from ON to OFF</td><td>53H</td></tr>
<tr><td rowspan="2">SM2</td><td>Changed from OFF to ON</td><td>54H</td></tr>
<tr><td>Changed from ON to OFF</td><td>55H</td></tr>
<tr><td>≀</td><td>≀</td><td>≀</td></tr>
<tr><td rowspan="2">SM48</td><td>Changed from OFF to ON</td><td>B0H</td></tr>
<tr><td>Changed from ON to OFF</td><td>B1H</td></tr>
<tr><td rowspan="2">SM49</td><td>Changed from OFF to ON</td><td>B2H</td></tr>
<tr><td>Changed from ON to OFF</td><td>B3H</td></tr>
</table></td><td>User</td></tr>
<tr><td>SM50</td><td>1-second cycle clock
Turns ON/OFF at a 1-second cycle.
</td><td rowspan="2">System</td></tr>
<tr><td>SM51</td><td>2-second cycle clock
Turns ON/OFF at a 2-second cycle.
</td></tr>
<tr><td>SM52</td><td>Interrupt code output disable flag
Enables or disables the output of the interrupt code.
OFF : Interrupt code output enabled ON : Interrupt code output disabled
When set to disable the interrupt code output, no interrupt data are output to the host.
(Relevant devices: D13, D14, SM0 to 49)</td><td>User</td></tr>
<tr><td>SM53 to 63</td><td>Unused</td><td>—</td></tr>
</table>

*1 After the ON/OFF state is changed, the interrupt data is output within a period of 1 to 10 ms.

*2 When the ON/OFF state of SM0 to 49 is changed from the host side, interrupt output is not performed.

POINT

(1) The side where virtual devices are set

System : Set on the system side.

User : Set on the user side (by sending request messages from host or using the touch switches, etc. on the GOT).

(2) Interrupt outputs (SM0 to 49)

- To disable the interrupt output, turn ON SM52 (interrupt code output disable flag).(☞ 2.4.6 SM devices)
- To enable the interrupt output, set 8 bits to the data length at "Communication Detail Settings". (☞ 2.6.1 Setting communication interface (Communication settings))
- When "7 bits" is set, the MSB (8th bit) is ignored. (Example: FFH→7FH)

■ Differences in address specifications by data format

The address specification of devices varies depending on the data format.*1
The following shows the address specification values for each data format.

Model	Address								Address specification value				
	b7	b6	b5	b4	b3	b2	b1	b0	Format 1, 2	Format 3 to 6	Format 7 to 10	Format 11 to 13	Format 14, 15
	SM7	SM6	SM5	SM4	SM3	SM2	SM1	SM0	8464	*2*4	*3*4	2110H	2200H
	SM15	SM14	SM13	SM12	SM11	SM10	SM9	SM8					2201H
	SM23	SM22	SM21	SM20	SM19	SM18	SM17	SM16	8465			2111H	2202H
	SM31	SM30	SM29	SM28	SM27	SM26	SM25	SM24					2203H
	SM39	SM38	SM37	SM36	SM35	SM34	SM33	SM32	8466			2112H	2204H
	SM47	SM46	SM45	SM44	SM43	SM42	SM41	SM40					2205H
	Unused			SM52	SM51	SM50	SM49	SM48	8467			2113H	2206H
	Unused								—				—

*1 For the address specification method for each data format, refer to the following.

2.5 Message Formats

- Formats 1, 2 : GOT-A900 Series microcomputer connection
- Formats 3 to 6 : A compatible 1C frame
- Formats 7 to 10 : QnA compatible 3C/4C frame
- Formats 11 to 13 : Digital Electronics Corporation's memory link method
- Formats 14, 15 : GOT-F900 Series microcomputer connection

*2 In formats 3 to 6, values are specified within a range of M9000 to 9052.
*3 In formats 7 to 10, values are specified within a range of SM0 to 52.
*4 For reading or writing data in word units, specify the addresses in 16-point units. (Example: SM0, SM16, SM32, etc.)

2.5 Message Formats

This section describes the format of messages that can be used in the microcomputer connection (serial).

2.5.1 Data format type and application

■ Data format type and application

Communication is possible using any of the data formats shown below.

(1) Formats 1, 2 (GOT-A900 Series microcomputer connection)
This is the same message format as when a microcomputer connection is established with the GOT-A900 series.

Type	Name	Description	Refer to
Format 1	GOT-A900 Series microcomputer connection (format 1)	This format is used when the GOT is connected to the host in a 1:1 connection.	2.5.3
Format 2	GOT-A900 Series microcomputer connection (format 2)	This is the appended format with error code at the error response of the GOT-A900 Series microcomputer connection (format 1).	

(2) Formats 3 to 6 (A compatible 1C frame)
This is the same message format as when communication is performed using the dedicated protocol of the A series computer link module.

Type	Name	Description	Refer to
Format 3	A compatible 1C frame (format 1)	This is the basic format of the dedicated protocols.	2.5.4
Format 4	A compatible 1C frame (format 2)	This is the appended format of the A compatible 1C frame (format 1) with a block No.	
Format 5	A compatible 1C frame (format 3)	This is the enclosed format of the A compatible 1C frame (format 1) with STX and ETX.	
Format 6	A compatible 1C frame (format 4)	This is the appended format of the A compatible 1C frame (format 1) with CR and LF.	

(3) Formats 7 to 10 (QnA compatible 3C/4C frame)
This is the same message format as when a communication is performed using the MC protocol of Q/QnA Series serial communication module.

Type	Name	Description	Refer to
Format 7	QnA compatible 3C/4C frame (format 1)	This is the basic format of the MC protocols.	2.5.5
Format 8	QnA compatible 3C/4C frame (format 2)	This is the appended format of the QnA compatible 3C/4C frame (format 1) with block No.	
Format 9	QnA compatible 3C/4C frame (format 3)	This is the enclosed format of the QnA compatible 3C/4C frame (format 1) with STX and ETX.	
Format 10	QnA compatible 3C/4C frame (format 4)	This is the appended format of the QnA compatible 3C/4C frame (format 1) with CR and LF.	

(4) Formats 11 to 13 (Digital Electronics Corporation's memory link method)
This is the same format as the protocol of the Digital Electronics Corporation's memory link method.

Type	Name	Description	Refer to
Format 11	Digital Electronics Corporation's memory link method (compatible mode)	This is the basic format of the Digital Electronics Corporation's memory link method.	☞ 2.5.6
Format 12	Digital Electronics Corporation's memory link method (extended mode, ASCII code 1:1)	This is the appended format of the Digital Electronics Corporation's memory link method (compatible mode) with sum check, CR and LF.	
Format 13	Digital Electronics Corporation's memory link method (extended mode, ASCII code 1:n)	This is the appended format of the Digital Electronics Corporation's memory link method (extended mode, ASCII code 1:1) with a station No.	

(5) Formats 14, 15 (GOT-F900 Series microcomputer connection)
This is the same message format as when a microcomputer connection is established with the GOT-F900 Series.

Type	Name	Description	Refer to
Format 14	GOT-F900 Series microcomputer connection (format 1)	Use this format when establishing a 1:1 or m:n connection between the GOT and the host. The end code is CR.	☞ 2.5.7
Format 15	GOT-F900 Series microcomputer connection (format 2)	Use this format when establishing a 1:1 or m:n connection between the GOT and the host. The end code is ETX or sum check.	

■ How to set data format

Set the data format at [Detail setting] in GT Designer3.
For details of the data format setting method, refer to the following.

☞ 2.6.1 Setting communication interface (Communication settings)

2.5.2 List of commands

The following shows the list of commands available in each data format.

■ List of commands for formats 1, 2 (GOT-A900 Series microcomputer connection)

Command		Command name	Description	Max. number of points processed
Symbol	ASCII code			
RD	52H 44H	Batch read in word units	Reads bit devices in 16-point units.	64 words (1024 points)
			Reads word devices in 1-point units.	64 points
WD	57H 44H	Batch write in word units	Writes to bit devices in 16-point units.	64 words (1024 points)
			Writes to word devices in 1-point units.	64 points
RR	52H 52H	Random read in word units*1	Reads multiple different bit devices in 16-point units.	64 words (1024 points)
			Reads multiple different word devices in 1-point units.	64 points
RW	52H 57H	Random write in word units*1	Writes to multiple different word devices in 16-point units.	64 words (1024 points)
			Writes to multiple different word devices in 1-point units.	64 points
TR	54H 52H	Read clock data	Reads the clock data of the GOT.	—
TS	54H 53H	Set clock data	Sets the clock data of the GOT.	—

*1 Mixed specification of bit devices and word devices is also possible.

■ List of commands for formats 3 to 6 (A compatible 1C frame)

Command		Command name	Description	Max. number of points processed
Symbol	ASCII code			
BR JR	42H 52H 4AH 52H	Batch read in bit units	Reads bit devices in 1-point units.	64 points
WR QR	57H 52H 51H 52H	Batch read in word units	Reads bit devices in 16-point units.*3	64 words (1024 points)
			Reads word devices in 1-point units.	64 points
BW JW	42H 57H 4AH 57H	Batch write in bit units	Writes to bit devices in 1-point units.	64 points
WW QW	57H 57H 51H 57H	Batch write in word units	Writes to bit devices in 16-point units.*3	64 words (1024 points)
			Writes to word devices in 1-point units.	64 points
BT JT	42H 54H 4AH 54H	Test in bit units (random write)	Writes to multiple different bit devices in 1-point units.	64 points
WT QT	57H 54H 51H 54H	Test in word units (random write)	Writes to multiple different bit devices in 16-point units.*3	64 words (1024 points)
			Writes to multiple different word devices in 1-point units.	64 points
TR*2	54H 52H	Read clock data	Reads the clock data of the GOT.	—
TS*2	54H 53H	Set clock data	Sets the clock data of the GOT.	—

*2 This is a dedicated command of GOT for the microcomputer connection.

*3 Specifies the address of bit devices in 16-point units. (Example: M0, M16, M32, and others)

■ Command lists for formats 7 to 10 (QnA compatible 3C/4C frame)

Command	Sub-command	Command name	Description	Max. number of points processed
0401	0001	Batch read in bit units	Reads bit devices in 1-point units.	64 points
0401	0000	Batch read in word units	Reads bit devices in 16-point units.*3	64 words (1024 points)
			Reads word devices in 1-point units.	64 points
1401	0001	Batch write in bit units	Writes to bit devices in 1-point units.	64 points
1401	0000	Batch write in word units	Writes to bit devices in 16-point units.*3	64 words (1024 points)
			Writes to word devices in 1-point units.	64 points
0403	0000	Random read in word units*1	Reads multiple different bit devices in 16-point and 32-point units.*3	64 words (1024 points)
			Reads multiple different word devices in 1-point and 2-point units.	64 points
1402	0001	Random write in bit units	Writes to multiple different bit devices in 1-point units.	64 points
1402	0000	Random write in word units*1	Writes to multiple different bit devices in 16-point and 32-point units.*3	64 words (1024 points)
			Writes to multiple different word devices in 1-point and 2-point units.	64 points
0406	0000	Multiple block batch read	Reads multiple blocks. A bit device (16 bits for 1 point) or a word device (1 word for 1 point) is regarded as one block.*3	64 points
1406	0000	Multiple block batch write	Writes multiple blocks. A bit device (16 bits for 1 point) or a word device (1 word for 1 point) is regarded as one block.*3	64 points
1901*2	0000	Read clock data	Reads the clock data of the GOT.	—
0901*2	0000	Set clock data	Sets the clock data of the GOT.	—

*1 Mixed specification of bit devices and word devices is also possible.
*2 This is a dedicated command of GOT for the microcomputer connection.
*3 Specifies the address of bit devices in 16-point units. (Example: M0, M16, M32, and others)

■ List of commands for formats 11 to 13 (Digital Electronics Corporation's memory link method)

Command		Command name	Description	Max. number of points processed
Symbol	ASCII code			
R	52H	Batch read in word units	Reads bit devices in 16-point units.	64 words (1024 points)
			Reads word devices in 1-point units.	64 points
W	57H	Batch write in word units	Writes to bit devices in 16-point units.	64 words (1024 points)
			Writes to word devices in 1-point units.	64 points
I	49H	Interrupt inquiry	Issues an interrupt inquiry.(format 13 only)	—
N*4	4DH	Read clock data	Reads the clock data of the GOT.	—
M*4	4EH	Set clock data	Sets the clock data of the GOT.	—

*4 This is a dedicated command of GOT for the microcomputer connection.

■ List of commands for formats 14, 15 (GOT-F900 series microcomputer connection)

Command		Command name	Description	Max. number of points processed
Symbol	ASCII code			
0	30H	Batch read (w/out station No.)	Reads bit devices in byte units.	255bytes (2040 points)
			Reads word devices in byte units.	255bytes (127 points)
A	41H	Batch read (w/ station No.)	Reads bit devices in byte units.	255bytes (2040 points)
			Reads word devices in byte units.	255bytes (127 points)
1	31H	Batch write (w/out station No.)	Writes to bit devices in byte units.	255bytes (2040 points)
			Writes to word devices in byte units.	255bytes (127 points)
B	42H	Batch write (w/ station No.)	Writes to bit devices in byte units.	255bytes (2040 points)
			Writes to word devices in byte units.	255bytes (127 points)
3	33H	Multi-point write in bit units (w/out station No.)	Writes bit patterns (bit ON/OFF, inversion, direct specification) in 1-point units (8 bits for 1 point) to a specified device.	70bytes (560 points)
D	44H	Multi-point write in bit units (w/ station No.)		
4	34H	Fill command (w/out station No.)	Writes the same value to a range of specified devices.	—
E	45H	Fill command (w/ station No.)		
5	35H	Set clock data (w/out station No.)	Sets the clock data of the GOT.	—
F	46H	Set clock data (w/ station No.)		
6	36H	Read clock data (w/out station No.)	Reads the clock data of the GOT.	—
G	47H	Read clock data (w/ station No.)		

2.5.3 Formats 1, 2 (GOT-A900 Series microcomputer connection)

■ Basic format of data communication

<table>
<tr><th>Item</th><th colspan="2">Message format</th></tr>
<tr><td>Request message
(host → GOT)</td><td colspan="2"> 
</td></tr>
<tr><td>Response message during normal communication
(GOT → host)</td><td colspan="2">(1) During processing of read commands
 

(2) During processing of write commands
 
</td></tr>
<tr><td>Response message during faulty communication
(GOT → host)</td><td>(format 1: GOT-A900 Series microcomputer connection (format 1))
 
</td><td>(format 2: GOT-A900 Series microcomputer connection (format 2))
 
</td></tr>
<tr><td>During interrupt output</td><td>(format 1: GOT-A900 Series microcomputer connection (format 1))
 
</td><td>(format 2: GOT-A900 Series microcomputer connection (format 2))
 
</td></tr>
</table>

*1 Set the number of interrupt data bytes at [Detail setting] in GT Designer3.
For the setting of the number of interrupt data bytes, refer to the following.

2.6.1 Setting communication interface (Communication settings)

■ Details of data items in message format

POINT

Data code during communication
Communication is performed in ASCII code. (excluding interrupt output)

(1) Control codes

Symbol	ASCII code	Description
STX	02H	Start of Text (start marker of message frame)
ETX	03H	End of Text (end marker of message frame)
EOT	04H	End of Transmission
ENQ	05H	Enquiry (start of enquiry)
NAK	15H	Negative ACK (error response)
ACK	06H	Acknowledge (write completion response)
LF	0AH	Line Feed
CL	0CH	Clear
CR	0DH	Carriage Return

(2) Command
Specifies the contents to access from the host to GOT.
The command is converted to a 2-digit ASCII code (Hex) and transmitted from the upper digit.
For details of the commands that can be used, refer to the following.

☞ 2.5.2 List of commands

(3) Address
Specifies the head No. of the device data to be read/written.
The address notated in decimal is converted to a 4-digit ASCII code (Hex) and transmitted from the upper digit.
For details of the device range that can be accessed, refer to the following.

☞ 2.4 Device Data Area

(4) Number of points
Specifies the number of device data to be read/written. (Setting range: 1 to 64)
The address notated in decimal is converted to a 2-digit ASCII code (Hex) and transmitted from the upper digit.

(5) Year, month, day, hour, minute, second and day of the week data
Specifies year, month, day, hour, minute, second, and day of the week to be read/set to the GOT clock data.
The address notated in decimal is converted to a 2-digit ASCII code (Hex) and transmitted from the upper digit.

☞ ■ Message format (5) Read clock data (TR) command

☞ ■ Message format (6) Set clock data (TS) command

(6) Data
Specifies the data to read from/write to the specified device data.(word unit)
The address notated in hexadecimal is converted to a 4-digit ASCII code (Hex) and transmitted from the upper digit.

(7) Error code
This is the response message at faulty communication appended with error contents.
Error code is transmitted in 1 byte.
For details of the error codes generated in format 2 (GOT-A900 Series microcomputer connection (format 2)), refer to the following:

☞ ■ Error code list

(8) Sum check code

The sum check code is obtained by converting the lower 1 byte (8 bits) of the result (sum), after having added the sum check target data as binary data, to 2-digit ASCII code (Hex).

STX	Command		Address				Number of points		ETX	Sum Check	
	R	D	0	1	0	0	0	2		B	C
02H	52H	44H	30H	31H	30H	30H	30H	32H	03H	42H	43H
	(H)	(L)	(H)	–	–	(L)	(H)	(L)		(H)	(L)

Sum check is performed in this range.

$52_H + 44_H + 30_H + 31_H + 30_H + 30_H + 30_H + 32_H + 03_H = 1BC_H$

■ Message Formats

(1) Batch read in word units (RD) command

(a) When reading a word device

The following shows an example of reading the two points of the virtual devices D100 and D101.
(Assuming D100=0102H, D101=0304H are stored.)



Item	Message format
Request message (host → GOT)	STX: 02H Command: R (52H) D (44H) Address: 0 (30H) 1 (31H) 0 (30H) 0 (30H) Number of points: 0 (30H) 2 (32H) ETX: 03H Sum Check: B (42H) C (43H) Sum check is performed in this range.
Response message during normal communication (GOT → host)	STX: 02H Data 1 (D100): 0 (30H) 1 (31H) 0 (30H) 2 (32H) Data 2 (D101): 0 (30H) 3 (33H) 0 (30H) 4 (34H) ETX: 03H Sum Check: 8 (38H) D (44H) Sum check is performed in this range.
Response message during faulty communication (GOT → host)	(format 1: GOT-A900 Series microcomputer connection (format 1)) NAK: 15H (format 2: GOT-A900 Series microcomputer connection (format 2)) NAK: 15H, Error code: 06H The above is a case where the sum check error (06H) has occurred.

(b) When reading a bit device

The following shows an example of reading the two points of the virtual devices M0 to M31.
(Assuming M0="1" and M31="1" are stored.



Item	Message format
Request message (host → GOT)	STX: 02H Command: R D = 52H (H) 44H (L) Address: 8 3 2 0 = 38H (H) 33H 32H 30H (L) Number of points: 0 2 = 30H (H) 32H (L) ETX: 03H Sum Check: C 8 = 43H (H) 38H (L) Sum check is performed in this range.
Response message during normal communication (GOT → host)	Sum check is performed in this range. STX: 02H Data 1 (M15 to 0): 0 0 0 1 = 30H 30H 30H 31H (H – – L) Data 2 (M31 to 16): 8 0 0 0 = 38H 30H 30H 30H (H – – L) ETX: 03H Sum Check: 8 C = 38H (H) 43H (L) 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1 1 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 M M M M M M M M M M M M M M M M M M M M M M M M M M M M M M M M 1 1 1 1 1 1 9 8 7 6 5 4 3 2 1 0 3 3 2 2 2 2 2 2 2 2 2 2 1 1 1 1 5 4 3 2 1 0 1 0 9 8 7 6 5 4 3 2 1 0 9 8 7 6
Response message during faulty communication (GOT → host)	(format 1: GOT-A900 Series microcomputer connection (format 1)) NAK: 15H (format 2: GOT-A900 Series microcomputer connection (format 2)) NAK: 15H, Error code: 06H The above is a case where the sum check error (06H) has occurred.

(2) Batch write in word units (WD) command

(a) When writing to a word device

The following shows as example of writing "0064H"and "0065H"to virtual devices D100 and D101.



Item	Message format
Request message (host → GOT)	STX: 02H Command: W 57H (H), D 44H (L) Address: 0 30H (H), 1 31H, 0 30H, 0 30H (L) Number of points: 0 30H (H), 2 32H (L) Data 1(D100): 0 30H (H), 0 30H, 6 36H, 4 34H (L) Data 2 (D101): 0 30H (H), 0 30H, 6 36H, 5 35H (L) ETX: 03H Sum Check: 5 35H (H), 6 36H (L) Sum check is performed in this range.
Response message during normal communication (GOT → host)	ACK: 06H
Response message during faulty communication (GOT → host)	(format 1: GOT-A900 Series microcomputer connection (format 1)) NAK: 15H (format 2: GOT-A900 Series microcomputer connection (format 2)) NAK: 15H, Error code: 06H The above is a case where the sum check error (06H) has occurred.

(b) When writing to a bit device

The following shows an example of writing "1"s to virtual devices M0 and M31.



Item	Message format
Request message (host → GOT)	Sum check is performed in this range. STX | Command (W 57H (H), D 44H (L)) | Address (8 3 2 0 → 38H 33H 32H 30H) | Number of points (0 2 → 30H 32H) | Data 1 (M15 to 0) (0 0 0 1 → 30H 30H 30H 31H) | Data 2 (M31 to 16) (8 0 0 0 → 38H 30H 30H 30H) | ETX 03H | Sum Check (5 6 → 35H 36H) 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1 1 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 M M M M M M M M M M M M M M M M M M M M M M M M M M M M 1 1 1 1 1 1 9 8 7 6 5 4 3 2 1 0 3 3 2 2 2 2 2 2 2 2 2 2 1 1 1 1 5 4 3 2 1 0 1 0 9 8 7 6 5 4 3 2 1 0 9 8 7 6
Response message during normal communication (GOT → host)	ACK: 06H
Response message during faulty communication (GOT → host)	(format 1: GOT-A900 Series microcomputer connection (format 1)) NAK: 15H (format 2: GOT-A900 Series microcomputer connection (format 2)) NAK: 15H | Error code: 06H The above is a case where the sum check error (06H) has occurred.

(3) Random read in word units (RR) command

The following shows an example of reading the two points of the virtual devices D100 and M0 to M15.
(Assuming D100=0064H, M0=1are stored.)



Item	Message format
Request message (host → GOT)	
Response message during normal communication (GOT → host)	
Response message during faulty communication (GOT → host)	(format 1: GOT-A900 Series microcomputer connection (format 1))  (format 2: GOT-A900 Series microcomputer connection (format 2))  The above is a case where the sum check error (06H) has occurred.

STX
Command
Address 1
Address 2
ETX
Sum Check
02H
R R 0 1 0 0 8 3 2 0 3 5
52H 52H 30H 31H 30H 30H 38H 33H 32H 30H 03H 33H 35H
(H) (L) (H) – – (L) (H) – – (L) (H) (L)
Sum check is performed in this range.

Sum check is performed in this range.
STX
Data 1 (D100)
Data 2 (M15 to 0)
ETX
Sum Check
02H
0 0 6 4 0 0 0 1 8 E
30H 30H 36H 34H 30H 30H 30H 31H 03H 38H 45H
(H) – – (L) (H) – – (L) (H) (L)
0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1
MMMMMMMMMMMMMMMM
1 1 1 1 1 1 9 8 7 6 5 4 3 2 1 0
5 4 3 2 1 0

(4) Random write in word units (RW) command

The following shows an example of writing "0064H" and "1" to virtual devices D100 and M0, respectively.



Item	Message format
Request message (host → GOT)	
Response message during normal communication (GOT → host)	
Response message during faulty communication (GOT → host)	(format 1: GOT-A900 Series microcomputer connection (format 1))  (format 2: GOT-A900 Series microcomputer connection (format 2)) 

The above is a case where the sum check error (06H) has occurred.

(5) Read clock data (TR) command

The following shows an example of reading the clock data of GOT.
(Assuming that the clock data of GOT has been set to "2004, June 1, 18:46:49, Tuesday".)



<table>
<tr><th>Item</th><th>Message format</th></tr>
<tr><td>Request message
(host → GOT)</td><td>
<table>
<tr><td>STX</td><td colspan="3">Command</td><td>ETX</td><td colspan="2">Sum Check</td></tr>
<tr><td></td><td>T</td><td>R</td><td></td><td></td><td>A</td><td>9</td></tr>
<tr><td>02H</td><td>54H</td><td>52H</td><td>03H</td><td></td><td>41H</td><td>39H</td></tr>
<tr><td></td><td>(H)</td><td>(L)</td><td></td><td></td><td>(H)</td><td>(L)</td></tr>
</table>
Sum check is performed in this range.
</td></tr>
<tr><td>Response message during normal communication
(GOT → host)</td><td>
<table>
<tr><td>STX</td><td colspan="2">Year data</td><td colspan="2">Month data</td><td colspan="2">Day data</td><td colspan="2">Hour data</td><td colspan="2">Minute data</td><td colspan="2">Second data</td><td colspan="2">Day-of-week data</td><td>ETX</td><td colspan="2">Sum Check</td></tr>
<tr><td></td><td>0</td><td>4</td><td>0</td><td>6</td><td>0</td><td>1</td><td>1</td><td>8</td><td>4</td><td>6</td><td>4</td><td>9</td><td>0</td><td>2</td><td></td><td>D</td><td>0</td></tr>
<tr><td>02H</td><td>30H</td><td>34H</td><td>30H</td><td>36H</td><td>30H</td><td>31H</td><td>31H</td><td>38H</td><td>34H</td><td>36H</td><td>34H</td><td>39H</td><td>30H</td><td>32H</td><td>03H</td><td>44H</td><td>30H</td></tr>
<tr><td></td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td></td><td>(H)</td><td>(L)</td></tr>
</table>
Sum check is performed in this range.
</td></tr>
<tr><td>Response message during faulty communication
(GOT → host)</td><td>
(format 1: GOT-A900 Series microcomputer connection (format 1))
<table>
<tr><td>NAK</td></tr>
<tr><td>15H</td></tr>
</table>
(format 2: GOT-A900 Series microcomputer connection (format 2))
<table>
<tr><td>NAK</td><td>Error code</td></tr>
<tr><td>15H</td><td>06H</td></tr>
</table>
The above is a case where the sum check error (06H) has occurred.
</td></tr>
</table>

(6) Set clock data (TS) command

The following shows an example of setting the clock data of GOT.
(Assuming the clock data of GOT is to be set to "2004, June 1, 18:46:49 Tuesday".)



After execution

<table>
<tr><th>Item</th><th>Message format</th></tr>
<tr><td>Request message
(host → GOT)</td><td>
<table>
<tr><td>STX</td><td colspan="2">Command</td><td colspan="2">Year data</td><td colspan="2">Month data</td><td colspan="2">Day data</td><td colspan="2">Hour data</td><td colspan="2">Minute data</td><td colspan="2">Second data</td><td colspan="2">Day-of-week data</td><td>ETX</td><td colspan="2">Sum Check</td></tr>
<tr><td>02H</td><td>T
54H
(H)</td><td>S
53H
(L)</td><td>0
30H
(H)</td><td>4
34H
(L)</td><td>0
30H
(H)</td><td>6
36H
(L)</td><td>0
30H
(H)</td><td>1
31H
(L)</td><td>1
31H
(H)</td><td>8
38H
(L)</td><td>4
34H
(H)</td><td>6
36H
(L)</td><td>4
34H
(H)</td><td>9
39H
(L)</td><td>0
30H
(H)</td><td>2
32H
(L)</td><td>03H</td><td>7
37H
(H)</td><td>7
37H
(L)</td></tr>
</table>
Sum check is performed in this range.
</td></tr>
<tr><td>Response message during normal communication
(GOT → host)</td><td>
<table>
<tr><td>ACK</td></tr>
<tr><td>06H</td></tr>
</table>
</td></tr>
<tr><td>Response message during faulty communication
(GOT → host)</td><td>
(format 1: GOT-A900 Series microcomputer connection (format 1))
<table>
<tr><td>NAK</td></tr>
<tr><td>15H</td></tr>
</table>
(format 2: GOT-A900 Series microcomputer connection (format 2))
<table>
<tr><td>NAK</td><td>Error code</td></tr>
<tr><td>15H</td><td>06H</td></tr>
</table>
The above is a case where the sum check error (06H) has occurred.
</td></tr>
</table>

POINT

When a wrong day of the week has been set by the clock data setting command

If a wrong day of the week is set by the clock data setting commands, the clock data will differ from the time displayed on the utility.

Example: When June 1, 2004 (Thursday) is set by the clock data setting command (the actual day of week is Tuesday), Tuesday (TUE) will be displayed on the utility time display.

(7) In the case of interrupt outputs

The following shows an example of an interrupt output when data are written to the interrupt output devices (D13 and D14).

(Assuming that "3139H" is written to D13 and "AA55H" to D14.)

Example: When the number of interrupt data bytes is 2



Item	Message format
Interrupt output (GOT → host)	(1) When [Interrupt Data Byte] in "Communication Detail Settings" is set to "1 byte"

(format 1: in the case of GOT-A900 Series microcomputer connection (format 1))

Output value 1
39H

(format 2: in the case of GOT-A900 Series microcomputer connection (format 2))

STX	Output value 1	ETX	Sum check	
			3	C
02H	39H	03H	33H	43H
			(H)	(L)

Sum check is performed in this range.

(2) When [Interrupt Data Byte] in "Communication Detail Settings" is set to "2 byte"

(format 1: in the case of GOT-A900 Series microcomputer connection (format 1))

Output value 1	Output value 2
31H	39H

(format 2: in the case of GOT-A900 Series microcomputer connection (format 2))

STX	Output value 1	Output value 2	ETX	Sum check	
				6	D
02H	31H	39H	03H	36H	44H
				(H)	(L)

Sum check is performed in this range.

(3) When [Interrupt Data Byte] in "Communication Detail Settings" is set to "4 byte"

(format 1: in the case of GOT-A900 Series microcomputer connection (format 1))

Output value1	Output value2	Output value3	Output value4
AAH	55H	31H	39H

(format 2: in the case of GOT-A900 Series microcomputer connection (format 2))

STX	Output value1	Output value2	Output value3	Output value4	ETX	Sum Check	
						6	C
02H	AAH	55H	31H	39H	03H	36H	43H
						(H)	(L)

Sum check is performed in this range.

POINT

Interrupt output

- To disable the interrupt output, turn ON SM52 (interrupt code output disable flag). (☞ 2.4.6 SM devices)
- To enable the interrupt output, set 8 bits to the data length at "Communication Detail Settings".
  (☞ 2.6.1 Setting communication interface (Communication settings))
- When "7 bits" is set, the MSB (8th bit) is ignored. (Example: FFH→7FH)

■ Error code list

In the case of format 2 (GOT-A900 series microcomputer connection (format 2)), the error contents (error code) are appended to the response message during faulty communication.
The following shows error code, error contents, cause, and measures.

Error code	Description	Action
06H	Sum check error The sum check code created from received data differs from the sum check code in the receive data.	• Review the contents of the message to transmit.
10H	Command error An unsupported command was used.	• Review the contents of the message to transmit. • Check the commands in the message. (☞ 2.5.2 List of commands)
11H	Message length error The upper limit of the data length that can be received by the GOT has been exceeded.	• Review the contents of the message to transmit. • Check the data length of the message.(data length of the data section, etc.)
12H	Communication message error EXT was not found within the upper limit of the receive buffer.	• Check the communication cable and communication module attachment. • Check the settings of "Communication Detail Settings". • Review the contents of the message to transmit.
15H	Clock data setting error The setting value of the clock data has error.	• Review the contents of the message to transmit. • Check whether the non-existent data is set (e.g. setting "07" at the day of the week) as clock data.
7AH	Address error The start address of the read/write device is out of range.	• Review the contents of the message to transmit. • Check the devices that can be used and the device ranges. (☞ 2.4 Device Data Area)
7BH	Exceeded number of points error The read/write range exceeded the device range.	

■ Precautions

(1) Batch reading/writing crossing over different devices
When using the batch read (RD) or batch write (WD) command, do not batch read/write crossing over the different devices.
This will cause an error response.

(2) Storage order for 32-bit data
To use the program of GOT-A900 series with [32bit Order] setting to GOT1000 series, set [HL Order] to [32bit Order] for [Communication Detail Settings] when 32-bit data is set for GOT-A900 series.
With setting [LH Order], the order of upper bits and lower bits are reversed when the GOT displays and writes 32-bit data.

2.5.4 Formats 3 to 6 (A compatible 1C frame)

■ Basic format of data communication

This is the same message format as when communication is performed using the dedicated protocol (A compatible 1C frame) of the A Series computer link module.
For details of the basic format of data communication, refer to the following manual:

☞ MELSEC-Q/L MELSEC Communication Protocol Reference Manual

This section describes items whose settings differ from the dedicated protocol of the A Series computer link modules, and the dedicated commands for a GOT microcomputer connection.

Example: Request message for the batch read in word units (QR) command in format 4 (A compatible 1C frame (format 2))

Character A section

ENQ	Block No.		Station No.		PLC No.		Command		Wait	Address							Number of points		Sum Check	
	0	0	0	0	0	0	Q	R	0	D	0	0	0	1	0	0	0	2	B	A
05H	30H	30H	30H	30H	30H	30H	51H	52H	30H	44H	30H	30H	30H	31H	30H	30H	30H	32H	42H	41H
	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)		(H)	–	–	–	–	–	(L)	(H)	(L)	(H)	(L)

Sum check is performed in this range.

■ Details of data items in message format

POINT

Data code during communication
Communication is performed in ASCII code.

(1) Block No, PLC No.
Ignored in a microcomputer connection of the GOT.
Specify "00".
"00" is converted to a 2-digit ASCII code (Hex) and transmitted from the upper digit.

(2) Station No.
Station No. is used to identify the GOT with which the host communicates. (Setting range: 0 to 31)
The address notated in decimal is converted to a 2-digit ASCII code (Hex) and transmitted from the upper digit.
The GOT processes only commands whose station No. matches the "Host Address (0 to 31)" set at "Communication Detail Settings". (The message of command whose station No. does not match is ignored.)
For setting method of "Communication Detail Settings", refer to the following.

☞ 2.6.1 Setting communication interface (Communication settings)

(3) Command
Specifies the contents to access from the host to GOT.
The command is converted to a 2-digit ASCII code (Hex) and transmitted from the upper digit.
For details of the commands that can be used, refer to the following.

☞ 2.5.2 List of commands

(4) Address

Specifies the head No. of the device data to be read/written.
The data annotated in decimal is converted to a 5- or 7-digit ASCII code (Hex) and transmitted from the upper digit.
For details of the device range that can be accessed, refer to the following.

☞ 2.4 Device Data Area

(5) Number of points

Specifies the number of device data to be read/written. (Setting range: 1 to 40H)
The address notated in hexadecimal is converted to a 2-digit ASCII code (Hex) and transmitted from the upper digit.

(6) Year, month, day, hour, minute, second and day of the week data

Specifies year, month, day, hour, minute, second, and day of the week to be read/set to the GOT clock data.
The address notated in decimal is converted to a 2-digit ASCII code (Hex) and transmitted from the upper digit.

☞ ■ (1) Read clock data (TR) command

☞ ■ (2) Set clock data (TS) command

(7) Error code

This is the response message at faulty communication appended with error contents.
The address notated in hexadecimal is converted to a 2-digit ASCII code (Hex) and transmitted from the upper digit.
For details of error codes generated in formats 3 to 6 (A compatible 1C frame), refer to the following:

☞ ■ Error code list

POINT

When connecting a microcomputer, etc. that uses the dedicated protocol of the A series computer link module with the GOT

When connecting a microcomputer, etc. that uses the dedicated protocol of the A series computer link module with the GOT, correct the commands to use and the device range according to the specifications of GOT.

■ Message format

The following shows the message format of the dedicated commands for a microcomputer connection of GOT.

(1) Read clock data (TR) command

The following shows an example of reading the clock data of GOT.
(Assuming that the clock data of GOT has been set to "2004, June 1, 18:46:49, Tuesday".)



<table>
<tr><th>Item</th><th>Message format</th></tr>
<tr><td>Request message
(host → GOT)</td><td>Example: Format 3 (A compatible 1C frame (format 1))
<table>
<tr><td>ENQ</td><td colspan="2">Station No.</td><td colspan="2">PLC No.</td><td colspan="2">Command</td><td>Wait</td><td colspan="2">Sum Check</td></tr>
<tr><td></td><td>0</td><td>0</td><td>0</td><td>0</td><td>T</td><td>R</td><td>0</td><td>9</td><td>6</td></tr>
<tr><td>05H</td><td>30H</td><td>30H</td><td>30H</td><td>30H</td><td>54H</td><td>52H</td><td>30H</td><td>39H</td><td>36H</td></tr>
<tr><td></td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td></td><td>(H)</td><td>(L)</td></tr>
</table>
Sum check is performed in this range.</td></tr>
<tr><td>Response message during normal communication
(GOT → host)</td><td>Example: Format 3 (A compatible 1C frame (format 1))
Character B section
<table>
<tr><td>STX</td><td colspan="2">Station No.</td><td colspan="2">PLC No.</td><td rowspan="4">Following*1</td><td>ETX</td><td colspan="2">Sum Check</td></tr>
<tr><td></td><td>0</td><td>0</td><td>0</td><td>0</td><td></td><td>9</td><td>0</td></tr>
<tr><td>02H</td><td>30H</td><td>30H</td><td>30H</td><td>30H</td><td>03H</td><td>39H</td><td>30H</td></tr>
<tr><td></td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td></td><td>(H)</td><td>(L)</td></tr>
</table>
Sum check is performed in this range.
*1
<table>
<tr><td></td><td colspan="2">Year data</td><td colspan="2">Month data</td><td colspan="2">Day data</td><td colspan="2">Hour data</td><td colspan="2">Minute data</td><td colspan="2">Second data</td><td colspan="2">Day-of-week data</td></tr>
<tr><td></td><td>0</td><td>4</td><td>0</td><td>6</td><td>0</td><td>1</td><td>1</td><td>8</td><td>4</td><td>6</td><td>4</td><td>9</td><td>0</td><td>2</td></tr>
<tr><td></td><td>30H</td><td>34H</td><td>30H</td><td>36H</td><td>30H</td><td>31H</td><td>31H</td><td>38H</td><td>34H</td><td>36H</td><td>34H</td><td>39H</td><td>30H</td><td>32H</td></tr>
<tr><td></td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td></tr>
</table></td></tr>
<tr><td>Response message during faulty communication
(GOT → host)</td><td>Example: Format 3 (A compatible 1C frame (format 1))
<table>
<tr><td>NAK</td><td colspan="2">Station No.</td><td colspan="2">PLC No.</td><td colspan="2">Error code</td></tr>
<tr><td></td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>5</td></tr>
<tr><td>15H</td><td>30H</td><td>30H</td><td>30H</td><td>30H</td><td>30H</td><td>35H</td></tr>
<tr><td></td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td></tr>
</table>
The above is the case where an overrun error (05H) has occurred.</td></tr>
</table>

(2) Set clock data (TS) command

The following shows an example of setting the clock data of GOT.

(Assuming the clock data of GOT is to be set to "2004, June 1, 18:46:49 Tuesday".)



After execution

Item	Message format

Request message (host → GOT)

Example: Format 3 (A compatible 1C frame (format 1))

Character C section

ENQ	Station No.		PLC No.		Command		Wait	Following*1	Sum Check	
	0	0	0	0	T	S	0		6	4
05H	30H	30H	30H	30H	54H	53H	30H		36H	34H
	(H)	(L)	(H)	(L)	(H)	(L)			(H)	(L)

Sum check is performed in this range.

*1

Year data		Month data		Day data		Hour data		Minute data		Second data		Day-of-week data	
0	4	0	6	0	1	1	8	4	6	4	9	0	2
30H	34H	30H	36H	30H	31H	31H	38H	34H	36H	34H	39H	30H	32H
(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)

Response message during normal communication (GOT → host)

Example: Format 3 (A compatible 1C frame (format 1))

ACK	Station No.		PLC No.	
	0	0	0	0
06H	30H	30H	30H	30H
	(H)	(L)	(H)	(L)

Response message during faulty communication (GOT → host)

Example: Format 3 (A compatible 1C frame (format 1))

NAK	Station No.		PLC No.		Error code	
	0	0	0	0	0	5
15H	30H	30H	30H	30H	30H	35H
	(H)	(L)	(H)	(L)	(H)	(L)

The above is the case where an overrun error (05H) has occurred.

POINT

When a wrong day of the week has been set by the clock data setting command

If a wrong day of the week is set by the clock data setting commands, the clock data will differ from the time displayed on the utility.

Example: When June 1, 2004 (Thursday) is set by the clock data setting command (the actual day of week is Tuesday), Tuesday (TUE) will be displayed on the utility time display.

■ Error code list

The following shows error code, error contents, cause, and measures.

Error code	Description	Action
01H	Parity error The parity bit does not match.	• Check the communication cable and communication module attachment. • Check the settings of "Communication Detail Settings". • Match the GOT and host transmission settings.
02H	Sum check error The sum check code created from received data differs from the sum check code in the receive data.	• Review the contents of the message to transmit.
03H	Protocol error Received a message that does not follow the control procedure of the format set at "Communication Detail Settings".	• Check the settings of "Communication Detail Settings". • Review the contents of the message to transmit.
05H	Overrun error The next data was transmitted from the host before GOT completes the processing of the data received.	• Check the settings of "Communication Detail Settings". • Decrease the transmission speed.
06H	Character section error The character section specification error. •The method of specifying the character section is wrong. •The specified command has error. •The number of points of the processing requests exceeds the allowable range. •A non-existent device has been specified. •The setting value of the clock data has error.	• Review the contents of the message to transmit. • Check the commands in the message. (☞ 2.5.2 List of commands) • Check the devices that can be used and the device ranges. (☞ 2.4 Device Data Area) • Check whether the non-existent data is set (e.g. setting "07" at the day of the week) as clock data.
07H	Character error A character other than "A to Z", "0 to 9", space, and control codes has been received.	• Review the contents of the message to transmit.

2.5.5 Formats 7 to 10 (QnA compatible 3C/4C frame)

■ Basic format of data communication

This is the same message format as when communication is performed using the MC protocol (QnA compatible 3C/4C frame) of the Q/QnA Series serial communication module.
For details of the basic format of data communication, refer to the following manual:

☞ MELSEC-Q/L MELSEC Communication Protocol Reference Manual

This section describes items whose settings differ from the MC protocol of the Q/QnA Series serial communication module, and the dedicated commands for a GOT microcomputer connection.

Example: Request message for the batch read in word units (0401) command in format 8 (QnA compatible 4C frame (format 2))

ENQ	Block No.		Frame ID No.		Station No.		Network No.		PLC No.		Request destination module I/O No.				Request destination module station No.		Host Address No.		Following *1	Sum check	
	0	0	F	8	0	0	0	0	0	0	0	0	0	0	0	0	0	0		B	A
05H	30H	30H	46H	38H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H		42H	41H
	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	–	–	(L)	(H)	(L)	(H)	(L)		(H)	(L)

Sum check is performed in this range.

*1 Character A section

Command				Sub-command				Device code		Head Device						Device points			
0	4	0	1	0	0	0	0	D	*	0	0	0	1	0	0	0	0	0	2
30H	34H	30H	31H	30H	30H	30H	30H	44H	2AH	30H	30H	30H	31H	30H	30H	30H	30H	30H	32H
(H)	–	–	(L)	(H)	–	–	(L)	(H)	(L)	(H)	–	–	–	–	(L)	(H)	–	–	(L)

POINT

QnA compatible 4C frame (format 5)
GOT cannot use the QnA compatible 4C frame (format 5).

■ Details of data items in message format

POINT

Data code during communication
Communication is performed in ASCII code.

(1) Block No., network No., PLC No., request destination module I/O No. and station No.
Ignored in a microcomputer connection of the GOT.
Specify "00". (The request destination module I/O No. is "0000".)
"00" is converted to a 2-digit ASCII code (Hex) and transmitted from the upper digit.
(The request destination module I/O No. is 4-digit.)

(2) Station No.
Station No. is used to identify the GOT with which the host communicates.(Setting range: 0 to 1FH)
The address notated in hexadecimal is converted to a 2-digit ASCII code (Hex) and transmitted from the upper digit.
The GOT processes only commands whose station No. matches the "Host Address (0 to 31)" set at "Communication Detail Settings". (The message of command whose station No. does not match is ignored.)
For setting method of "Communication Detail Settings", refer to the following.

☞ 2.6.1 Setting communication interface (Communication settings)

(3) Command, sub-command
Specifies the contents to access from the host to GOT.
The command is converted to a 4-digit ASCII code (Hex) and transmitted from the upper digit.
For details of the commands that can be used, refer to the following.

☞ 2.5.2 List of commands

(4) Device code
Specifies the code by which the device data to be read/written is recognized.
The command is converted to a 2-digit ASCII code (Hex) and transmitted from the upper digit.
For details of the device range that can be accessed, refer to the following.

☞ 2.4 Device Data Area

(5) Head device
Specifies the head No. of the device data to be read/written.
The address notated in decimal is converted to a 6-digit ASCII code (Hex) and transmitted from the upper digit.
For details of the device range that can be accessed, refer to the following.

☞ 2.4 Device Data Area

(6) Device points
Specifies the number of device data to be read/written. (Setting range: 1 to 40H)
The address notated in hexadecimal is converted to a 2-digit ASCII code (Hex) and transmitted from the upper digit.
When specifying multiple devices as follows, limit the total device points to within 64 points.

(a) When using random read/write command
When setting multiple bit accesses, word accesses or double word accesses, limit the total number of access points to within 64 points

(b) When using multiple block batch read/write commands
When setting multiple blocks, limit the total number of points of all blocks to within 64 points.

(7) Year, month, day, hour, minute, second and day of the week data

Specifies year, month, day, hour, minute, second, and day of the week to be read/set to the GOT clock data.
The address notated in decimal is converted to a 2-digit ASCII code (Hex) and transmitted from the upper digit.

☞ ■ Message format (1) Read clock data (1901) command

☞ ■ Message format (2) Set clock data (0901) command

(8) Error code

This is the response message at faulty communication appended with error contents.
The address notated in hexadecimal is converted to a 4-digit ASCII code (Hex) and transmitted from the upper digit.
For details of error codes that are generated in formats 7 to 10 (QnA compatible 3C/4C frame), refer to the following:

☞ ■ Error code list

POINT

When connecting a microcomputer, etc. that uses the MC protocol of the Q/QnA series serial communication module with the GOT

When connecting a microcomputer, etc. that uses the MC protocol of the Q/QnA series serial communication module with the GOT, correct the commands to be used and the device ranges to match the GOT specifications.

■ Message format

The following shows the message format of the dedicated commands for a microcomputer connection of GOT.

(1) Read clock data (1901) command

The following shows an example of reading the clock data of GOT.
(Assuming that the clock data of GOT has been set to "2004, June 1, 18:46:49, Tuesday".)



<table>
<tr><th>Item</th><th>Message format</th></tr>
<tr><td>Request message
(host → GOT)</td><td>
Example: Format 7 (QnA compatible 4C frame (format 1))
<table>
<tr><td>ENQ</td><td colspan="2">Frame ID No.</td><td colspan="2">Station No.</td><td colspan="2">Network No.</td><td colspan="2">PLC No.</td><td colspan="4">Request destination module I/O No.</td><td colspan="2">Request destination module station No.</td><td rowspan="3">Following *1</td><td colspan="2">Sum check</td></tr>
<tr><td></td><td>F</td><td>8</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>A</td><td>9</td></tr>
<tr><td>05H</td><td>46H</td><td>38H</td><td>30H</td><td>30H</td><td>30H</td><td>30H</td><td>30H</td><td>30H</td><td>30H</td><td>30H</td><td>30H</td><td>30H</td><td>30H</td><td>30H</td><td>41H</td><td>39H</td></tr>
<tr><td></td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>–</td><td>–</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td></tr>
</table>
Sum check is performed in this range.
<table>
<tr><td>*1</td><td colspan="2">Host Address No.</td><td colspan="2">Command</td><td colspan="2">Sub-command</td></tr>
<tr><td></td><td>0</td><td>0</td><td>1</td><td>9</td><td>0</td><td>1</td><td>0</td><td>0</td><td>0</td><td>0</td></tr>
<tr><td></td><td>30H</td><td>30H</td><td>31H</td><td>39H</td><td>30H</td><td>31H</td><td>30H</td><td>30H</td><td>30H</td><td>30H</td></tr>
<tr><td></td><td>(H)</td><td>(L)</td><td>(H)</td><td>–</td><td>–</td><td>(L)</td><td>(H)</td><td>–</td><td>–</td><td>(L)</td></tr>
</table>
Character A section
</td></tr>
<tr><td>Response message during normal communication
(GOT → host)</td><td>
Example: Format 7 (QnA compatible 4C frame (format 1))
<table>
<tr><td>STX</td><td colspan="2">Frame ID No.</td><td colspan="2">Station No.</td><td colspan="2">Network No.</td><td colspan="2">PLC No.</td><td colspan="4">Request destination module I/O No.</td><td colspan="2">Request destination module station No.</td><td rowspan="3">Following *1</td><td>ETX</td><td colspan="2">Sum check</td></tr>
<tr><td></td><td>F</td><td>8</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td></td><td>E</td><td>E</td></tr>
<tr><td>02H</td><td>46H</td><td>38H</td><td>30H</td><td>30H</td><td>30H</td><td>30H</td><td>30H</td><td>30H</td><td>30H</td><td>30H</td><td>30H</td><td>30H</td><td>30H</td><td>30H</td><td>03H</td><td>43H</td><td>43H</td></tr>
<tr><td></td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>–</td><td>–</td><td>(L)</td><td>(H)</td><td>(L)</td><td></td><td>(H)</td><td>(L)</td></tr>
</table>
Sum check is performed in this range.
<table>
<tr><td>*1</td><td colspan="2">Host Address No.</td><td colspan="2">Year data</td><td colspan="2">Month data</td><td colspan="2">Day data</td><td colspan="2">Hour data</td><td colspan="2">Minute data</td><td colspan="2">Second data</td><td colspan="2">Day-of-week data</td></tr>
<tr><td></td><td>0</td><td>0</td><td>0</td><td>4</td><td>0</td><td>6</td><td>0</td><td>1</td><td>1</td><td>8</td><td>4</td><td>6</td><td>4</td><td>9</td><td>0</td><td>2</td></tr>
<tr><td></td><td>30H</td><td>30H</td><td>30H</td><td>34H</td><td>30H</td><td>36H</td><td>30H</td><td>31H</td><td>31H</td><td>38H</td><td>34H</td><td>36H</td><td>34H</td><td>39H</td><td>30H</td><td>32H</td></tr>
<tr><td></td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td></tr>
</table>
Character B section
</td></tr>
</table>

(Continued to next page)

(From previous page)

Item	Message format
Response message during faulty communication (GOT → host)	Example: Format 7 (QnA compatible 4C frame (format 1))

NAK	Frame ID No.		Station No.		Network No.		PLC No.		Request destination module I/O No.				Request destination module station No.		Host Address No.		Following *1
15H	F	8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	46H	38H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	
	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	–	–	(L)	(H)	(L)	(H)	(L)	

*1

Error code			
7	F	6	9
37H	46H	36H	39H
(H)	–	–	(L)

The above is the case where a parity error (7F69H) has occurred.

(2) Set clock data (0901) command

The following shows an example of setting the clock data of GOT.
(Assuming the clock data of GOT is to be set to "2004, June 1, 18:46:49 Tuesday".)



After execution

Item	Message format
Request message (host → GOT)	Example: Format 7 (QnA compatible 4C frame (format 1))
Response message during normal communication (GOT → host)	Example: Format 7 (QnA compatible 4C frame (format 1))

Request message (host → GOT)

ENQ	Frame ID No.		Station No.		Network No.		PLC No.		Request destination module I/O No.				Request destination module station No.		Host Address No.		Following *1	Sum check	
	F	8	0	0	0	0	0	0	0	0	0	0	0	0	0	0		7	5
05H	46H	38H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H		37H	35H
	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	–	–	(L)	(H)	(L)	(H)	(L)		(H)	(L)

Sum check is performed in this range.

Character C section

*1

Command				Sub-command				
0	9	0	1	0	0	0	0	→ 1)
30H	39H	30H	31H	30H	30H	30H	30H	
(H)	–	–	(L)	(H)	–	–	(L)	

Character C section

1) →

Year data		Month data		Day data		Hour data		Minute data		Second data		Day-of-week data	
0	4	0	6	0	1	1	8	4	6	4	9	0	2
30H	34H	30H	36H	30H	31H	31H	38H	34H	36H	34H	39H	30H	32H
(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)

Response message during normal communication (GOT → host)

ACK	Frame ID No.		Station No.		Network No.		PLC No.		Request destination module I/O No.				Request destination module station No.		Host Address No.	
	F	8	0	0	0	0	0	0	0	0	0	0	0	0	0	0
06H	46H	38H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H
	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	–	–	(L)	(H)	(L)	(H)	(L)

(Continued to next page)

(From previous page)

Item	Message format
Response message during faulty communication (GOT → host)	Example: Format 7 (QnA compatible 4C frame (format 1))

NAK	Frame ID No.		Station No.		Network No.		PLC No.		Request destination module I/O No.				Request destination module station No.		Host Address No.		Following*1
	F	8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
15H	46H	38H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	
	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	–	–	(L)	(H)	(L)	(H)	(L)	

*1

	Error code			
	7	F	6	9
	37H	46H	36H	39H
	(H)	–	–	(L)

The above is the case where a parity error (7F69H) has occurred.

POINT

When a wrong day of the week has been set by the clock data setting command

If a wrong day of the week is set by the clock data setting commands, the clock data will differ from the time displayed on the utility.

Example: When June 1, 2004 (Thursday) is set by the clock data setting command (the actual day of week is Tuesday), Tuesday (TUE) will be displayed on the utility time display.

■ Error code list

The following shows error code, error contents, cause, and measures.

Error code	Description	Action
7E40H	Command error An unsupported command or sub-command was used.	• Review the contents of the message to transmit. • Check the commands in the message. (☞ 2.5.2 List of commands)
7E41H	Data length error Specified points exceeding the number of points that can be communicated during random read/write.	• Review the contents of the message to transmit. • Check the devices that can be used and the device ranges. (☞ 2.4 Device Data Area)
7E42H	Number of data error The number of requests exceeds the command range.	
7E43H	Device error A non-existent device has been specified.	• Review the contents of the message to transmit. • Check the devices that can be used and the device ranges. (☞ 2.4 Device Data Area)
7E46H	Clock data setting error The setting value of the clock data has error.	• Review the contents of the message to transmit. • Check whether the non-existent data is set (e.g. setting "07" at the day of the week) as clock data.
7E4FH	Exceeded number of points error The read/write range exceeded the device range.	• Review the contents of the message to transmit. • Check the devices that can be used and the device ranges. (☞ 2.4 Device Data Area)
7F20H	Character error A character other than "A to Z", "0 to 9", space, and control codes has been received.	• Review the contents of the message to transmit.
7F23H	Communication message error EXT/CR+LF was not found within the upper limit of the receive buffer.	• Check the communication cable and communication module attachment. • Check the settings of "Communication Detail Settings". • Review the contents of the message to transmit.
7F24H	Sum check error The sum check code created from received data differs from the sum check code in the receive data.	• Review the contents of the message to transmit.
7F67H	Overrun error The next data was transmitted from the host before GOT completes the processing of the data received.	• Check the settings of "Communication Detail Settings". • Decrease the transmission speed.
7F68H	Framing error The data bit and/or stop bit are not correct.	• Check the communication cable and communication module attachment. • Check the settings of "Communication Detail Settings". • Match the GOT and host transmission settings.
7F69H	Parity error The parity bit does not match.	
7F6AH	Buffer full error The receive buffer overflowed.	• Check the communication cable and communication module attachment. • Check the settings of "Communication Detail Settings". • Review the contents of the message to transmit.

2.5.6 Formats 11 to 13 (Digital Electronics Corporation's memory link method)

■ Basic format of data communication

This is the same format as the protocol of the Digital Electronics Corporation's memory link method.
For details of the basic format of data communication, refer to the following manual:

☞ The connection manual of the device manufactured by Digital Electronics Corporation

This section describes items whose settings differ from the protocols of the Digital Electronics Corporation's memory link method and dedicated commands for a microcomputer connection of GOT.

Example:Request message for the batch read in word units (R) command in format 13 (Digital Electronics Corporation's memory link method (extended mode, ASCII code 1:n))

ENQ	Station No.		ESC	Com-mand	Address				Number of points				Sum Check		CR	LF
	0	0		R	0	0	6	4	0	0	0	2	5	E		
05H	30H	30H	1BH	52H	30H	30H	36H	34H	30H	30H	30H	32H	35H	45H	0DH	0AH
	(H)	(L)			(H)	–	–	(L)	(H)	–	–	(L)	(H)	(L)		

Sum check is performed in this range.

POINT

Compatibility with the Digital Electronics Corporation's memory link method

In the case of formats 12 and 13 (Digital Electronics Corporation's memory link method (extended mode)), a communication error may occur since some communication packets are not compatible with the Digital Electronics Corporation's memory link method in the communication.
To give the compatibility, turn on the digital compatible signals (GS580 to GS583) of the GOT internal device and communicate in the fully compatible message format.

Device	Function	Bit	Bit position	Settings
GS580	Microcomputer connection extended setting (CH1)	Digital compatible signal	b0	0: Partly compatible (Default) 1: Fully compatible
GS581	Microcomputer connection extended setting (CH2)	Digital compatible signal	b0	0: Partly compatible (Default) 1: Fully compatible
GS582	Microcomputer connection extended setting (CH3)	Digital compatible signal	b0	0: Partly compatible (Default) 1: Fully compatible
GS583	Microcomputer connection extended setting (CH4)	Digital compatible signal	b0	0: Partly compatible (Default) 1: Fully compatible

For the GOT internal device, refer to the following manual.

☞ GT Designer3 (GOT2000) Help

■ Details of data items in message format

POINT

Data code during communication

Communication is performed in ASCII code.

(1) Command

Specifies the contents to access from the host to GOT.
The command is converted to a 1-digit ASCII code (Hex) and transmitted.
For details of the commands that can be used, refer to the following.

☞ 2.5.2 List of commands

(2) Station No.

Station No. is used to identify the GOT with which the host communicates. (Setting range: 0 to 1FH)
The address notated in hexadecimal is converted to a 2-digit ASCII code (Hex) and transmitted from the upper digit.
The GOT processes only commands whose station No. matches the "Host Address (0 to 31)" set at "Communication Detail Settings". (The message of command whose station No. does not match is ignored.)
For setting method of "Communication Detail Settings", refer to the following.

☞ 2.6.2 Communication detail settings

(3) Address

Specifies the head No. of the device data to be read/written.
The address notated in hexadecimal is converted to a 4-digit ASCII code (Hex) and transmitted from the upper digit.
For details of the device range that can be accessed, refer to the following.

☞ 2.4 Device Data Area

(4) Number of points

Specifies the number of device data to be read/written. (Setting range: 1 to 40H)
The address notated in hexadecimal is converted to a 4-digit ASCII code (Hex) and transmitted from the upper digit.

(5) Year, month, day, hour, minute, second and day of the week data

Specifies year, month, day, hour, minute, second, and day of the week to be read/set to the GOT clock data.
The address notated in decimal is converted to a 2-digit ASCII code (Hex) and transmitted from the upper digit.

☞ ■ Message format (1) Read clock data (N) command

☞ ■ Message format (2) Set clock data (M) command

(6) Error code

This is the response message at faulty communication appended with error contents.
The address notated in hexadecimal is converted to a 2-digit ASCII code (Hex) and transmitted from the upper digit.
For details of error codes generated in formats 12 and 13 (Digital Electronics Corporation's memory link method (extended mode)), refer to the following:

☞ ■ Error code list

POINT

When connecting a microcomputer, etc. that uses the protocol of the Digital Electronics Corporation's memory link method with the GOT

When connecting a microcomputer, etc. that uses the protocol of the Digital Electronics Corporation's memory link method with the GOT, correct the commands to be used and the device ranges to match the specifications of the GOT.

■ Message format

The following shows the message format of the dedicated commands for a microcomputer connection of GOT.

(1) Read clock data (N) command

The following shows an example of reading the clock data of GOT.
(Assuming that the clock data of GOT has been set to "2004, June 1, 18:46:49, Tuesday".)



<table>
<tr><th>Item</th><th>Message format</th></tr>
<tr><td>Request message
(host → GOT)</td><td>
Example: Format 13 (Digital Electronics Corporation's memory link method (extended mode, ASCII code 1:n))
• Digital compatible signal (GS580 to GS583): OFF (Partly compatible)
<table>
<tr><th>ENQ</th><th colspan="2">Station No.</th><th>ESC</th><th>Com-mand</th><th colspan="2">Sum Check</th><th>CR</th><th>LF</th></tr>
<tr><td></td><td>0</td><td>0</td><td></td><td>N</td><td>C</td><td>E</td><td></td><td></td></tr>
<tr><td>05H</td><td>30H</td><td>30H</td><td>1BH</td><td>4EH</td><td>43H</td><td>45H</td><td>0DH</td><td>0AH</td></tr>
<tr><td></td><td>(H)</td><td>(L)</td><td></td><td></td><td>(H)</td><td>(L)</td><td></td><td></td></tr>
</table>
This range Sum check
• Digital compatible signal (GS580 to GS583): ON (Fully compatible)
<table>
<tr><th>ENQ</th><th colspan="2">Station No.</th><th>ESC</th><th>Com-mand</th><th colspan="2">Sum Check</th><th>CR</th><th>LF</th></tr>
<tr><td></td><td>0</td><td>0</td><td></td><td>N</td><td>C</td><td>9</td><td></td><td></td></tr>
<tr><td>05H</td><td>30H</td><td>30H</td><td>1BH</td><td>4EH</td><td>43H</td><td>39H</td><td>0DH</td><td>0AH</td></tr>
<tr><td></td><td>(H)</td><td>(L)</td><td></td><td></td><td>(H)</td><td>(L)</td><td></td><td></td></tr>
</table>
This range Sum check
</td></tr>
</table>

(Continued to next page)

Item	Message format
Response message during normal communication (GOT → host)	Example: Format 13 (Digital Electronics Corporation's memory link method (extended mode, ASCII code 1:n)) • Digital compatible signal (GS580 to GS583): OFF (Partly compatible)

STX	Station No.		ESC	Com-mand	Following*1	ETX	Sum Check		CR	LF
	0	0		A			8	E		
02H	30H	30H	1BH	41H		03H	38H	45H	0DH	0AH
	(H)	(L)					(H)	(L)		

This range Sum check

*1

Year data		Month data		Day data		Hour data		Minute data		Second data		Day-of-week data	
0	4	0	6	0	1	1	8	4	6	4	9	0	2
30H	34H	30H	36H	30H	31H	31H	38H	34H	36H	34H	39H	30H	32H
(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)

• Digital compatible signal (GS580 to GS583): ON (Fully compatible)

STX	Station No.		ESC	Com-mand	Following*1	ETX	Sum Check		CR	LF
	0	0		A			8	C		
02H	30H	30H	1BH	41H		03H	38H	43H	0DH	0AH
	(H)	(L)					(H)	(L)		

This range Sum check

*1

Year data		Month data		Day data		Hour data		Minute data		Second data		Day-of-week data	
0	4	0	6	0	1	1	8	4	6	4	9	0	2
30H	34H	30H	36H	30H	31H	31H	38H	34H	36H	34H	39H	30H	32H
(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)

Response message during faulty communication (GOT → host)	Example: Format 13 (Digital Electronics Corporation's memory link method (extended mode, ASCII code 1:n))

NAK	Station No.		Error code		CR	LF
	0	0	0	6		
15H	30H	30H	30H	36H	0DH	0AH
	(H)	(L)	(H)	(L)		

The above is a case where the sum check error (06H) has occurred.

(2) Set clock data (M) command

The following shows an example of setting the clock data of GOT.

(Assuming the clock data of GOT is to be set to "2004, June 1, 18:46:49 Tuesday".)



After execution

Item	Message format
Request message (host → GOT)	Example: Format 13 (Digital Electronics Corporation's memory link method (extended mode, ASCII code 1:n)) • Digital compatible signal (GS580 to GS583): OFF (Partly compatible)

ENQ	Station No.		ESC	Com-mand	Following*1	Sum Check		CR	LF
	0	0		M		9	A		
05H	30H	30H	1BH	4DH		39H	41H	0DH	0AH
	(H)	(L)				(H)	(L)		

Sum check is performed in this range.

*1

Year data		Month data		Day data		Hour data		Minute data		Second data		Day-of-week data	
0	4	0	6	0	1	1	8	4	6	4	9	0	2
30H	34H	30H	36H	30H	31H	31H	38H	34H	36H	34H	39H	30H	32H
(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)

• Digital compatible signal (GS580 to GS583): ON (Fully compatible)

ENQ	Station No.		ESC	Com-mand	Following*1	Sum Check		CR	LF
	0	0		M		9	5		
05H	30H	30H	1BH	4DH		39H	35H	0DH	0AH
	(H)	(L)				(H)	(L)		

Sum check is performed in this range.

*1

Year data		Month data		Day data		Hour data		Minute data		Second data		Day-of-week data	
0	4	0	6	0	1	1	8	4	6	4	9	0	2
30H	34H	30H	36H	30H	31H	31H	38H	34H	36H	34H	39H	30H	32H
(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)

Item	Message format
Response message during normal communication (GOT → host)	Example: Format 13 (Digital Electronics Corporation's memory link method (extended mode, ASCII code 1:n))

ACK	Station No.		CR	LF
	0	0		
06H	30H	30H	0DH	0AH
	(H)	(L)		

(Continued to next page)

(From previous page)

Item	Message format
Response message during faulty communication (GOT → host)	Example: Format 13 (Digital Electronics Corporation's memory link method (extended mode, ASCII code 1:n))

NAK	Station No.		Error code		CR	LF
	0	0	0	6		
15H	30H (H)	30H (L)	30H (H)	36H (L)	0DH	0AH

The above is a case where the sum check error (06H) has occurred.

POINT

When a wrong day of the week has been set by the clock data setting command

If a wrong day of the week is set by the clock data setting commands, the clock data will differ from the time displayed on the utility.

Example: When June 1, 2004 (Thursday) is set by the clock data setting command (the actual day of week is Tuesday), Tuesday (TUE) will be displayed on the utility time display.

(3) In the case of interrupt inquiry

The following shows an example of an interrupt inquiry when data are written to the interrupt output devices (D13 and D14).
(Assuming that "3139H" is written to D13 and "AA55H" to D14.)

Example: When the number of interrupt data bytes is 2 in format 11



Item	Message format
Request message (host → GOT)	Example: Format 13 (Digital Electronics Corporation's memory link method (extended mode, ASCII code 1:n)) • Digital compatible signal (GS580 to GS583): OFF (Partly compatible)  • Digital compatible signal (GS580 to GS583): ON (Fully compatible) 

(Continued to next page)

Item	Message format
Interrupt inquiry (GOT → host)	Example: Format 13 (Digital Electronics Corporation's memory link method (extended mode, ASCII code 1:n)) (1) When [Interrupt Data Byte] in "Communication Detail Settings" is set to "1 byte"

STX	Station No.		ESC	Com-mand	Output value 1		ETX	Sum Check		CR	LF
	0	0		I	3	9		9	4		
02H	30H	30H	1BH	49H	33H	39H	03H	39H	44H	0DH	0AH
	(H)	(L)			(H)	(L)		(H)	(L)		

This range Sum check is performed.

(2) When [Interrupt Data Byte] in "Communication Detail Settings" is set to "2 byte"

STX	Station No.		ESC	Com-mand	Output value 1		Output value 2		ETX	Sum Check		CR	LF
	0	0		I	3	1	3	9		F	9		
02H	30H	30H	1BH	49H	33H	31H	33H	39H	03H	46H	39H	0DH	0AH
	(H)	(L)			(H)	(L)	(H)	(L)		(H)	(L)		

Sum check is performed in this range.

(3) When [Interrupt Data Byte] in "Communication Detail Settings" is set to "4 byte"

STX	Station No.		ESC	Com-mand	Output value 1		Output value 2		Output value 3		Output value 4		ETX	Sum Check		CR	LF
	0	0		I	A	A	5	5	3	1	3	9		E	7		
02H	30H	30H	1BH	49H	41H	41H	35H	35H	33H	31H	33H	39H	03H	45H	37H	0DH	0AH
	(H)	(L)			(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)		(H)	(L)		

Sum check is performed in this range.

POINT

Interrupt output

- To disable the interrupt output, turn ON SM52 (interrupt code output disable flag).(☞ 2.4.6 SM devices)
- To issue interrupts in format 11, set the data length to "8 bits" at "Communication Detail Settings".
  (☞ 2.6.1 Setting communication interface (Communication settings))
- When "7 bits" is set, the MSB (8th bit) is ignored.(Example: FFH → 7FH)

■ Error code list

In the case of formats 12 and 13 (Digital Electronics Corporation's memory link method (extended mode)), the details (error code) of the error are appended to the response message during faulty communication.
The following shows error code, error contents, cause, and measures.

Error code	Description	Action
06H	Sum check error The sum check code created from received data differs from the sum check code in the receive data.	• Review the contents of the message to transmit.
10H	Command error An unsupported command was used.	• Review the contents of the message to transmit. • Check the commands in the message. (☞ 2.5.2 List of commands)
12H	Message length error The upper limit of the data length that can be received by the GOT has been exceeded.	
16H	Clock data setting error The setting value of the clock data has error.	• Review the contents of the message to transmit. • Check the data length of the message.(data length of the data section, etc.)
FAH	Address error The start address of the read/write device is out of range.	• Review the contents of the message to transmit. • Check whether the non-existent data is set (e.g. setting "07" at the day of the week) as clock data.
FBH	Exceeded number of points error The read/write range exceeded the device range.	• Review the contents of the message to transmit. • Check the devices that can be used and the device ranges. (☞ 2.4 Device Data Area)
FCH	Message format error The format of the received message has error.	• Check the settings of "Communication Detail Settings". • Review the contents of the message to transmit.
FFH	Timeout error There is no response from the GOT, or the station of the specified address does not exist.	• Check the communication cable and communication module attachment. • Check the settings of "Communication Detail Settings". • Review the contents of the message to transmit.

■ Precautions

(1) Batch reading/writing crossing over different devices
When using the batch read (R) or batch write (W) command, do not batch read/write crossing over the different devices.
This will cause an error response.

(2) Storage order for 32-bit data
To use the program of Digital Electronics Corporation's memory link method with [32bit Order] setting to GOT1000 series, set [HL Order] to [32bit Order] for [Communication Detail Settings] when 32-bit data is set for GOT-A900 series.
With setting [LH Order], the order of upper bits and lower bits are reversed when the GOT displays and writes 32-bit data.

2.5.7 Formats 14, 15 (GOT-F900 Series microcomputer connection)

■ Basic format of data communication

<table>
<tr><th>Item</th><th>Message format</th></tr>
<tr><td>Request message
(host → GOT)</td><td>
(format 14: GOT-F900 Series microcomputer connection (format 1))
(1) w/out station No.


(2) w/station No.


(format 15: GOT-F900 Series microcomputer connection (format 2))
(1) w/out station No.


(2) w/station No.


</td></tr>
<tr><td rowspan="2">Response message during normal communication
(GOT → host)</td><td>
(1) During processing of read commands
(format 14: GOT-F900 Series microcomputer connection (format 1))


(format 15: GOT-F900 Series microcomputer connection (format 2))


</td></tr>
<tr><td>
(2) During processing of write commands


</td></tr>
<tr><td>Response message during faulty communication
(GOT → host)</td><td>


</td></tr>
<tr><td>During interrupt output</td><td>


</td></tr>
</table>

*1 Set the number of interrupt data bytes at [Detail setting] in GT Designer3.
For the setting of the number of interrupt data bytes, refer to the following.

2.6.1 Setting communication interface (Communication settings)

■ Details of data items in message format

POINT

Data code during communication

Communication is performed in ASCII code. (excluding interrupt output)

(1) Control codes

Symbol	ASCII code	Description
STX	02H	Start of Text (start marker of message frame)
ETX	03H	End of Text (end marker of message frame)
EOT	04H	End of Transmission
ENQ	05H	Enquiry (start of enquiry)
NAK	15H	Negative ACK (error response)
ACK	06H	Acknowledge (write completion response)
LF	0AH	Line Feed
CL	0CH	Clear
CR	0DH	Carriage Return

(2) Command

Specifies the contents to access from the host to GOT.
The command is converted to a 1-digit ASCII code (Hex) and transmitted.
For details of the commands that can be used, refer to the following.

☞ 2.5.2 List of commands

(3) Station No.

Station No. is used to identify the GOT with which the host communicates. (Setting range: 0 to 31)
The address notated in decimal is converted to a 2-digit ASCII code (Hex) and transmitted from the upper digit.
The GOT processes only commands whose station No. matches the "Host Address (0 to 31)" set at "Communication Detail Settings". (The message of command whose station No. does not match is ignored.)
For setting method of "Communication Detail Settings", refer to the following.

☞ 2.6.1 Setting communication interface (Communication settings)

(4) Address

Specifies the head No. of the device data to be read/written.
The address notated in hexadecimal is converted to a 4-digit ASCII code (Hex) and transmitted from the upper digit.
For details of the device range that can be accessed, refer to the following.

☞ 2.4 Device Data Area

(5) Bit pattern

Specifies the pattern of the bits to change.
The address notated in hexadecimal is converted to a 2-digit ASCII code (Hex) and transmitted from the upper digit.

☞ ■ Message format (3) Multi-point write in bit units (3) command (w/out station No.), multi-point write in bit units (D) command (w/ station No.)

(6) Write specification

Specifies how to change the data of the specified address by bit pattern.
(Setting range: 0 to 3)
Data notated in decimal is converted to a 1-digit ASCII code (Hex) and transmitted.

☞ ■ Message format (3) Multi-point write in bit units (3) command (w/out station No.), multi-point write in bit units (D) command (w/ station No.)

(7) Number of bytes

Specifies the number of bytes of the device data to be batch read/written.(Setting range: 0 to FF$_H$)
The address notated in hexadecimal is converted to a 2-digit ASCII code (Hex) and transmitted from the upper digit.

(8) Number of points

Specifies the number of device data to be written to multiple points in bit units.(Setting range: 0 to 70)
The address notated in decimal is converted to a 2-digit ASCII code (Hex) and transmitted from the upper digit.

(9) Year, month, day, hour, minute, second and day of the week data

Specifies year, month, day, hour, minute, second, and day of the week to be read/set to the GOT clock data.
The address notated in decimal is converted to a 2-digit ASCII code (Hex) and transmitted from the upper digit.

☞ ■ (5) Read clock data (6) command (w/out station No.), read clock data (G) command (w/station No.)

☞ ■ (6) Set clock data (5) command (w/out station No.), set clock data (F) command (w/station No.)

(10) Data

Specifies the data to read from/write to the specified device data.(word unit)
The address notated in hexadecimal is converted to a 4-digit ASCII code (Hex) and transmitted from the upper digit.

(11) Write data

Specifies the data to write to the specified device data.
The address notated in hexadecimal is converted to a 2-digit ASCII code (Hex) and transmitted from the upper digit.

(12) Sum check code (for format 15: GOT-F900 series microcomputer connection (format 2) only)

The sum check code is obtained by converting the lower 1 byte (8 bits) of the result (sum), after having added the sum check target data as binary data, to 2-digit ASCII code (Hex).


STX
Command
Address
Number of points
ETX
Sum Check
R D 0 1 0 0 0 2 B C
02H 52H 44H 30H 31H 30H 30H 30H 32H 03H 42H 43H
(H) (L) (H) – – (L) (H) (L) (H) (L)
Sum check is performed in this range.
52H + 44H + 30H + 31H + 30H + 30H + 30H + 32H + 03H = 1BCH

■ Message format

(1) Batch read (0) command (w/out station No.), batch read (A) command (w/station No.)

(a) When reading a word device

The following shows an example of reading four bytes of virtual devices R100 to R101 from the GOT at station No.15.

(Assuming R100=3D21H, R101=3604H are stored.)



Item	Message format
Request message (host → GOT)	(format 14: GOT-F900 Series microcomputer connection (format 1))

STX	Com-mand	Station No.		Address				Number of bytes		CR
	A	1	5	0	0	C	8	0	4	
02H	41H	31H	35H	30H	30H	43H	38H	30H	34H	0DH
		(H)	(L)	(H)	–	–	(L)	(H)	(L)	

(format 15: GOT-F900 Series microcomputer connection (format 2))

STX	Com-mand	Station No.		Address				Number of bytes		ETX	Sum Check	
	A	1	5	0	0	C	8	0	4		E	9
02H	41H	31H	35H	30H	30H	43H	38H	30H	34H	03H	45H	39H
		(H)	(L)	(H)	–	–	(L)	(H)	(L)		(H)	(L)

Sum check is performed in this range.

Response message during normal communication (GOT → host)	(format 14: GOT-F900 Series microcomputer connection (format 1))

STX	Data 1 (R100 upper)		Data 2 (R100 lower)		Data 3 (R101 upper)		Data 4 (R101 lower)		CR
	3	D	2	1	3	6	0	4	
02H	33H	44H	32H	31H	33H	36H	30H	34H	0DH
	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	

(format 15: GOT-F900 Series microcomputer connection (format 2))

STX	Data 1 (R100 upper)		Data 2 (R100 lower)		Data 3 (R101 upper)		Data 4 (R101 lower)		ETX	Sum Check	
	3	D	2	1	3	6	0	4		A	A
02H	33H	44H	32H	31H	33H	36H	30H	34H	03H	41H	41H
	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)		(H)	(L)

Sum check is performed in this range.

Response message during faulty communication (GOT → host)

NAK
15H

(b) When reading a bit device

The following shows an example of reading four bytes of the virtual devices M0 to M31.
(Assuming M0="1" and M31="1" are stored.



<table>
<tr><th>Item</th><th>Message format</th></tr>
<tr><td>Request message
(host → GOT)</td><td>(format 14: GOT-F900 Series microcomputer connection (format 1))
 
(format 15: GOT-F900 Series microcomputer connection (format 2))
  </td></tr>
<tr><td>Response message during normal communication
(GOT → host)</td><td>(format 14: GOT-F900 Series microcomputer connection (format 1))
 
(format 15: GOT-F900 Series microcomputer connection (format 2))
  </td></tr>
<tr><td>Response message during faulty communication
(GOT → host)</td><td>  </td></tr>
</table>

(2) Batch write (1) command (w/out station No.), batch write (B) command (w/station No.)

(a) When writing to a word device

The following shows an example of writing "0064H" and "0065H" to virtual devices R100 and R101 on the GOT at station No.15.



Before execution　　After execution

Item	Message format
Request message (host → GOT)	(format 14: GOT-F900 Series microcomputer connection (format 1))

STX	Com-mand	Station No.		Address				Number of bytes		Following*1	CR
	B	1	5	0	0	C	8	0	4		
02H	42H	31H	35H	30H	30H	43H	38H	30H	34H		0DH
		(H)	(L)	(H)	–	–	(L)	(H)	(L)		

(format 15: GOT-F900 Series microcomputer connection (format 2))

STX	Com-mand	Station No.		Address				Number of bytes		Following*1	ETX	Sum Check	
	B	1	5	0	0	C	8	0	4			9	1
02H	42H	31H	35H	30H	30H	43H	38H	30H	34H		03H	39H	31H
		(H)	(L)	(H)	–	–	(L)	(H)	(L)			(H)	(L)

Sum check is performed in this range.

*1

Data 1 (R100 upper)		Data 2 (R100 lower)		Data 3 (R101 upper)		Data 4 (R101 lower)	
0	0	6	4	0	0	6	5
30H	30H	36H	34H	30H	30H	36H	35H
(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)

Item	Message format
Response message during normal communication (GOT → host)	ACK (06H)
Response message during faulty communication (GOT → host)	NAK (15H)

(b) When writing to a bit device

The following shows an example of writing "1"s to virtual devices M0 and M31 on the GOT at station No.15.



Item	Message format
Request message (host → GOT)	(format 14: GOT-F900 Series microcomputer connection (format 1))

STX	Com-mand	Station No.		Address				Number of bytes		Following*1	CR
	B	1	5	2	0	0	0	0	4		
02H	42H	31H (H)	35H (L)	32H (H)	30H –	30H –	30H (L)	30H (H)	34H (L)		0DH

(format 15: GOT-F900 Series microcomputer connection (format 2))

STX	Com-mand	Station No.		Address				Byte Number		Following*1	ETX	Sum Check	
	B	1	5	2	0	0	0	0	4			5	A
02H	42H	31H (H)	35H (L)	32H (H)	30H –	30H –	30H (L)	30H (H)	34H (L)		03H	35H (H)	41H (L)

Sum check is performed in this range.

*1

Data 1 (M7 to 0)		Data 2 (M15 to 8)		Data 3 (M23 to 16)		Data 4 (M31 to 24)	
0	1	0	0	0	0	8	0
30H (H)	31H (L)	30H (H)	30H (L)	30H (H)	30H (L)	38H (H)	30H (L)

0 0 0 0 0 0 0 1 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1 0 0 0 0 0 0 0

M M M M M M M M M M M M M M M M M M M M M M M M M M M M M M M M
7 6 5 4 3 2 1 0 1 1 1 1 1 1 1 9 8 2 2 2 2 2 1 1 1 1 3 3 2 2 2 2 2 2
5 4 3 2 1 0 3 2 1 0 9 8 7 6 1 0 9 8 7 6 5 4

Item	Message format
Response message during normal communication (GOT → host)	ACK: 06H
Response message during faulty communication (GOT → host)	NAK: 15H

(3) Multi-point write in bit units (3) command (w/out station No.), multi-point write in bit units (D) command (w/ station No.)
The following shows an example of turning OFF the virtual device M31 and turning ON the virtual device M2038 on the GOT at station No.31.

Item	Message format
Request message (host → GOT)	(format 14: GOT-F900 Series microcomputer connection (format 1))

STX	Com-mand	Station No.		Number of points		Following*1	CR
	D	3	1	0	2		
02H	44H	33H (H)	31H (L)	30H (H)	32H (L)		0DH

(format 15: GOT-F900 Series microcomputer connection (format 2))

STX	Com-mand	Station No.		Number of points		Following *1	ETX	Sum check	
	D	3	1	0	2			E	C
02H	44H	33H (H)	31H (L)	30H (H)	32H (L)		03H	45H (H)	43H (L)

Sum check is performed in this range.

*1

Write specification 1	Address1				Bit pattern1		Write specification 2	Address2				Bit pattern2	
1	2	0	0	3	8	0	0	2	0	F	E	4	0
31H	32H (H)	30H –	30H –	33H (L)	38H (H)	30H (L)	30H	32H (H)	30H –	46 –	45H (L)	34H (H)	30H (L)

*2 (write specification1=1)

	MM3	MM2	MM1	MM0	MM7	MM6	MM5	MM4
Source data bit pattern	1	0	1	0	1	0	1	0
	1	0	0	0	0	0	0	0
Result	0	0	1	0	1	0	1	0

*2 (write specification2=0)

	MM23	MM22	MM21	MM20	MM27	MM26	MM25	MM24
Source data bit pattern	1	0	1	0	1	0	1	0
	0	1	0	0	0	0	0	0
Result	1	1	1	0	1	0	1	0

Item	Message format
Response message during normal communication (GOT → host)	ACK: 06H
Response message during faulty communication (GOT → host)	NAK: 15H

*2 The write specification specifies how the data of the specified address is changed in the bit pattern.

Write specification	Function	Description	Action example	
0	ON specification	Bits set to "1" by the bit pattern are turned ON.	Original data Bit pattern Result	1010 1100 1110
1	OFF specification	Bits set to "1" by the bit pattern are turned OFF.	Original data Bit pattern Result	1010 1100 0010
2	Invert specification	Bits set to "1" by the bit pattern are inverted.	Original data Bit pattern Result	1010 1100 0110
3	Write specification	The numerical values to write by the bit pattern are specified directly.	Original data Bit pattern Result	1010 1100 1100

(4) Fill command (4) (w/out station No.), fill command (E) (w/station No.)
The following shows an example of writing "16"s to virtual devices R50 to R100 on the GOT at station No.27.



Before execution After execution

Item	Message format
Request message (host → GOT)	(format 14: GOT-F900 Series microcomputer connection (format 1))

STX	Com-mand	Station No.		Start address				End address				Write Data		CR
	E	2	7	0	0	6	4	0	0	C	9	1	6	
02H	45H	32H (H)	37H (L)	30H (H)	30H –	36H –	34H (L)	30H (H)	30H –	43H –	39H (L)	31H (H)	36H (L)	0DH

(format 15: GOT-F900 Series microcomputer connection (format 2))

STX	Com-mand	Station No.		Start address				End address				Write Data		ETX	Sum Check	
	E	2	7	0	0	6	4	0	0	C	9	1	6		B	E
02H	45H	32H (H)	37H (L)	30H (H)	30H –	36H –	34H (L)	30H (H)	30H –	43H –	39H (L)	31H (H)	36H (L)	03H	42H (H)	45H (L)

Sum check is performed in this range.

Response message during normal communication (GOT → host)	ACK: 06H
Response message during faulty communication (GOT → host)	NAK: 15H

POINT

(1) Start address/end address specification conditions
Specify addresses so that the start address is the same or less than the end address.
Error response occurs in the following cases:
- The address to specify has the start address greater than the end address.
- Either of the start address or end address exceeds the device range that can be specified.

(2) Address specifying crossing over different devices
The start address and end address can be specified crossing over different devices.

(5) Read clock data (6) command (w/out station No.), read clock data (G) command (w/station No.)
The following shows an example of reading the clock data of GOT at station No.27.
(Assuming that the clock data of GOT has been set to "2004, June 1, 18:46:49, Tuesday".)



<table>
<tr><th>Item</th><th>Message format</th></tr>
<tr><td>Request message
(host → GOT)</td><td>(format 14: GOT-F900 Series microcomputer connection (format 1))
<table>
<tr><td>STX</td><td>Com-mand</td><td colspan="2">Station No.</td><td>CR</td></tr>
<tr><td></td><td>G</td><td>2</td><td>7</td><td></td></tr>
<tr><td>02H</td><td>47H</td><td>32H
(H)</td><td>37H
(L)</td><td>0DH</td></tr>
</table>
(format 15: GOT-F900 Series microcomputer connection (format 2))
<table>
<tr><td>STX</td><td>Com-mand</td><td colspan="2">Station No.</td><td>ETX</td><td colspan="2">Sum Check</td></tr>
<tr><td></td><td>G</td><td>2</td><td>7</td><td></td><td>B</td><td>3</td></tr>
<tr><td>02H</td><td>47H</td><td>32H
(H)</td><td>37H
(L)</td><td>03H</td><td>42H
(H)</td><td>33H
(L)</td></tr>
</table>
Sum check is performed in this range.</td></tr>
<tr><td>Response message during normal communication
(GOT → host)</td><td>(format 14: GOT-F900 Series microcomputer connection (format 1))
<table>
<tr><td>STX</td><td colspan="2">Year data</td><td colspan="2">Month data</td><td colspan="2">Day data</td><td colspan="2">Hour data</td><td colspan="2">Minute data</td><td colspan="2">Second data</td><td colspan="2">Day-of-week data</td><td>CR</td></tr>
<tr><td></td><td>0</td><td>4</td><td>0</td><td>6</td><td>0</td><td>1</td><td>1</td><td>8</td><td>4</td><td>6</td><td>4</td><td>9</td><td>0</td><td>2</td><td></td></tr>
<tr><td>02H</td><td>30H
(H)</td><td>34H
(L)</td><td>30H
(H)</td><td>36H
(L)</td><td>30H
(H)</td><td>31H
(L)</td><td>31H
(H)</td><td>38H
(L)</td><td>34H
(H)</td><td>36H
(L)</td><td>34H
(H)</td><td>39H
(L)</td><td>30H
(H)</td><td>32H
(L)</td><td>0DH</td></tr>
</table>
(format 15: GOT-F900 Series microcomputer connection (format 2))
<table>
<tr><td>STX</td><td colspan="2">Year data</td><td colspan="2">Month data</td><td colspan="2">Day data</td><td colspan="2">Hour data</td><td colspan="2">Minute data</td><td colspan="2">Second data</td><td colspan="2">Day-of-week data</td><td>ETX</td><td colspan="2">Sum Check</td></tr>
<tr><td></td><td>0</td><td>4</td><td>0</td><td>6</td><td>0</td><td>1</td><td>1</td><td>8</td><td>4</td><td>6</td><td>4</td><td>9</td><td>0</td><td>2</td><td></td><td>D</td><td>0</td></tr>
<tr><td>02H</td><td>30H
(H)</td><td>34H
(L)</td><td>30H
(H)</td><td>36H
(L)</td><td>30H
(H)</td><td>31H
(L)</td><td>31H
(H)</td><td>38H
(L)</td><td>34H
(H)</td><td>36H
(L)</td><td>34H
(H)</td><td>39H
(L)</td><td>30H
(H)</td><td>32H
(L)</td><td>03H</td><td>44H
(H)</td><td>30H
(L)</td></tr>
</table>
Sum check is performed in this range.</td></tr>
<tr><td>Response message during faulty communication
(GOT → host)</td><td>
<table>
<tr><td>NAK</td></tr>
<tr><td>15H</td></tr>
</table></td></tr>
</table>

(6) Set clock data (5) command (w/out station No.), set clock data (F) command (w/station No.)
The following shows an example of setting clock data of GOT at station No.27.
(Assuming the clock data of GOT is to be set to "2004, June 1, 18:46:49 Tuesday".)



After execution

<table>
<tr><th>Item</th><th>Message format</th></tr>
<tr><td>Request message
(host → GOT)</td><td>
(format 14: GOT-F900 Series microcomputer connection (format 1))
<table>
<tr><th>STX</th><th>Com-mand</th><th>Station No.</th><th>Year data</th><th>Month data</th><th>Day Data</th><th>Hour data</th><th>Minute data</th><th>Second data</th><th>Day-of-week data</th><th>CR</th></tr>
<tr><td></td><td>F</td><td>2 7</td><td>0 4</td><td>0 6</td><td>0 1</td><td>1 8</td><td>4 6</td><td>4 9</td><td>0 2</td><td></td></tr>
<tr><td>02H</td><td>46H</td><td>32H 37H
(H) (L)</td><td>30H 34H
(H) (L)</td><td>30H 36H
(H) (L)</td><td>30H 31H
(H) (L)</td><td>31H 38H
(H) (L)</td><td>34H 36H
(H) (L)</td><td>34H 39H
(H) (L)</td><td>30H 32H
(H) (L)</td><td>0DH</td></tr>
</table>
(format 15: GOT-F900 Series microcomputer connection (format 2))
<table>
<tr><th>STX</th><th>Com-mand</th><th>Station No.</th><th></th><th>ETX</th><th>Sum Check</th></tr>
<tr><td></td><td>F</td><td>2 7</td><td rowspan="2">Following*1</td><td></td><td>7 F</td></tr>
<tr><td>02H</td><td>46H</td><td>32H 37H
(H) (L)</td><td>03H</td><td>37H 46H
(H) (L)</td></tr>
</table>
Sum check is performed in this range.
*1
<table>
<tr><th>Year data</th><th>Month data</th><th>Day data</th><th>Hour data</th><th>Minute data</th><th>Second data</th><th>Day-of-week data</th></tr>
<tr><td>0 4</td><td>0 6</td><td>0 1</td><td>1 8</td><td>4 6</td><td>4 9</td><td>0 2</td></tr>
<tr><td>30H 34H
(H) (L)</td><td>30H 36H
(H) (L)</td><td>30H 31H
(H) (L)</td><td>31H 38H
(H) (L)</td><td>34H 36H
(H) (L)</td><td>34H 39H
(H) (L)</td><td>30H 32H
(H) (L)</td></tr>
</table>
</td></tr>
<tr><td>Response message during normal communication
(GOT → host)</td><td>
<table>
<tr><th>ACK</th></tr>
<tr><td>06H</td></tr>
</table>
</td></tr>
<tr><td>Response message during faulty communication
(GOT → host)</td><td>
<table>
<tr><th>NAK</th></tr>
<tr><td>15H</td></tr>
</table>
</td></tr>
</table>

POINT

When a wrong day of the week has been set by the clock data setting command

If a wrong day of the week is set by the clock data setting commands, the clock data will differ from the time displayed on the utility.

Example: When June 1, 2004 (Thursday) is set by the clock data setting command(the actual day of week is Tuesday),
Tuesday (TUE) will be displayed on the utility time display.

(7) In the case of interrupt outputs

The following shows an example of an interrupt output when data are written to the interrupt output devices (D13 and D14).

(Assuming that "3139H" is written to D13 and "AA55H" to D14.)

Example: When the number of interrupt data bytes is 2



Item	Message format
Interrupt output (GOT → host)	(1) When [Interrupt Data Byte] in "Communication Detail Settings" is set to "1 byte" Output value 1: 39H (2) When [Interrupt Data Byte] in "Communication Detail Settings" is set to "2 byte" Output value 1: 31H, Output value 2: 39H (3) When [Interrupt Data Byte] in "Communication Detail Settings" is set to "4 byte" Output value 1: AAH, Output value 2: 55H, Output value 3: 31H, Output value 4: 39H

POINT

Interrupt output

- To disable the interrupt output, turn ON SM52 (interrupt code output disable flag). (☞ 2.4.6 SM devices)
- To enable the interrupt output, set 8 bits to the data length at "Communication Detail Settings". (☞ 2.6.1 Setting communication interface (Communication settings))
- When "7 bits" is set, the MSB (8th bit) is ignored.(Example: FFH→7FH)

■ Error code list

When faulty, the error code is stored in SD2.
For details of error code stored in SD2, the error contents, cause and measures, refer to the following:

☞ 2.4.5 ■ Details and actions for errors (error codes) stored into SD2

When an error other than those to be stored in SD2 occurs, at faulty, only the NAK response is executed.

■ Precautions

(1) Batch reading/writing crossing over different devices
When using the batch read (0, A) or batch write (1, B) command, do not batch read/write crossing over different devices.
This will cause an error response.

2.6 GOT Side Settings

2.6.1 Setting communication interface (Communication settings)

■ Controller setting

Set the channel of the equipment to be connected to the GOT.



1. Select [Common] → [Controller Setting] from the menu.
2. The Controller Setting window is displayed. Select the channel to be used from the list menu.
3. Set the following items.
   - Manufacturer: Others
   - Controller Type:Computer
   - I/F: Interface to be used
   - Driver:Computer
4. The detailed setting is displayed after Manufacturer, Controller Type, I/F, and Driver are set.
   Make the settings according to the usage environment.
   ☞ 2.6.2 Communication detail settings

Click the [OK] button when settings are completed.

POINT

The settings of connecting equipment can be set and confirmed in [I/F Communication Setting]. For details, refer to the following.

☞ 1.1.2 I/F communication setting

2.6.2 Communication detail settings

Make the settings according to the usage environment.

Property	Value
Transmission Speed(BPS)	19200
Data Bit	7 bit
Stop Bit	1 bit
Parity	Even
Host Address	0
Format	1
Interrupt Data Byte(Byte)	1
Special Interrupt Code	No
Control Method	No
32bit Storage	LH Order

Item	Description	Range
Transmission Speed	Set this item when change the transmission speed used for communication with the connected equipment. (Default: 19200bps)	4800bps, 9600bps, 19200bps, 38400bps, 57600bps, 115200bps
Data Bit	Set this item when change the data length used for communication with the connected equipment. (Default: 7bits)	7bits/8bits
Stop Bit	Specify the stop bit length for communications. (Default: 1bit)	1bit/2bits
Parity	Specify whether or not to perform a parity check, and how it is performed during communication. (Default: Even)	None Even Odd
Host Address	Specify the host address (station No. of the PLC to which the GOT is connected) in the network of the GOT. (Default: 0)	0 to 31
Format	Select the communication format. (Default: 1)	1 to 15
Interrupt Data Byte	Specify the number of bytes of interrupt data. (Default: 1byte)	1byte, 2byte, 4byte
Special Interrupt Code	Set whether or not to output the special interrupt code. (Default: No)	Yes or No
Control Method	Set this item when selecting the XON/XOFF control for the control method. (Default: No)	XON/XOFF, No
32bit Storage	Select the steps to store two words (32-bit data). (Default: LH Order)	LH Order/ HL Order

POINT

(1) Special Interrupt Code
The following shows the compatibility between the special interrupt codes and the event types.

Special Interrupt Code (Hex)	Event type
20H	Base Screen*1 and Overlap Window*1 Output when the screens are switched according to the change in the switching device values assigned to 1/2. *1: Base Screen or Overlap Window 1/2 switches independently without being interlocked. (Example of output) When all the switching device values assigned to the Base Screen and Overlap Window1/2 are changed, 3 special interrupt codes are output.
21H	Output when Numerical/ASCII Input is completed.
22H	Output when Recipe data transfer (read-out, write-in) is completed.
23H	Output when Bar code, RFID data has been imported into GOT

(2) Communication detail setting when connecting multiple GOTs
For the following items, set the same settings to the n+1th GOT interface as the CH No.1 of n-th GOT.
- Transmission Speed
- Data Bit
- Stop Bit
- Parity

Set each [Host Address] for the GOT.

(3) Communication interface setting by the Utility
The communication interface setting can be changed on the Utility's [Communication setting] after writing [Communication Settings] of project data.
For details on the Utility, refer to the following manual.

☞ User's Manual of GOT used.

(4) Precedence in communication settings
When settings are made by GT Designer3 or the Utility, the latest setting is effective.

2.7 System Configuration Examples

The following shows a system configuration example in the case of the microcomputer connection (serial).

■ System configuration

The system configuration example illustrated below is explained in this section.



IBM-PC/AT-compatible PC
(Microsoft® Visual C++® Ver.6.0)

■ Communication settings on GOT side and monitor screen settings

(1) Transmission settings

Set the transmission settings of the GOT.
The transmission settings in the microcomputer connection (serial) are made at [Detail Setting] on GT Designer3.

2.6.2 Communication detail settings

Setting item	Setting details
Baud rate	38400bps
Data bit	8bits
Stop bit	1bit
Parity	Even
Interrupt Data Byte	1 byte
Host address (0 to 31)	0
Format	1
Special Interrupt Code	None
Control Method	None
32bit Storage	LH Order

(2) Monitor screen settings

The following shows the monitor screen settings in this system configuration example.

(a) Common settings

Set D20 to the screen switching device (base screen).


GT Designer3 (GOT2000) Untitled1
Project Edit Search/Replace View Screen Common Figure Object Communication Tools Window Help
GOT Type Setting...
GOT Environmental Setting
GOT Setup
Screen Switching/Windows...
Language Switching...

1. Select [Common] → [GOT Environmental Setting] → [Screen Switching/Window] to display [Environment Setup] on GT Designer3.



2. Set D20 to the screen switching device (base screen).

(b) Monitor screen image
Create the following screens by GT Designer3.

Base screen 1



1. Numerical display
By setting this with the numerical display, the device value of D21 can be monitored.
The device value is incremented only while [Sample Screen 1] is displayed.

2. Switch 1
This is the screen switching switch to [Sample Screen 2].
Touching this changes the base screen to [Sample Screen 2].

Base screen 2



3. Bit lamp
The device status of D22.b0 is displayed as a lamp.

4. Switch 2
This is an alternate switch for changing the state of D22.b0.

5. Switch 3
This is the screen switching switch to [Sample Screen 1]. Touching this changes the base screen to [Sample Screen 1].

Numerical display

No.	Basic Settings				
	Device/Style				
	Device	Data Type	Format	Number Size	Digits
1.	D21	Unsigned BIN16	Signed Decimal	Arbitrary	4

Touch switch

No.	Basic Settings					
	Action					
	Action	Next Screen	Device	Data Type	Setting Value	Action Type
2.	Screen Switching Base	Fixed Screen No.2	—	—	—	—
	Word	—	D13	Signed BIN16	Constant 1	—
4.	Bit	—	D22.b0	—	—	Alternate
5.	Screen Switching Base	Fixed Screen No.1	—	—	—	—
	Word	—	D13	Signed BIN16	Constant 255	—

Bit lamp

No.	Basic Settings			
	Device/Style			
	Lamp Type	Device	Shape	Shape Attribute
3.	Bit	D22.b0	Arbitrary	Arbitrary

■ Outline of system operation

The following describes the processing on the host side, display/processing on the GOT side, and data transfer packets.
(Assuming that host side programs use programs which perform the processing on host side shown below.)

Processing	Processing on host side		Packet used for data transfer	Display/ Processing on GOT side
Initial processing	Opens the port.		——	——
	Writes "1" to the screen switching device (D20).		Screen 1 batch switching Write packet*1	Displays base screen 1.
	Receives a response from the GOT.		——	——
	Judges whether or not there is an error in the response from the GOT.		——	——
	Writes an initial value to device (D21).		Batch numerical value display write packet*2	Displays "0" on the numerical value display on base screen 1.
Reception of response/ interrupt from GOT	When receiving a response to writing to device (D21) from the GOT	Issues the current value acquisition request to device (D21).	Batch numerical value display read packet*3	Increments the numerical value displayed on base screen 1. (The host side repeats the processing on the left as long as base screen 1 is displayed.))
	When receiving a response to reading of device (D21) from the GOT	Creates the next device value (D21).	——	
		Calculates the sum check of the send packet.	——	
		Issues the update request of device (D21).	Batch numerical value display write packet*2	
	When receiving an interrupt requesting the base screen switching from 1 to 2	Sets the state of the base screen to base screen 2.	Interrupt receive *6	Touch touch switch 1 to switch to base screen 2.Notify the host by an interrupt.
	When receiving an interrupt requesting the base screen switching from 2 to 1	Sets the state of the base screen to base screen 1.	Interrupt receive packet*6 *6	Touch touch switch 3 to switch to base screen 1.Notify the host by an interrupt.
End processing (only when receiving an error response)	Close the port.		——	——

*1 Displays the send packet structure of the screen 1 batch switching write packet.

STX	Command		Address				Number of points		Data 1 (D20)				ETX	Sum Check	
	W	D	0	0	2	0	0	1	0	0	0	1		8	2
02H	57H	44H	30H	30H	32H	30H	30H	31H	30H	30H	30H	31H	03H	38H	32H
	(H)	(L)	(H)	–	–	(L)	(H)	(L)	(H)	–	–	(L)		(H)	(L)

Sum check is performed in this range.

*2 Displays the send packet structure of the numerical value display batch write packet.

STX	Command		Address				Number of points		Data 1 (D21)				ETX	Sum check	
	W	D	0	0	2	1	0	1	(any value)					(Changes according to data section.)	
02H	57H	44H	30H	30H	32H	31H	30H	31H					03H		
	(H)	(L)	(H)	–	–	(L)	(H)	(L)	(H)	–	–	(L)		(H)	(L)

Sum check is performed in this range.

*3 Displays the send packet structure of the numerical value display batch read packet.

STX	Command		Address				Number of points		ETX	Sum Check	
	R	D	0	0	2	1	0	1		B	D
02H	52H	44H	30H	30H	32H	31H	30H	31H	03H	42H	44H
	(H)	(L)	(H)	–	–	(L)	(H)	(L)		(H)	(L)

Sum check is performed in this range.

*4 Displays the receive packet structure of the batch write response packet.

When normally operated

ACK
06H

When an error occurred

NAK
15H

*5 Displays the receive packet structure of the batch read response packet.

When normally operated

STX	Data				ETX	Sum check	
	(any data)					(Changes according to data section.)	
02H					03H		
	(H)	–	–	(L)		(H)	(L)

Sum check is performed in this range.

When an error occurred

NAK
15H

*6 Displays the receive packet structure of the interrupt receive packet.

Output value
Interrupt data (value of D13)

2.8 Device Range that Can Be Set

The device ranges of controller that can be used for GOT are as follows.
Note that the device ranges in the following tables are the maximum values that can be set in GT Designer3.
The device specifications of controllers may differ depending on the models, even though belonging to the same series.
Please make the setting according to the specifications of the controller actually used.
When a non-existent device or a device number outside the range is set, other objects with correct device settings may not be monitored.

■ Setting item



Item	Description
Device	Set the device name, device number, and bit number. The bit number can be set only when specifying the bit of word device.
Information	Displays the device type and setting range which are selected in [Device].

	Device name	Setting range			Device No. representation
Bit device	Internal relay (M)	M0	to	M2047	Decimal
	Special relay (SM)	SM0	to	SM63	
	Latch relay (L)	L0	to	L2047	
	Word device bit	Specified bit of the following word devices			
Word device	Data register (D)	D0	to	D4095	Decimal
	Link special register (SD)	SD0	to	SD15	
	File register (R)	R0	to	R4095	
	Bit device word	Converting bit devices into word			

2.9 Precautions

■ GOT clock control

The settings of "time adjusting" or "time broadcast" made on the GOT will be disabled on the PLC. Use the dedicated commands to set or read out the clock data of microcomputer.


MEMO

3

MICROCOMPUTER CONNECTION (ETHERNET)

3.1 Microcomputer connection (Ethernet) . . . . . 3 - 2
3.2 System Configuration . . . . . 3 - 2
3.3 Device Data Area . . . . . 3 - 3
3.4 Message Formats . . . . . 3 - 16
3.5 GOT Side Settings . . . . . 3 - 69
3.6 System Configuration Examples . . . . . 3 - 71
3.7 Device Range that Can Be Set . . . . . 3 - 72
3.8 Precautions . . . . . 3 - 73

3. MICROCOMPUTER CONNECTION (ETHERNET)

3.1 Microcomputer connection (Ethernet)

The "microcomputer connection (Ethernet)" is a function by which data can be written or read from a PC, microcomputer board, PLC, etc. (hereinafter referred to as "host") to virtual devices of the GOT after connecting the host to the GOT with the Ethernet.
Interrupt output is also available from the GOT to the host.

For the flow of the data processing, such as reading or writing data and interrupt output, refer to the following.

2.1 Microcomputer Connection (Serial)

3.2 System Configuration

3.2.1 For the microcomputer connection (Ethernet)





Host	Connection cable		GOT		Number of connectable equipment
Communication Type	Cable model	Maximum segment length*2	Option device	Model	
Ethernet	Twisted pair cable*1 • 100BASE-TX Shielded twisted pair cable (STP) or unshielded twisted pair cable (UTP) of category 5 or higher • 10BASE-T Shielded twisted pair cable (STP) or unshielded twisted pair cable (UTP) of category 3 or higher	100m	- (Built into GOT)	GT27 GT23 GS	Unlimited number of GOTs for 1 host

*1 The destination connected with the twisted pair cable varies with the configuration of the applicable Ethernet network system.
Connect to the Ethernet module, hub, transceiver or other system equipment corresponding to the applicable Ethernet network system.
Use cables, connectors, and hubs that meet the IEEE802.3 10BASE-T/100BASE-TX standard.

*2 A length between a hub and a node.
The maximum distance differs depending on the Ethernet device to be used.
The following shows the number of the connectable nodes when a repeater hub is used.
• 10BASE-T: Max. 4 nodes for a cascade connection (500m)
• 100BASE-TX: Max. 2 nodes for a cascade connection (205m)
When switching hubs are used, the cascade connection between the switching hubs has no logical limit for the number of cascades.
For the limit, contact the switching hub manufacturer.

3.3 Device Data Area

The following shows a list of virtual devices inside the GOT available in the microcomputer connection (Ethernet), and the address specification values for each data format.

The address specification of the virtual devices differs depending on the data format.*1

Virtual device*2			Address specification value				Refer to
Name	Device range (decimal)	Device type	Format 1, 2	Format 3, 4	Format 5	Format 6 to 9	
D	0 to 4095	Word	0 to 4095	8000 to 9FFFH	0000 to 0FFFH	D0 to 4095	3.3.1
R	0 to 4095	Word	4096 to 8191	0000 to 1FFFH	1000 to 1FFFH	R0 to 4095	3.3.2
L	0 to 2047	Bit	8192 to 8319	A000 to A0FFH	2000 to 207FH	L0 to 2047	3.3.3
M	0 to 2047	Bit	8320 to 8447	2000 to 20FFH	2080 to 20FFH	M0 to 2047	3.3.4
SD	0 to 15	Word	8448 to 8463	2100 to 211FH (3000 to 300DH)*3	2100 to 210FH	SD0 to 15	3.3.5
SM	0 to 63	Bit	8464 to 8467	2200 to 2207H	2110 to 2113H	SM0 to 63	3.3.6

*1 For the address specification method for each data format, refer to the following.

3.4 Message Formats

- Formats 1, 2 : GOT-A900 Series microcomputer connection
- Formats 3, 4 : GOT-F900 series microcomputer connection
- Formats 5 : Digital Electronics Corporation's memory link method
- Formats 6, 7 : 4E frame
- Formats 8, 9 : QnA compatible 3E frame

*2 When reusing GOT900 Series project data

- GOT-A900 Series virtual devices (D0 to 2047)
  Can be used as they are without changing the assignments.
- GOT-F900 Series virtual devices
  Since some of the assigned virtual device values differ as indicated below, change the assignment using device batch edit of GT Designer3.
  Refer to the following manual for device batch edit of GT Designer3.

GT Designer3 (GOT2000) Help

GOT1000 Series virtual devices	GOT-F900 Series virtual devices
D0 to 2047	—
D2048 to 4095	—
R0 to 4095	D0 to 4095
L0 to 2047	—
M0 to 2047	M0 to 2047
SD0 to 15	D8000 to 8015 GD0 to 6
SM0 to 63	M8000 to 8063

*3 Access to SD3 to 9 can also be made by the specification of the addresses (3000 to 300DH) of GD0 to 6 on the GOT-F900 Series.

POINT

Values of virtual devices inside the GOT

When the GOT is turned OFF or reset, values are cleared to their defaults (bit devices: OFF, word devices: 0).
Values are held in the memory when project data are written to the GOT.

3.3.1 D devices

The D devices are word devices into which GOT communication errors, clock data or other information are stored. The user can also store data using the user area.

■ List of D devices

The following lists the D devices (virtual devices inside the GOT).

<table>
<tr><th>Address</th><th>Description</th><th>Set side</th></tr>
<tr><td>D0 to 2</td><td>Unused</td><td>—</td></tr>
<tr><td>D3</td><td>Communication error status
Stores the communication error details of GOT.
 

• b4 to 6 turn ON when an SIO error occurs, and turn OFF when an request message from the host is received successfully after the error occurrence.
• b7 turns ON about 3 seconds after the host side DTR becomes OFF, and turns OFF when transmission is performed successfully to the host after the error occurrence.</td><td rowspan="4">System</td></tr>
<tr><td>D4</td><td>Clock data (year)
 
</td></tr>
<tr><td>D5</td><td>Clock data (month)
 
</td></tr>
<tr><td>D6</td><td>Clock data (day)
 
</td></tr>
</table>

(Continued to next page)

(From previous page)

Address	Description	Set side
D7	Clock data (hour) 	System
D8	Clock data (minute) 	
D9	Clock data (second) 	
D10	Clock data (day of week)*1 	
D11, D12	Unused	—

(Continued to next page)

*1 If a wrong day of the week is set by the clock data setting commands, the clock data will differ from the time displayed on the utility.
Example: When October 1, 2009 (Tuesday) is set by the clock data setting command (the actual day of the week is Thursday), "02" is stored to D10 although Thursday (THU) will be displayed on the utility time display.

(From previous page)

<table>
<tr><th>Address</th><th>Description</th><th>Set side</th></tr>
<tr><td>D13</td><td>Interrupt output
When data are written to D13 and D14 from a GOT touch switch, for example, the data of D13 and D14 are transmitted (interrupt output) to the host side.*1*2
The data amount (number of bytes) to be interrupt-output is set at "Interrupt Data Byte" in "Communication Detail Settings".
(☞ 3.5.1 Setting communication interface (Communication settings))
• Output value when 1 is set to "Interrupt Data Byte" in "Communication Detail Settings"
 
</td><td rowspan="2">User</td></tr>
<tr><td>D14</td><td>• Output value when 2 is set to "Interrupt Data Byte" in "Communication Detail Settings"
 

• Output value when 4 is set to "Interrupt Data Byte" in "Communication Detail Settings
(1) When setting the LH order to [32bit Storage] for the communication detail settings
 

(2) When setting the HL order to [32bit Storage] for the communication detail settings
 
</td></tr>
<tr><td>D15 to 19</td><td>Unused</td><td>—</td></tr>
<tr><td>D20 to 2031</td><td>User area</td><td>User</td></tr>
<tr><td>D2032 to 2034</td><td>Unused</td><td>—</td></tr>
<tr><td>D2035</td><td>1-second binary counter
The counter is incremented at 1-second intervals after the GOT is turned ON.
(The time elapsed after GOT is turned ON is stored in 1-second units.)
Data are stored in binary format.</td><td>System</td></tr>
<tr><td>D2036 to 4095</td><td>User area</td><td>User</td></tr>
</table>

*1 After writing data, the interrupt data is output within a period of 1 to 10ms.
*2 When data are written to D13 and D14 from the host side, interrupt output is not performed.

POINT

(1) The side where virtual devices are set
System : Set on the system side.
User : Set on the user side (by sending request messages from host or using the touch switches, etc. on the GOT).

(2) Interrupt output (D13, D14)
- To disable the interrupt output, turn ON SM52 (interrupt code output disable flag). (☞ 3.3.6 SM devices)
- To enable the interrupt output, set 8 bits to the data length at "Communication Detail Settings". (☞ 3.5.1 Setting communication interface (Communication settings))
- When "7 bits" is set, the MSB (8th bit) is ignored. (Example: FFH→7FH)

■ Differences in address specifications by data format

The address specification of devices varies depending on the data format.*1
The following shows the address specification values for each data format.

Address	Address specification value				
	Format 1, 2	Format 3, 4		Format 5	Format 6 to 9
D0	0	8000H 8001H	8000H (Upper 8 bits) 8001H (Lower 8 bits)	0000H	D0
D1	1	8002H 8003H	8002H (Upper 8 bits) 8003H (Lower 8 bits)	0001H	D1
:	:	:		:	:
D4095	4095	9FFEH 9FFFH	9FFEH (Upper 8 bits) 9FFFH (Lower 8 bits)	0FFFH	D4095

*1 For the address specification method for each data format, refer to the following.

3.4 Message Formats

- Formats 1, 2 : GOT-A900 Series microcomputer connection
- Formats 3, 4 : GOT-F900 series microcomputer connection
- Formats 5 : Digital Electronics Corporation's memory link method
- Formats 6, 7 : 4E frame
- Formats 8, 9 : QnA compatible 3E frame

3.3.2 R devices

The R devices are word devices into which user data are stored.
All of these devices can be used as a user area.

■ List of R devices and differences in address specification by data format

The following shows the R devices (virtual devices inside the GOT).

The address specification values different depending on the data format are also given below.*1

Address	Address specification value				
	Format 1, 2	Format 3, 4		Format 5	Format 6 to 9
D0	4096	0000H 0001H	0000H (Upper 8 bits) 0001H (Lower 8 bits)	1000H	R0
D1	4097	0002H 0003H	0002H (Upper 8 bits) 0003H (Lower 8 bits)	1001H	R1
:	:	:		:	:
D4095	8191	1FFEH 1FFFH	1FFEH (Upper 8 bits) 1FFFH (Lower 8 bits)	1FFFH	R4095

*1 For the address specification method for each data format, refer to the following.

3.4 Message Formats

- Formats 1, 2 : GOT-A900 Series microcomputer connection
- Formats 3, 4 : GOT-F900 series microcomputer connection
- Formats 5 : Digital Electronics Corporation's memory link method
- Formats 6, 7 : 4E frame
- Formats 8, 9 : QnA compatible 3E frame

3.3.3 L devices

The L devices are bit devices into which user data are stored.
All of these devices can be used as a user area.

■ List of L devices and differences in address specification by data format

The following shows the L devices (virtual devices inside the GOT).

The address specification values different depending on the data format are also given below.*1

Address								Address specification value				
									Format3, 4			
b7	b6	b5	b4	b3	b2	b1	b0	Format 1, 2	When GS580.b8, GS581.b8, GS582.b8, or GS583.b8 is ON	When GS580.b8, GS581.b8, GS582.b8, or GS583.b8 is OFF	Format 5	Format 6 to 9
L7	L6	L5	L4	L3	L2	L1	L0	8192	A000H	A001H	2000H	Same as address column on left*2
L15	L14	L13	L12	L11	L10	L9	L8		A001H	A000H		
L23	L22	L21	L20	L19	L18	L17	L16	8193	A002H	A003H	2001H	
L31	L30	L29	L28	L27	L26	L25	L24		A003H	A002H		
:								:	:	:	:	
L2039	L2038	L2037	L2036	L2035	L2034	L2033	L2032	8319	A0FEH	A0FFH	207FH	
L2047	L2046	L2045	L2044	L2043	L2042	L2041	L2040		A0FFH	A0FEH		

*1 For the address specification method for each data format, refer to the following.

3.4 Message Formats

- Formats 1, 2 : GOT-A900 Series microcomputer connection
- Formats 3, 4 : GOT-F900 series microcomputer connection
- Formats 5 : Digital Electronics Corporation's memory link method
- Formats 6, 7 : 4E frame
- Formats 8, 9 : QnA compatible 3E frame

*2 For reading or writing data in word units, specify the addresses in 16-point units. (Example: L0, L16, L32, etc.)

3.3.4 M devices

The M devices are bit devices into which user data are stored.
All of these devices can be used as a user area.

■ List of M devices and differences in address specification by data format

The following shows the M devices (virtual devices inside the GOT).

The address specification values different depending on the data format are also given below.*1

Address								Address specification value				
									Format3, 4			
b7	b6	b5	b4	b3	b2	b1	b0	Format 1, 2	When GS580.b8, GS581.b8, GS582.b8, or GS583.b8 is ON	When GS580.b8, GS581.b8, GS582.b8, or GS583.b8 is OFF	Format 5	Format 6 to 9
M7	M6	M5	M4	M3	M2	M1	M0	8320	2000H	2001H	2080H	Same as address column on left*2
M15	M14	M13	M12	M11	M10	M9	M8		2001H	2000H		
M23	M22	M21	M20	M19	M18	M17	M16	8321	2002H	2003H	2081H	
M31	M30	M29	M28	M27	M26	M25	M24		2003H	2002H		
:								:	:	:	:	
M2039	M2038	M2037	M2036	M2035	M2034	M2033	M2032	8447	20FEH	20FFH	20FFH	
M2047	M2046	M2045	M2044	M2043	M2042	M2041	M2040		20FFH	20FEH		

*1 For the address specification method for each data format, refer to the following.

3.4 Message Formats

- Formats 1, 2 : GOT-A900 Series microcomputer connection
- Formats 3, 4 : GOT-F900 series microcomputer connection
- Formats 5 : Digital Electronics Corporation's memory link method
- Formats 6, 7 : 4E frame
- Formats 8, 9 : QnA compatible 3E frame

*2 For reading or writing data in word units, specify the addresses in 16-point units.(Example: M0, M16, M32, and others)

3.3.5 SD devices

The SD devices are word devices into which GOT communication errors (error codes), clock data and other information are stored.

■ List of SD devices

The following lists the SD devices (virtual devices inside the GOT).

Address	Description	Set side
SD0 SD1	100ms counter (32bits) The counter is incremented at 100ms intervals after GOT is turned ON. (The time elapsed after GOT is turned ON is stored in 100ms units.) (1) When setting the LH order to [32bit Storage] for the communication detail settings The lower and upper bits are stored in SD0 and SD1 respectively. (2) When setting the HL order to [32bit Storage] for the communication detail settings The upper and lower bits are stored in SD0 and SD1 respectively. 	System
SD2*1	Communication error status An error data (error code) occurred during communication is stored. •Host Address (Communication error that occurred on the request destination GOT) 0: No error 1: Parity error 2: Framing error 3: Overrun error 4: Communication message error 5: Command error 6: Clock data setting error •Other station (Communication error that occurred on another GOT when multiple GOTs are connected) 101: Parity error 102: Framing error 103: Overrun error 104: Communication message error 105: Timeout error (No station of the specified address exists.) 106: Multiple units not connectable 107: Clock data setting error	
SD3	Clock data (second) Second data of 00 to 59 is stored.	
SD4	Clock data (minute) Minute data of 00 to 59 is stored.	
SD5	Clock data (hour) Hour data of 00 to 23 is stored.	
SD6	Clock data (day) Day data of 00 to 31 is stored.	
SD7	Clock data (month) Month data of 01 to 12 is stored.	

(Continued to next page)

*1 For details and corrective actions for the errors (error codes) that are stored into SD2, refer to the following:

■ Details and actions for errors (error codes) stored into SD2

(From previous page)

Address	Description	Set side
SD8	Clock data (year) 4-digit year data is stored.	System
SD9	Clock data (day of week)*1 Day-of-the-week data is stored. 0: Sunday 1: Monday 2: Tuesday 3: Wednesday 4: Thursday 5: Friday 6: Saturday	
SD10 to 15	Unused	—

*1 If a wrong day of the week is set by the clock data setting commands, the clock data will differ from the time displayed on the utility.
Example: When October 1, 2009 (Tuesday) is set by the clock data setting command (the actual day of the week is Thursday), "2" is stored to SD9 although Thursday (THU) will be displayed on the utility time display.

POINT

The side where virtual devices are set

System : Set on the system side.
User : Set on the user side (by sending request messages from host or using the touch switches, etc. on the GOT).

■ Details and actions for errors (error codes) stored into SD2

Error code	Description	Action
0	No error	—
1, 101	Parity error The parity bit does not match.	• Check the communication cable and communication module attachment. • Check the settings of "Communication Detail Settings". • Match the GOT and host transmission settings.
2, 102	Framing error The data bit and/or stop bit are not correct.	
3, 103	Overrun error The next data was transmitted from the host before GOT completes the processing of the data received.	• Check the settings of "Communication Detail Settings". • Decrease the transmission speed.
4, 104	Communication message error EXT/CR could not be found before the upper limit of the receive buffer was exceeded.	• Check the communication cable and communication module attachment. • Check the settings of "Communication Detail Settings". • Review the contents of the message to transmit.
5	Command error An unsupported command was used.	• Review the contents of the message to transmit. • Check the commands in the message. (☞ 3.4.2 List of commands)
105	Timeout error There is no response from the GOT, or the station of the specified address does not exist.	• Check the communication cable and communication module attachment. • Check the settings of "Communication Detail Settings". • Review the contents of the message to transmit.
106	Multiple units not connectable The RS-232 port is occupied.	• Check the communication cable and communication module attachment. • Check the settings of "Communication Detail Settings". • Check to see if the RS-232 port is occupied.
6, 107	Clock data setting error The setting value of the clock data has error.	• Review the contents of the message to transmit. • Check whether the non-existent data is set (e.g. setting "07" at the day of the week) as clock data.

■ Differences in address specifications by data format

The address specification of devices varies depending on the data format.*1
The following shows the address specification values for each data format.

Address	Address specification value			
	Formats 1, 2	Formats 3, 4*2	Formats 5	Formats 6 to 9
SD0	8448	2100H (Upper 8 bits) / 2101H (Lower 8 bits)	2100H	SD0
SD1	8449	2102H (Upper 8 bits) / 2103H (Lower 8 bits)	2101H	SD1
SD2	8450	2104H (Upper 8 bits) / 2105H (Lower 8 bits)	2102H	SD2
SD3	8451	2106H (3000H) (Upper 8 bits) / 2107H (3001H) (Lower 8 bits)	2103H	SD3
SD4	8452	2108H (3002H) (Upper 8 bits) / 2109H (3003H) (Lower 8 bits)	2104H	SD4
SD5	8453	210AH (3004H) (Upper 8 bits) / 210BH (3005H) (Lower 8 bits)	2105H	SD5
SD6	8454	210CH (3006H) (Upper 8 bits) / 210DH (3007H) (Lower 8 bits)	2106H	SD6
SD7	8455	210EH (3008H) (Upper 8 bits) / 210FH (3009H) (Lower 8 bits)	2107H	SD7
SD8	8456	2110H (300AH) (Upper 8 bits) / 2111H (300BH) (Lower 8 bits)	2108H	SD8
SD9	8457	2112H (300CH) (Upper 8 bits) / 2113H (300DH) (Lower 8 bits)	2109H	SD9

*1 For the address specification method for each data format, refer to the following.

3.4 Message Formats

- Formats 1, 2 : GOT-A900 Series microcomputer connection
- Formats 3, 4 : GOT-F900 series microcomputer connection
- Formats 5 : Digital Electronics Corporation's memory link method
- Formats 6, 7 : 4E frame
- Formats 8, 9 : QnA compatible 3E frame

*2 SD3 to 9 correspond to GD0 to 6 on the GOT-F900 Series.
Access to SD3 to 9 can be also made by the specification of the addresses (3000 to 300DH) of GD0 to 6 on the GOT-F900 Series.

3.3.6 SM devices

The SM devices are bit devices into which interrupt outputs and clock data that turn ON/OFF at 1-second cycles.

■ List of SM devices

The following shows the SM devices (virtual devices inside the GOT).

<table>
<tr><th>Address</th><th>Description</th><th>Set side</th></tr>
<tr><td>SM0 to 49</td><td>Interrupt output
When the ON/OFF state of SM0 to 49 is changed by a touch switch on the GOT, for example, the interrupt codes shown below are transmitted (interrupt output) to the host side.*1*2
The data amount (number of bytes) to be interrupt-output is set at "Interrupt Data Byte" in "Communication Detail Settings". (☞ 3.5.1 Setting communication interface (Communication settings))
<table>
<tr><th>Address</th><th>Event type</th><th>Interrupt code</th></tr>
<tr><td rowspan="2">SM0</td><td>Changed from OFF to ON</td><td>50H</td></tr>
<tr><td>Changed from ON to OFF</td><td>51H</td></tr>
<tr><td rowspan="2">SM1</td><td>Changed from OFF to ON</td><td>52H</td></tr>
<tr><td>Changed from ON to OFF</td><td>53H</td></tr>
<tr><td rowspan="2">SM2</td><td>Changed from OFF to ON</td><td>54H</td></tr>
<tr><td>Changed from ON to OFF</td><td>55H</td></tr>
<tr><td>≀</td><td>≀</td><td>≀</td></tr>
<tr><td rowspan="2">SM48</td><td>Changed from OFF to ON</td><td>B0H</td></tr>
<tr><td>Changed from ON to OFF</td><td>B1H</td></tr>
<tr><td rowspan="2">SM49</td><td>Changed from OFF to ON</td><td>B2H</td></tr>
<tr><td>Changed from ON to OFF</td><td>B3H</td></tr>
</table></td><td>User</td></tr>
<tr><td>SM50</td><td>1-second cycle clock
Turns ON/OFF at a 1-second cycle.
</td><td rowspan="2">System</td></tr>
<tr><td>SM51</td><td>2-second cycle clock
Turns ON/OFF at a 2-second cycle.
</td></tr>
<tr><td>SM52</td><td>Interrupt code output disable flag
Enables or disables the output of the interrupt code.
OFF : Interrupt code output enabled ON : Interrupt code output disabled
When set to disable the interrupt code output, no interrupt data are output to the host.
(Relevant devices: D13, D14, SM0 to 49)</td><td>User</td></tr>
<tr><td>SM53 to 63</td><td>Unused</td><td>—</td></tr>
</table>

*1 After the ON/OFF state is changed, the interrupt data is output within a period of 1 to 10 ms.

*2 When the ON/OFF state of SM0 to 49 is changed from the host side, interrupt output is not performed.

POINT

(1) The side where virtual devices are set

System : Set on the system side.

User : Set on the user side (by sending request messages from host or using the touch switches, etc. on the GOT).

(2) Interrupt outputs (SM0 to 49)

- To disable the interrupt output, turn ON SM52 (interrupt code output disable flag). (☞ 3.3.6 SM devices)
- To enable the interrupt output, set 8 bits to the data length at "Communication Detail Settings". (☞ 3.5.1 Setting communication interface (Communication settings))
- When "7 bits" is set, the MSB (8th bit) is ignored. (Example: FFH→7FH)

■ Differences in address specifications by data format

The address specification of devices varies depending on the data format.[*1]
The following shows the address specification values for each data format.

Address								Address specification value				
b7	b6	b5	b4	b3	b2	b1	b0	Format 1, 2	Format3, 4		Format 5	Format 6 to 9
									When GS580.b8, GS581.b8, GS582.b8, or GS583.b8 is ON	When GS580.b8, GS581.b8, GS582.b8, or GS583.b8 is OFF		
SM7	SM6	SM5	SM4	SM3	SM2	SM1	SM0	8464	2200H	2201H	2110H	*2*3
SM15	SM14	SM13	SM12	SM11	SM10	SM9	SM8		2201H	2200H		
SM23	SM22	SM21	SM20	SM19	SM18	SM17	SM16	8465	2202H	2203H	2111H	
SM31	SM30	SM29	SM28	SM27	SM26	SM25	SM24		2203H	2202H		
SM39	SM38	SM37	SM36	SM35	SM34	SM33	SM32	8466	2204H	2205H	2112H	
SM47	SM46	SM45	SM44	SM43	SM42	SM41	SM40		2205H	2204H		
Unused			SM52	SM51	SM50	SM49	SM48	8467	2206H	2207H	2113H	
Unused								-	-	-		

*1 For the address specification method for each data format, refer to the following.

3.4 Message Formats

- Formats 1, 2 : GOT-A900 Series microcomputer connection
- Formats 3, 4 : GOT-F900 series microcomputer connection
- Formats 5 : Digital Electronics Corporation's memory link method
- Formats 6, 7 : 4E frame
- Formats 8, 9 : QnA compatible 3E frame

*2 In formats 6, 7, values are specified within a range of SM0 to 52.

*3 For reading or writing data in word units, specify the addresses in 16-point units. (Example: SM0, SM16, SM32, etc.)

3.4 Message Formats

This section describes the format of messages that can be used in the microcomputer connection (Ethernet).

3.4.1 Data format type and application

■ Data format type and application

Communication is possible using any of the data formats shown below.

(1) Formats 1, 2 (GOT-A900 Series microcomputer connection)
This is the same message format as when a microcomputer connection is established with the GOT-A900 series.

Type	Name	Description	Refer to
Format 1	GOT-A900 series microcomputer connection (ASCII)	This format is used when the GOT is connected to the host in a 1:1 connection. The data format is ASCII.	☞ 3.4.3
Format 2	GOT-A900 series microcomputer connection (Binary)	This format is used when the GOT is connected to the host in a 1:1 connection. The data format is Binary.	

(2) Formats 3, 4 (GOT-F900 series microcomputer connection)
This is the compatible message format with when a microcomputer connection is established with the GOT-F900 Series.

Type	Name	Description	Refer to
Format 3	GOT-F900 series microcomputer connection (ASCII)	This format is used when the GOT is connected to the host in a 1:1 connection. The data format is ASCII.	☞ 3.4.4
Format 4	GOT-F900 series microcomputer connection (Binary)	This format is used when the GOT is connected to the host in a 1:1 connection. The data format is Binary.	

(3) Format 5 (Digital Electronics Corporation's memory link method)
This is the compatible message format with the protocol of the Digital Electronics Corporation's memory link method.

Type	Name	Description	Refer to
Format 5	Digital Electronics Corporation's memory link method	This is the basic format of the Digital Electronics Corporation's memory link method.	☞ 3.4.5

(4) Formats 6, 7 (4E frame)
This is the compatible message format with when a communication is performed using the MC protocol of Q/QnA Series serial communication module.

Type	Name	Description	Refer to
Format 6	4E frame (ASCII)	This is the basic format of the MC protocols. The data format is ASCII.	☞ 3.4.6
Format 7	4E frame (Binary)	This is the basic format of the MC protocols. The data format is Binary.	

(5) Formats 8, 9 (QnA compatible 3E frame)
This is the compatible message format with when a communication is performed using the MC protocol of Q/QnA Series serial communication module.

Type	Name	Description	Refer to
Format 8	QnA compatible 3E frame (ASCII)	This is the basic format of the MC protocols. The data format is ASCII.	☞ 3.4.7
Format 9	QnA compatible 3E frame (Binary)	This is the basic format of the MC protocols. The data format is Binary.	

■ How to set data format

Set the data format at [Detail setting] in GT Designer3.
For details of the data format setting method, refer to the following.

☞ 3.5.1 Setting communication interface (Communication settings)

3.4.2 List of commands

The following shows the list of commands available in each data format.

■ List of commands for formats 1, 2 (GOT-A900 Series microcomputer connection)

Command		Command name	Description	Max. number of points processed
Symbol	ASCII code			
RD	52H 44H	Batch read in word units	Reads bit devices in 16-point units.	64 words (1024 points)
			Reads word devices in 1-point units.	64 points
WD	57H 44H	Batch write in word units	Writes to bit devices in 16-point units.	64 words (1024 points)
			Writes to word devices in 1-point units.	64 points
RR	52H 52H	Random read in word units*1	Reads multiple different bit devices in 16-point units.	64 words (1024 points)
			Reads multiple different word devices in 1-point units.	64 points
RW	52H 57H	Random write in word units*1	Writes to multiple different word devices in 16-point units.	64 words (1024 points)
			Writes to multiple different word devices in 1-point units.	64 points
TR	54H 52H	Read clock data	Reads the clock data of the GOT.	—
TS	54H 53H	Set clock data	Sets the clock data of the GOT.	—

*1 Mixed specification of bit devices and word devices is also possible.

■ List of commands for formats 3, 4 (GOT-F900 series microcomputer connection)

Command		Command name	Description	Max. number of points processed
Symbol	ASCII code			
0	30H	Batch read (w/out station No.)	Reads bit devices in byte units.	255bytes (2040 points)
			Reads word devices in byte units.	255bytes (127 points)
A	41H	Batch read (w/ station No.)	Reads bit devices in byte units.	255bytes (2040 points)
			Reads word devices in byte units.	255bytes (127 points)
1	31H	Batch write (w/out station No.)	Writes to bit devices in byte units.	255bytes (2040 points)
			Writes to word devices in byte units.	255bytes (127 points)
B	42H	Batch write (w/ station No.)	Writes to bit devices in byte units.	255bytes (2040 points)
			Writes to word devices in byte units.	255bytes (127 points)
3	33H	Multi-point write in bit units (w/out station No.)	Writes bit patterns (bit ON/OFF, inversion, direct specification) in 1-point units (8 bits for 1 point) to a specified device.	70bytes (560 points)
D	44H	Multi-point write in bit units (w/ station No.)		
4	34H	Fill command (w/out station No.)	Writes the same value to a range of specified devices.	—
E	45H	Fill command (w/ station No.)		
5	35H	Set clock data (w/out station No.)	Sets the clock data of the GOT.	—
F	46H	Set clock data (w/ station No.)		
6	36H	Read clock data (w/out station No.)	Reads the clock data of the GOT.	—
G	47H	Read clock data (w/ station No.)		

■ List of commands for formats 5 (Digital Electronics Corporation's memory link method)

Command		Command name	Description	Max. number of points processed
Symbol	ASCII code			
R	52H	Batch read in word units	Reads bit devices in 16-point units.	64 words (1024 points)
			Reads word devices in 1-point units.	64 points
W	57H	Batch write in word units	Writes to bit devices in 16-point units.	64 words (1024 points)
			Writes to word devices in 1-point units.	64 points
I	49H	Interrupt inquiry	Issues an interrupt inquiry.	—

■ List of commands for formats 6, 7 (4E frame), formats 8, 9 (QnA compatible 3E frame)

Command	Sub-command	Command name	Description	Max. number of points processed
0401	0001	Batch read in bit units	Reads bit devices in 1-point units.	64 points
0401	0000	Batch read in word units	Reads bit devices in 16-point units.*3	64 words (1024 points)
			Reads word devices in 1-point units.	64 points
1401	0001	Batch write in bit units	Writes to bit devices in 1-point units.	64 points
1401	0000	Batch write in word units	Writes to bit devices in 16-point units.*3	64 words (1024 points)
			Writes to word devices in 1-point units.	64 points
0403	0000	Random read in word units*1	Reads multiple different bit devices in 16-point and 32-point units.*3	64 words (1024 points)
			Reads multiple different word devices in 1-point and 2-point units.	64 points
1402	0001	Random write in bit units	Writes to multiple different bit devices in 1-point units.	64 points
1402	0000	Random write in word units*1	Writes to multiple different bit devices in 16-point and 32-point units.*3	64 words (1024 points)
			Writes to multiple different word devices in 1-point and 2-point units.	64 points
0406	0000	Multiple block batch read	Reads multiple blocks. A bit device (16 bits for 1 point) or a word device (1 word for 1 point) is regarded as one block.*3	64 points
1406	0000	Multiple block batch write	Writes multiple blocks. A bit device (16 bits for 1 point) or a word device (1 word for 1 point) is regarded as one block.*3	64 points
1901*2	0000	Read clock data	Reads the clock data of the GOT.	—
0901*2	0000	Set clock data	Sets the clock data of the GOT.	—

*1 Mixed specification of bit devices and word devices is also possible.
*2 This is a dedicated command of GOT for the microcomputer connection.
*3 Specifies the address of bit devices in 16-point units. (Example: M0, M16, M32, and others)

3.4.3 Formats 1, 2 (GOT-A900 Series microcomputer connection)

■ Basic format of data communication

Item	Message format
Request message (host → GOT)	
Response message during normal communication (GOT → host)	(1) During processing of read commands  (2) During processing of write commands 
Response message during faulty communication (GOT → host)	
During interrupt output	

*1 Set the number of interrupt data bytes at [Detail setting] in GT Designer3.
For the setting of the number of interrupt data bytes, refer to the following.

3.5.1 Setting communication interface (Communication settings)

■ Details of data items in message format

POINT

Data code during communication

Communication of the format 1 is performed in ASCII code. (excluding interrupt output)
Communication of the format 2 is performed in Binary code.

(1) Control codes

Symbol	ASCII code	Description
EOT	04H	End of Transmission
ENQ	05H	Enquiry (start of enquiry)
NAK	15H	Negative ACK (error response)
ACK	06H	Acknowledge (write completion response)
LF	0AH	Line Feed
CL	0CH	Clear
CR	0DH	Carriage Return

(2) Command

Specifies the contents to access from the host to GOT.
The command is converted to a 2-digit ASCII code (Hex) and transmitted from the upper digit.
For details of the commands that can be used, refer to the following.

☞ 3.4.2 List of commands

(3) Address

Specifies the head No. of the device data to be read/written.
In the format 1, the address notated in decimal is converted to a 4-digit ASCII code (Hex) and transmitted from the upper digit.
In the format 2, the address notated in decimal is converted to a 2-digit Binary code (binary) and transmitted from the upper digit.
For details of the device range that can be accessed, refer to the following.

☞ 3.3 Device Data Area

(4) Number of points

Specifies the number of device data to be read/written. (Setting range: 1 to 64)
In the format 1, the address notated in decimal is converted to a 2-digit ASCII code (Hex) and transmitted from the upper digit.
In the format 2, the address notated in decimal is converted to a 1-digit Binary code (binary) and transmitted.

(5) Year, month, day, hour, minute, second and day of the week data

Specifies year, month, day, hour, minute, second, and day of the week to be read/set to the GOT clock data.
In the format 1, the address notated in decimal is converted to a 2-digit ASCII code (Hex) and transmitted from the upper digit.
In the format 2, the address notated in decimal is converted to a 1-digit Binary code (binary) and transmitted.

☞ ■ Message format (5) Read clock data (TR) command

☞ ■ Message format (6) Set clock data (TS) command

(6) Data

Specifies the data to read from/write to the specified device data.(word unit)
In the format 1, the address notated in hexadecimal is converted to a 4-digit ASCII code (Hex) and transmitted from the upper digit.
In the format 2, the address notated in hexadecimal is converted to a 2-digit Binary code (binary) and transmitted from the upper digit.

(7) Error code

This is the response message at faulty communication appended with error contents. Error code is transmitted in 1 byte.
For the error codes, refer to the following.

☞ ■ Error code list

■ Message Formats

(1) Batch read in word units (RD) command

(a) When reading a word device

The following shows an example of reading the two points of the virtual devices D100 and D101.
(Assuming D100=0102H, D101=0304H are stored.)



Item	Message format
Request message (host → GOT)	(format 1: GOT-A900 Series microcomputer connection (ASCII)) Command: R (52H) D (44H); Address: 0 (30H) 1 (31H) 0 (30H) 0 (30H); Number of points: 0 (30H) 2 (32H) (format 2: GOT-A900 Series microcomputer connection (Binary)) Command: R D; Address: 00H 64H; Number of points: 02H
Response message during normal communication (GOT → host)	(format 1: GOT-A900 Series microcomputer connection (ASCII)) Data 1 (D100): 0 (30H) 1 (31H) 0 (30H) 2 (32H); Data 2 (D101): 0 (30H) 3 (33H) 0 (30H) 4 (34H) (format 2: GOT-A900 Series microcomputer connection (Binary)) Data 1 (D100): 01H 02H; Data 2 (D101): 03H 04H
Response message during faulty communication (GOT → host)	NAK: 15H; Error code: 06H The above is a case where the sum check error (06H) has occurred.

(b) When reading a bit device

The following shows an example of reading the two points of the virtual devices M0 to M31.
(Assuming M0="1" and M31="1" are stored.)



<table>
<tr><th>Item</th><th>Message format</th></tr>
<tr><td>Request message
(host → GOT)</td><td>
(format 1: GOT-A900 Series microcomputer connection (ASCII))
<table>
<tr><th colspan="2">Command</th><th colspan="4">Address</th><th colspan="2">Number of points</th></tr>
<tr><td>R</td><td>D</td><td>8</td><td>3</td><td>2</td><td>0</td><td>0</td><td>2</td></tr>
<tr><td>52H</td><td>44H</td><td>38H</td><td>33H</td><td>32H</td><td>30H</td><td>30H</td><td>32H</td></tr>
<tr><td>(H)</td><td>(L)</td><td>(H)</td><td>–</td><td>–</td><td>(L)</td><td>(H)</td><td>(L)</td></tr>
</table>
(format 2: GOT-A900 Series microcomputer connection (Binary))
<table>
<tr><th colspan="2">Command</th><th colspan="2">Address</th><th>Number of points</th></tr>
<tr><td>R</td><td>D</td><td>83H</td><td>20H</td><td>02H</td></tr>
</table>
</td></tr>
<tr><td>Response message during normal communication
(GOT → host)</td><td>
(format 1: GOT-A900 Series microcomputer connection (ASCII))
<table>
<tr><th colspan="4">Data 1 (M15 to 0)</th><th colspan="4">Data 2 (M31 to 16)</th></tr>
<tr><td>0</td><td>0</td><td>0</td><td>1</td><td>8</td><td>0</td><td>0</td><td>0</td></tr>
<tr><td>30H</td><td>30H</td><td>30H</td><td>31H</td><td>38H</td><td>30H</td><td>30H</td><td>30H</td></tr>
<tr><td>(H)</td><td>–</td><td>–</td><td>(L)</td><td>(H)</td><td>–</td><td>–</td><td>(L)</td></tr>
</table>


(format 2: GOT-A900 Series microcomputer connection (Binary))
<table>
<tr><th colspan="2">Data 1 (M15 to 0)</th><th colspan="2">Data 2 (M31 to 16)</th></tr>
<tr><td>00H</td><td>01H</td><td>80H</td><td>00H</td></tr>
</table>

</td></tr>
<tr><td>Response message during faulty communication
(GOT → host)</td><td>
<table>
<tr><th>NAK</th><th>Error code</th></tr>
<tr><td>15H</td><td>06H</td></tr>
</table>
The above is a case where the sum check error (06H) has occurred.
</td></tr>
</table>

(2) Batch write in word units (WD) command

(a) When writing to a word device

The following shows as example of writing "0064H"and "0065H"to virtual devices D100 and D101.



Before execution　　After execution

Item	Message format
Request message (host → GOT)	(format 1: GOT-A900 Series microcomputer connection (ASCII)) Command: W D (57H 44H (H) (L)) / Address: 0 1 0 0 (30H 31H 30H 30H (H) — — (L)) / Number of points: 0 2 (30H 32H (H) (L)) / Data 1(D100): 0 0 6 4 (30H 30H 36H 34H (H) — — (L)) / Data 2 (D101): 0 0 6 5 (30H 30H 36H 35H (H) — — (L)) (format 2: GOT-A900 Series microcomputer connection (Binary)) Command: W D / Address: 00H 64H / Number of points: 02H / Data1 (D100): 00H 64H / Data 2 (D101): 00H 65H
Response message during normal communication (GOT → host)	ACK: 06H
Response message during faulty communication (GOT → host)	NAK: 15H / Error code: 06H The above is a case where the sum check error (06H) has occurred.

(b) When writing to a bit device

The following shows an example of writing "1"s to virtual devices M0 and M31.



Item	Message format
Request message (host → GOT)	(format 1: GOT-A900 Series microcomputer connection (ASCII))

Command		Address				Number of points		Data 1 (M15 to 0)				Data 2 (M31 to 16)			
W	D	8	3	2	0	0	2	0	0	0	1	8	0	0	0
57H	44H	38H	33H	32H	30H	30H	32H	30H	30H	30H	31H	38H	30H	30H	30H
(H)	(L)	(H)	–	–	(L)	(H)	(L)	(H)	–	–	(L)	(H)	–	–	(L)



(format 2: GOT-A900 Series microcomputer connection (Binary))

Command		Address		Number of points	Data 1 (M15 to 0)		Data 2 (M31 to 16)	
W	D	20H	80H	02H	00H	01H	80H	00H



Item	Message format
Response message during normal communication (GOT → host)	ACK: 06H
Response message during faulty communication (GOT → host)	NAK: 15H, Error code: 06H The above is a case where the sum check error (06H) has occurred.

(3) Random read in word units (RR) command

The following shows an example of reading the two points of the virtual devices D100 and M0 to M15.
(Assuming D100=0064H, M0=1are stored.)



<table>
<tr><th>Item</th><th>Message format</th></tr>
<tr><td>Request message
(host → GOT)</td><td>(format 1: GOT-A900 Series microcomputer connection (ASCII))
<table><tr><th colspan="2">Command</th><th colspan="4">Address 1</th><th colspan="4">Address 2</th></tr><tr><td>R</td><td>R</td><td>0</td><td>1</td><td>0</td><td>0</td><td>8</td><td>3</td><td>2</td><td>0</td></tr><tr><td>52H</td><td>52H</td><td>30H</td><td>31H</td><td>30H</td><td>30H</td><td>38H</td><td>33H</td><td>32H</td><td>30H</td></tr><tr><td>(H)</td><td>(L)</td><td>(H)</td><td>–</td><td>–</td><td>(L)</td><td>(H)</td><td>–</td><td>–</td><td>(L)</td></tr></table>
(format 2: GOT-A900 Series microcomputer connection (Binary))
<table><tr><th colspan="2">Command</th><th colspan="2">Address 1</th><th colspan="2">Address 2</th></tr><tr><td>R</td><td>R</td><td>00H</td><td>64H</td><td>20H</td><td>80H</td></tr></table></td></tr>
<tr><td>Response message during normal communication
(GOT → host)</td><td>(format 1: GOT-A900 Series microcomputer connection (ASCII))
<table><tr><th colspan="4">Data 1 (D100)</th><th colspan="4">Data 2 (M15 to 0)</th></tr><tr><td>0</td><td>0</td><td>6</td><td>4</td><td>0</td><td>0</td><td>0</td><td>1</td></tr><tr><td>30H</td><td>30H</td><td>36H</td><td>34H</td><td>30H</td><td>30H</td><td>30H</td><td>31H</td></tr><tr><td>(H)</td><td>–</td><td>–</td><td>(L)</td><td>(H)</td><td>–</td><td>–</td><td>(L)</td></tr></table>
<table><tr><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>1</td></tr><tr><td>M
1
5</td><td>M
1
4</td><td>M
1
3</td><td>M
1
2</td><td>M
1
1</td><td>M
1
0</td><td>M
9
9</td><td>M
8
8</td><td>M
7
7</td><td>M
6
6</td><td>M
5
5</td><td>M
4
4</td><td>M
3
3</td><td>M
2
2</td><td>M
1
1</td><td>M
0
0</td></tr></table>
(format 2: GOT-A900 Series microcomputer connection (Binary))
<table><tr><th colspan="2">Data 1
(D100)</th><th colspan="2">Data 2
(M15 to 0)</th></tr><tr><td>00H</td><td>64H</td><td>00H</td><td>01H</td></tr></table>
<table><tr><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>1</td></tr><tr><td>M
1
5</td><td>M
1
4</td><td>M
1
3</td><td>M
1
2</td><td>M
1
1</td><td>M
1
0</td><td>M
9
9</td><td>M
8
8</td><td>M
7
7</td><td>M
6
6</td><td>M
5
5</td><td>M
4
4</td><td>M
3
3</td><td>M
2
2</td><td>M
1
1</td><td>M
0
0</td></tr></table></td></tr>
<tr><td>Response message during faulty communication
(GOT → host)</td><td><table><tr><th>NAK</th><th>Error code</th></tr><tr><td>15H</td><td>06H</td></tr></table>
The above is a case where the sum check error (06H) has occurred.</td></tr>
</table>

(4) Random write in word units (RW) command

The following shows an example of writing "0064H" and "1" to virtual devices D100 and M0, respectively.



Item	Message format
Request message (host → GOT)	(format 1: GOT-A900 Series microcomputer connection (ASCII))

Command		Address 1				Data 1 (D100)				Address 2				Data 2 (M15 to 0)			
R	W	0	1	0	0	0	0	6	4	8	3	2	0	0	0	0	1
52H	57H	30H	31H	30H	30H	30H	30H	36H	34H	38H	33H	32H	30H	30H	30H	30H	31H
(H)	(L)	(H)	–	–	(L)	(H)	–	–	(L)	(H)	–	–	(L)	(H)	–	–	(L)

0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1
M	M	M	M	M	M	M	M	M	M	M	M	M	M	M	M
1	1	1	1	1	1	9	8	7	6	5	4	3	2	1	0
5	4	3	2	1	0										

(format 2: GOT-A900 Series microcomputer connection (Binary))

Command		Address 1		Data 1 (D100)		Address 2		Data 2 (M15 to 0)	
R	W	00H	64H	00H	00H	20H	80H	00H	01H

0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1
M	M	M	M	M	M	M	M	M	M	M	M	M	M	M	M
1	1	1	1	1	1	9	8	7	6	5	4	3	2	1	0
5	4	3	2	1	0										

Response message during normal communication (GOT → host)

ACK
06H

Response message during faulty communication (GOT → host)

NAK	Error code
15H	06H

The above is a case where the sum check error (06H) has occurred.

(5) Read clock data (TR) command

The following shows an example of reading the clock data of GOT.
(Assuming that the clock data of GOT has been set to "2009, October 1, 18:46:49, Thursday".)



<table>
<tr><th>Item</th><th>Message format</th></tr>
<tr><td>Request message
(host → GOT)</td><td>
<table>
<tr><th colspan="2">Command</th></tr>
<tr><td>T</td><td>R</td></tr>
<tr><td>54H</td><td>52H</td></tr>
<tr><td>(H)</td><td>(L)</td></tr>
</table>
</td></tr>
<tr><td>Response message during normal communication
(GOT → host)</td><td>
(format 1: GOT-A900 Series microcomputer connection (ASCII))
<table>
<tr><th colspan="2">Year data</th><th colspan="2">Month data</th><th colspan="2">Day data</th><th colspan="2">Hour data</th><th colspan="2">Minute data</th><th colspan="2">Second data</th><th colspan="2">Day-of-week data</th></tr>
<tr><td>0</td><td>9</td><td>1</td><td>0</td><td>0</td><td>1</td><td>1</td><td>8</td><td>4</td><td>6</td><td>4</td><td>9</td><td>0</td><td>4</td></tr>
<tr><td>30H</td><td>39H</td><td>31H</td><td>30H</td><td>30H</td><td>31H</td><td>31H</td><td>38H</td><td>34H</td><td>36H</td><td>34H</td><td>39H</td><td>30H</td><td>34H</td></tr>
<tr><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td></tr>
</table>
(format 2: GOT-A900 Series microcomputer connection (Binary))
<table>
<tr><th>Year data</th><th>Month data</th><th>Day data</th><th>Hour data</th><th>Minute data</th><th>Second data</th><th>Day-of-week data</th></tr>
<tr><td>09H</td><td>0AH</td><td>01H</td><td>12H</td><td>2EH</td><td>31H</td><td>04H</td></tr>
</table>
</td></tr>
<tr><td>Response message during faulty communication
(GOT → host)</td><td>
<table>
<tr><th>NAK</th><th>Error code</th></tr>
<tr><td>15H</td><td>06H</td></tr>
</table>
The above is a case where the sum check error (06H) has occurred.
</td></tr>
</table>

(6) Set clock data (TS) command

The following shows an example of setting the clock data of GOT.

(Assuming the clock data of GOT is to be set to "2009, October 1, 18:46:49 Thursday".)



After execution

<table>
<tr><th>Item</th><th>Message format</th></tr>
<tr><td>Request message
(host → GOT)</td><td>(format 1: GOT-A900 Series microcomputer connection (ASCII))
<table><tr><th>Command</th><th>Year data</th><th>Month data</th><th>Day data</th><th>Hour data</th><th>Minute data</th><th>Second data</th><th>Day-of-week data</th></tr><tr><td>T S</td><td>0 9</td><td>1 0</td><td>0 1</td><td>1 8</td><td>4 6</td><td>4 9</td><td>0 4</td></tr><tr><td>54H 53H
(H) (L)</td><td>30H 39H
(H) (L)</td><td>31H 30H
(H) (L)</td><td>30H 31H
(H) (L)</td><td>31H 38H
(H) (L)</td><td>34H 36H
(H) (L)</td><td>34H 39H
(H) (L)</td><td>30H 34H
(H) (L)</td></tr></table>(format 2: GOT-A900 Series microcomputer connection (Binary))
<table><tr><th>Command</th><th>Year data</th><th>Month data</th><th>Day data</th><th>Hour data</th><th>Minute data</th><th>Second data</th><th>Day-of-week data</th></tr><tr><td>T S</td><td>09H</td><td>0AH</td><td>01H</td><td>12H</td><td>2EH</td><td>31H</td><td>04H</td></tr></table></td></tr>
<tr><td>Response message during normal communication
(GOT → host)</td><td><table><tr><th>ACK</th></tr><tr><td>06H</td></tr></table></td></tr>
<tr><td>Response message during faulty communication
(GOT → host)</td><td><table><tr><th>NAK</th><th>Error code</th></tr><tr><td>15H</td><td>06H</td></tr></table>The above is a case where the sum check error (06H) has occurred.</td></tr>
</table>

POINT

When a wrong day of the week has been set by the clock data setting command

If a wrong day of the week is set by the clock data setting commands, the clock data will differ from the time displayed on the utility.

Example: When October 1, 2009 (Tuesday) is set by the clock data setting command (the actual day of the week is Thursday), Thursday (THU) will be displayed on the utility time display.

(7) In the case of interrupt outputs

The following shows an example of an interrupt output when data are written to the interrupt output devices (D13 and D14).

(Assuming that "3139H" is written to D13 and "AA55H" to D14.)

Example: When the number of interrupt data bytes is 2



Item	Message format
Interrupt output (GOT → host)	(1) When [Interrupt Data Byte] in "Communication Detail Settings" is set to "1 byte" Output value 1: 39H (2) When [Interrupt Data Byte] in "Communication Detail Settings" is set to "2 byte" Output value 1: 31H; Output value 2: 39H (3) When [Interrupt Data Byte] in "Communication Detail Settings" is set to "4 byte" Output value1: AAH; Output value2: 55H; Output value3: 31H; Output value4: 39H

POINT

Interrupt output

To disable the interrupt output, turn ON SM52 (interrupt code output disable flag).

(☞ 3.3.6 SM devices)

■ Error code list

The error contents (error code) are appended to the response message during faulty communication.
The following shows error code, error contents, cause, and measures.

Error code	Description	Action
10H	Command error An unsupported command was used.	• Review the contents of the message to transmit. • Check the commands in the message. (☞ 3.4.2 List of commands)
11H	Message length error The upper limit of the data length that can be received by the GOT has been exceeded.	• Review the contents of the message to transmit. • Check the data length of the message. (data length of the data section, etc.)
15H	Clock data setting error The setting value of the clock data has error.	• Review the contents of the message to transmit. • Check whether the non-existent data is set (e.g. setting "07" at the day of the week) as clock data.
7AH	Address error The start address of the read/write device is out of range.	• Review the contents of the message to transmit. • Check the devices that can be used and the device ranges. (☞ 3.3 Device Data Area)
7BH	Exceeded number of points error The read/write range exceeded the device range.	

■ Precautions

(1) Batch reading/writing crossing over different devices
When using the batch read (RD) or batch write (WD) command, do not batch read/write crossing over the different devices.
This will cause an error response.

(2) Storage order for 32-bit data
To use the program of GOT-A900 series with [32bit Order] setting to GOT1000 series, set [HL Order] to [32bit Order] for [Communication Detail Settings] when 32-bit data is set for GOT-A900 series.
With setting [LH Order], the order of upper bits and lower bits are reversed when the GOT displays and writes 32-bit data.

3.4.4 Formats 3, 4 (GOT-F900 series microcomputer connection)

■ Basic format of data communication

Item	Message format
Request message (host → GOT)	(1) w/out station No.  (2) w/station No. 
Response message during normal communication (GOT → host)	(1) During processing of read commands  (2) During processing of write commands 
Response message during faulty communication (GOT → host)	
During interrupt output	

*1 Set the number of interrupt data bytes at [Detail setting] in GT Designer3.
For the setting of the number of interrupt data bytes, refer to the following.

3.5.1 Setting communication interface (Communication settings)

■ Details of data items in message format

POINT

Data code during communication

Communication of the format 3 is performed in ASCII code. (excluding interrupt output)
Communication of the format 4 is performed in Binary code.

(1) Control codes

Symbol	ASCII code	Description
EOT	04H	End of Transmission
ENQ	05H	Enquiry (start of enquiry)
NAK	15H	Negative ACK (error response)
ACK	06H	Acknowledge (write completion response)
LF	0AH	Line Feed
CL	0CH	Clear
CR	0DH	Carriage Return

(2) Command

Specifies the contents to access from the host to GOT.
The command is converted to a 1-digit ASCII code (Hex) and transmitted.
For details of the commands that can be used, refer to the following.

☞ 3.4.2 List of commands

(3) Station No.

Station No. is used to identify the GOT with which the host communicates. (Setting range: 0 to 31)
In the format 3, the address notated in decimal is converted to a 2-digit ASCII code (Hex) and transmitted from the upper digit.
In the format 4, the address notated in decimal is converted to a 1-digit Binary code (binary) and transmitted.
The GOT processes only commands whose station No. matches the "Host Address (0 to 31)" set at "Communication Detail Settings". (The message of command whose station No. does not match is ignored.)
For setting method of "Communication Detail Settings", refer to the following.

☞ 3.5.1 Setting communication interface (Communication settings)

(4) Address

Specifies the head No. of the device data to be read/written.
In the format 3, the address notated in hexadecimal is converted to a 4-digit ASCII code (Hex) and transmitted from the upper digit.
In the format 4, the address notated in hexadecimal is converted to a 2-digit Binary code (binary) and transmitted from the upper digit.
For details of the device range that can be accessed, refer to the following.

☞ 3.3 Device Data Area

(5) Bit pattern

Specifies the pattern of the bits to change.
In the format 3, the address notated in hexadecimal is converted to a 2-digit ASCII code (Hex) and transmitted from the upper digit.
In the format 4, the address notated in hexadecimal is converted to a 1-digit Binary code (binary) and transmitted.

☞ ■ Message format (3) Multi-point write in bit units (3) command (w/out station No.), multi-point write in bit units (D) command (w/ station No.)

(6) Write specification

Specifies how to change the data of the specified address by bit pattern.
(Setting range: 0 to 3)
Data notated in decimal is converted to a 1-digit ASCII code (Hex) and transmitted.

☞ ■ Message format (3) Multi-point write in bit units (3) command (w/out station No.), multi-point write in bit units (D) command (w/ station No.)

(7) Number of bytes

Specifies the number of bytes of the device data to be batch read/written. (Setting range: 0 to FFH)
In the format 3, the address notated in hexadecimal is converted to a 2-digit ASCII code (Hex) and transmitted from the upper digit.
In the format 4, the address notated in hexadecimal is converted to a 1-digit Binary code (binary) and transmitted.

(8) Number of points

Specifies the number of device data to be written to multiple points in bit units. (Setting range: 0 to 70)
In the format 3, the address notated in decimal is converted to a 2-digit ASCII code (Hex) and transmitted from the upper digit.
In the format 4, the address notated in decimal is converted to a 1-digit Binary code (binary) and transmitted.

(9) Year, month, day, hour, minute, second and day of the week data

Specifies year, month, day, hour, minute, second, and day of the week to be read/set to the GOT clock data.
In the format 3, the address notated in decimal is converted to a 2-digit ASCII code (Hex) and transmitted from the upper digit.
In the format 4, the address notated in decimal is converted to a 1-digit Binary code (binary) and transmitted.

☞ ■ (5) Read clock data (6) command (w/out station No.), read clock data (G) command (w/station No.)

☞ ■ (6) Set clock data (5) command (w/out station No.), set clock data (F) command (w/station No.)

(10) Data

Specifies the data to read from/write to the specified device data. (word unit)
In the format 3, the address notated in hexadecimal is converted to a 4-digit ASCII code (Hex) and transmitted from the upper digit.
In the format 4, the address notated in hexadecimal is converted to a 2-digit Binary code (binary) and transmitted from the upper digit.

(11) Write data

Specifies the data to write to the specified device data.
The address notated in hexadecimal is converted to a 2-digit ASCII code (Hex) and transmitted from the upper digit.

■ Message format

(1) Batch read (0) command (w/out station No.), batch read (A) command (w/station No.)

(a) When reading a word device

The following shows an example of reading four bytes of virtual devices R100 to R101 from the GOT at station No.15.

(Assuming R100=3D21H, R101=3604H are stored.)



<table>
<tr><th>Item</th><th>Message format</th></tr>
<tr><td>Request message
(host → GOT)</td><td>(format 3: GOT-F900 Series microcomputer connection (ASCII))
<table><tr><th>Com-mand</th><th colspan="2">Station No.</th><th colspan="4">Address</th><th colspan="2">Number of bytes</th></tr><tr><td>A</td><td>1</td><td>5</td><td>0</td><td>0</td><td>C</td><td>8</td><td>0</td><td>4</td></tr><tr><td>41H</td><td>31H
(H)</td><td>35H
(L)</td><td>30H
(H)</td><td>30H
–</td><td>43H
–</td><td>38H
(L)</td><td>30H
(H)</td><td>34H
(L)</td></tr></table>
(format 4: GOT-F900 Series microcomputer connection (Binary))
<table><tr><th>Com-mand</th><th>Station No.</th><th colspan="2">Address</th><th>Number of bytes</th></tr><tr><td>A</td><td>0FH</td><td>00H</td><td>C8H</td><td>04H</td></tr></table></td></tr>
<tr><td>Response message during normal communication
(GOT → host)</td><td>(format 3: GOT-F900 Series microcomputer connection (ASCII))
<table><tr><th colspan="2">Data 1
(R100 upper)</th><th colspan="2">Data 2
(R100 lower)</th><th colspan="2">Data 3
(R101 upper)</th><th colspan="2">Data 4
(R101 lower)</th></tr><tr><td>3</td><td>D</td><td>2</td><td>1</td><td>3</td><td>6</td><td>0</td><td>4</td></tr><tr><td>33H
(H)</td><td>44H
(L)</td><td>32H
(H)</td><td>31H
(L)</td><td>33H
(H)</td><td>36H
(L)</td><td>30H
(H)</td><td>34H
(L)</td></tr></table>
(format 4: GOT-F900 Series microcomputer connection (Binary))
<table><tr><th>Data 1
(R100 upper)</th><th>Data 2
(R100 lower)</th><th>Data 3
(R101 upper)</th><th>Data 4
(R101 lower)</th></tr><tr><td>3DH</td><td>21H</td><td>36H</td><td>04H</td></tr></table></td></tr>
<tr><td>Response message during faulty communication
(GOT → host)</td><td><table><tr><th>NAK</th></tr><tr><td>15H</td></tr></table></td></tr>
</table>

(b) When reading a bit device

The following shows an example of reading four bytes of the virtual devices M0 to M31.
(Assuming M0="1" and M31="1" are stored.)



<table>
<tr><th>Item</th><th>Message format</th></tr>
<tr><td>Request message
(host → GOT)</td><td>(format 3: GOT-F900 Series microcomputer connection (ASCII))
<table><tr><th>Com-mand</th><th colspan="2">Station No.</th><th colspan="4">Address</th><th colspan="2">Number of bytes</th></tr><tr><td>A
41H</td><td>1
31H
(H)</td><td>5
35H
(L)</td><td>2
32H
(H)</td><td>0
30H
–</td><td>0
30H
–</td><td>0
30H
(L)</td><td>0
30H
(H)</td><td>4
34H
(L)</td></tr></table>
(format 4: GOT-F900 Series microcomputer connection (Binary))
<table><tr><th>Com-mand</th><th>Station No.</th><th colspan="2">Address</th><th>Number of bytes</th></tr><tr><td>A</td><td>0FH</td><td>20H</td><td>00H</td><td>04H</td></tr></table></td></tr>
<tr><td>Response message during normal communication
(GOT → host)</td><td>(format 3: GOT-F900 Series microcomputer connection (ASCII))
<table><tr><th>Data 1
(M7 to 0)</th><th>Data 2
(M15 to 8)</th><th>Data 3
(M23 to 16)</th><th>Data 4
(M31 to 24)</th></tr><tr><td>0 1
30H 31H
(H) (L)</td><td>0 0
30H 30H
(H) (L)</td><td>0 0
30H 30H
(H) (L)</td><td>8 0
38H 30H
(H) (L)</td></tr></table>
0 0 0 0 0 0 0 1 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
M M M M M M M M M M M M M M M M M M M M M M M M M M M M M M M M
7 6 5 4 3 2 1 0 1 1 1 1 1 1 1 9 8 2 2 2 2 1 1 1 1 1 3 3 2 2 2 2 2 2
5 4 3 2 1 0 3 2 1 0 9 8 7 6 1 0 9 8 7 6 5 4
(format 4: GOT-F900 Series microcomputer connection (Binary))
<table><tr><th>Data 1
(M7 to 0)</th><th>Data 2
(M15 to 8)</th><th>Data 3
(M23 to 16)</th><th>Data 4
(M31 to 24)</th></tr><tr><td>01H</td><td>00H</td><td>00H</td><td>80H</td></tr></table>
0 0 0 0 0 0 0 1 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
M M M M M M M M M M M M M M M M M M M M M M M M M M M M M M M M
7 6 5 4 3 2 1 0 1 1 1 1 1 1 1 9 8 2 2 2 2 1 1 1 1 1 3 3 2 2 2 2 2 2
5 4 3 2 1 0 3 2 1 0 9 8 7 6 1 0 9 8 7 6 5 4</td></tr>
<tr><td>Response message during faulty communication
(GOT → host)</td><td><table><tr><th>NAK</th></tr><tr><td>15H</td></tr></table></td></tr>
</table>

(2) Batch write (1) command (w/out station No.), batch write (B) command (w/station No.)

(a) When writing to a word device

The following shows an example of writing "3D21H" and "3604H" to virtual devices R100 and R101 on the GOT at station No.15.



Before execution　　After execution

Item	Message format
Request message (host → GOT)	(format 3: GOT-F900 Series microcomputer connection (ASCII))

Com-mand	Station No.		Address				Number of bytes		Following*1
B	1	5	0	0	C	8	0	4	
42H	31H	35H	30H	30H	43H	38H	30H	34H	
	(H)	(L)	(H)	–	–	(L)	(H)	(L)	

*1

Data 1 (R100 upper)		Data 2 (R100 lower)		Data 3 (R101 upper)		Data 4 (R101 lower)	
3	D	2	1	3	6	0	4
33H	44H	32H	31H	33H	36H	30H	34H
(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)

(format 4: GOT-F900 Series microcomputer connection (Binary))

Com-mand	Station No.	Address		Number of bytes	Following*2
B	0FH	00H	C8H	04H	

*2

Data 1 (R100 upper)	Data 2 (R100 lower)	Data 3 (R101 upper)	Data 4 (R101 lower)
3DH	21H	36H	04H

Item	Message format
Response message during normal communication (GOT → host)	ACK: 06H
Response message during faulty communication (GOT → host)	NAK: 15H

(b) When writing to a bit device

The following shows an example of writing "1"s to virtual devices M0 and M31 on the GOT at station No.15.



Item	Message format
Request message (host → GOT)	(format 3: GOT-F900 Series microcomputer connection (ASCII))

Com-mand	Station No.		Address				Number of bytes		Following*1
B	1	5	2	0	0	0	0	4	
42H	31H (H)	35H (L)	32H (H)	30H –	30H –	30H (L)	30H (H)	34H (L)	

*1

Data 1 (M7 to 0)		Data 2 (M15 to 8)		Data 3 (M23 to 16)		Data 4 (M31 to 24)	
0	1	0	0	0	0	8	0
30H (H)	31H (L)	30H (H)	30H (L)	30H (H)	30H (L)	38H (H)	30H (L)

0 0 0 0 0 0 0 1 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0

MMMMMMMMMMMMMMMMMMMMMMMMMMMMMMMM
76543210111111119822221111133222222
5432103210987610987654

(format 4: GOT-F900 Series microcomputer connection (Binary))

Com-mand	Station No.	Address		Number of bytes	Following*2
B	0FH	20H	00H	04H	

*2

Data 1 (M7 to 0)	Data 2 (M15 to 8)	Data 3 (M23 to 16)	Data 4 (M31 to 24)
01H	00H	00H	80H

0 0 0 0 0 0 0 1 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0

MMMMMMMMMMMMMMMMMMMMMMMMMMMMMMMM
76543210111111119822221111133222222
5432103210987610987654

Item	Message format
Response message during normal communication (GOT → host)	ACK 06H
Response message during faulty communication (GOT → host)	NAK 15H

(3) Multi-point write in bit units (3) command (w/out station No.), multi-point write in bit units (D) command (w/ station No.)
The following shows an example of turning OFF the virtual device M31 and turning ON the virtual device M2038 on the GOT at station No.31.

Item	Message format
Request message (host → GOT)	(format 3: GOT-F900 Series microcomputer connection (ASCII))  (format 4: GOT-F900 Series microcomputer connection (Binary)) 
Response message during normal communication (GOT → host)	
Response message during faulty communication (GOT → host)	

*2 The write specification specifies how the data of the specified address is changed in the bit pattern.

Write specification	Function	Description	Action example	
0	ON specification	Bits set to "1" by the bit pattern are turned ON.	Original data	1010
			Bit pattern	1100
			Result	1110
1	OFF specification	Bits set to "1" by the bit pattern are turned OFF.	Original data	1010
			Bit pattern	1100
			Result	0010
2	Invert specification	Bits set to "1" by the bit pattern are inverted.	Original data	1010
			Bit pattern	1100
			Result	0110
3	Write specification	The numerical values to write by the bit pattern are specified directly.	Original data	1010
			Bit pattern	1100
			Result	1100

(4) Fill command (4) (w/out station No.), fill command (E) (w/station No.)
The following shows an example of writing "16"s to virtual devices R50 to R100 on the GOT at station No.27.



Before execution　　After execution

Item	Message format
Request message (host → GOT)	(format 3: GOT-F900 Series microcomputer connection (ASCII))

Com-mand	Station No.		Start address				End address				Write Data	
E	2	7	0	0	6	4	0	0	C	9	1	6
45H	32H	37H	30H	30H	36H	34H	30H	30H	43H	39H	31H	36H
	(H)	(L)	(H)	–	–	(L)	(H)	–	–	(L)	(H)	(L)

(format 4: GOT-F900 Series microcomputer connection (Binary))

Com-mand	Station No.	Start address		End address		Write Data
E	1BH	00H	64H	00H	C9H	16H

Response message during normal communication (GOT → host)
ACK
06H

Response message during faulty communication (GOT → host)
NAK
15H

POINT

(1) Start address/end address specification conditions
Specify addresses so that the start address is the same or less than the end address.
Error response occurs in the following cases:
- The address to specify has the start address greater than the end address.
- Either of the start address or end address exceeds the device range that can be specified.

(2) Address specifying crossing over different devices
The start address and end address can be specified crossing over different devices.

(5) Read clock data (6) command (w/out station No.), read clock data (G) command (w/station No.)
The following shows an example of reading the clock data of GOT at station No.27.
(Assuming that the clock data of GOT has been set to "2009, October 1, 18:46:49, Thursday".)



Item	Message format
Request message (host → GOT)	(format 3: GOT-F900 Series microcomputer connection (ASCII)) Command: G (47H); Station No.: 2 (32H) (H), 7 (37H) (L) (format 4: GOT-F900 Series microcomputer connection (Binary)) Command: G; Station No.: 1BH
Response message during normal communication (GOT → host)	(format 3: GOT-F900 Series microcomputer connection (ASCII)) Year data: 0 (30H) (H), 9 (39H) (L); Month data: 1 (31H) (H), 0 (30H) (L); Day data: 0 (30H) (H), 1 (31H) (L); Hour data: 1 (31H) (H), 8 (38H) (L); Minute data: 4 (34H) (H), 6 (36H) (L); Second data: 4 (34H) (H), 9 (39H) (L); Day-of-week data: 0 (30H) (H), 4 (34H) (L) (format 4: GOT-F900 Series microcomputer connection (Binary)) Year data: 09H; Month data: 0AH; Day data: 01H; Hour data: 12H; Minute data: 2EH; Second data: 31H; Day-of-week data: 04H
Response message during faulty communication (GOT → host)	NAK: 15H

(6) Set clock data (5) command (w/out station No.), set clock data (F) command (w/station No.)
The following shows an example of setting clock data of GOT at station No.27.
(Assuming the clock data of GOT is to be set to "2009, October 1, 18:46:49 Thursday".)



After execution

<table>
<tr><th>Item</th><th>Message format</th></tr>
<tr><td>Request message
(host → GOT)</td><td>
(format 3: GOT-F900 Series microcomputer connection (ASCII))
<table>
<tr><th>Com-mand</th><th colspan="2">Station No.</th><th colspan="2">Year data</th><th colspan="2">Month data</th><th colspan="2">Day Data</th><th colspan="2">Hour data</th><th colspan="2">Minute data</th><th colspan="2">Second data</th><th colspan="2">Day-of-week data</th></tr>
<tr><td>F</td><td>2</td><td>7</td><td>0</td><td>9</td><td>1</td><td>0</td><td>0</td><td>1</td><td>1</td><td>8</td><td>4</td><td>6</td><td>4</td><td>9</td><td>0</td><td>4</td></tr>
<tr><td>46H</td><td>32H</td><td>37H</td><td>30H</td><td>39H</td><td>31H</td><td>30H</td><td>30H</td><td>31H</td><td>31H</td><td>38H</td><td>34H</td><td>36H</td><td>34H</td><td>39H</td><td>30H</td><td>34H</td></tr>
<tr><td></td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td></tr>
</table>
(format 4: GOT-F900 Series microcomputer connection (Binary))
<table>
<tr><th>Com-mand</th><th>Station No.</th><th>Year data</th><th>Month data</th><th>Day data</th><th>Hour data</th><th>Minute data</th><th>Second data</th><th>Day-of-week data</th></tr>
<tr><td>F</td><td>1BH</td><td>09H</td><td>0AH</td><td>01H</td><td>12H</td><td>2EH</td><td>31H</td><td>04H</td></tr>
</table>
</td></tr>
<tr><td>Response message during normal communication
(GOT → host)</td><td>
<table>
<tr><td>ACK</td></tr>
<tr><td>06H</td></tr>
</table>
</td></tr>
<tr><td>Response message during faulty communication
(GOT → host)</td><td>
<table>
<tr><td>NAK</td></tr>
<tr><td>15H</td></tr>
</table>
</td></tr>
</table>

POINT

When a wrong day of the week has been set by the clock data setting command

If a wrong day of the week is set by the clock data setting commands, the clock data will differ from the time displayed on the utility.

Example: When October 1, 2009 (Tuesday) is set by the clock data setting command (the actual day of the week is Thursday), Thursday (THU) will be displayed on the utility time display.

(7) In the case of interrupt outputs

The following shows an example of an interrupt output when data are written to the interrupt output devices (D13 and D14).

(Assuming that "3139H" is written to D13 and "AA55H" to D14.)

Example: When the number of interrupt data bytes is 2



Item	Message format
Interrupt output (GOT → host)	(1) When [Interrupt Data Byte] in "Communication Detail Settings" is set to "1 byte" Output value 1: 39H (2) When [Interrupt Data Byte] in "Communication Detail Settings" is set to "2 byte" Output value 1: 31H, Output value 2: 39H (3) When [Interrupt Data Byte] in "Communication Detail Settings" is set to "4 byte" Output value 1: AAH, Output value 2: 55H, Output value 3: 31H, Output value 4: 39H

POINT

Interrupt output

- To disable the interrupt output, turn ON SM52 (interrupt code output disable flag). (☞ 3.3.6 SM devices)
- To enable the interrupt output, set 8 bits to the data length at "Communication Detail Settings". (☞ 3.5.1 Setting communication interface (Communication settings))
- When "7 bits" is set, the MSB (8th bit) is ignored.(Example: FFH→7FH)

■ Error code list

When faulty, the error code is stored in SD2.
For details of error code stored in SD2, the error contents, cause and measures, refer to the following:

☞ 3.3.5 ■ Details and actions for errors (error codes) stored into SD2

When an error other than those to be stored in SD2 occurs, at faulty, only the NAK response is executed.

■ Precautions

(1) Batch reading/writing crossing over different devices
When using the batch read (0, A) or batch write (1, B) command, do not batch read/write crossing over different devices.
This will cause an error response.

3.4.5 Formats 5(Digital Electronics Corporation's memory link method)

■ Basic format of data communication

This is the same format as the protocol of the Digital Electronics Corporation's memory link method.
For details of the basic format of data communication, refer to the following manual:

☞ The connection manual of the device manufactured by Digital Electronics Corporation

This section describes items whose settings differ from the protocols of the Digital Electronics Corporation's memory link method and dedicated commands for a microcomputer connection of GOT.

Example:Request message for the batch read in word units (R) command in format 5
(Digital Electronics Corporation's memory link method)

					Data length				ESC	Com-mand	Address		Number of points	
B										R				
42H	00H	00H	00H		00H	00H	00H	06H	1BH	52H	00H	64H	00H	02H

■ Details of data items in message format

POINT

Data code during communication

Communication is performed in ASCII code.

(1) Command
Specifies the contents to access from the host to GOT.
The command is converted to a 1-digit ASCII code (Hex) and transmitted.
For details of the commands that can be used, refer to the following.

☞ 3.4.2 List of commands

(2) Address
Specifies the head No. of the device data to be read/written.
The address notated in hexadecimal is converted to a 4-digit ASCII code (Hex) and transmitted from the upper digit.
For details of the device range that can be accessed, refer to the following.

☞ 3.3 Device Data Area

(3) Number of points
Specifies the number of device data to be read/written. (Setting range: 1 to 40H)
The address notated in hexadecimal is converted to a 4-digit ASCII code (Hex) and transmitted from the upper digit.

(4) Error code
This is the response message at faulty communication appended with error contents.
The address notated in hexadecimal is converted to a 2-digit ASCII code (Hex) and transmitted from the upper digit.
For details of error codes generated in format 5 (Digital Electronics Corporation's memory link method), refer to the following:

☞ ■ Error code list

POINT

When connecting a microcomputer, etc. that uses the protocol of the Digital Electronics Corporation's memory link method with the GOT

When connecting a microcomputer, etc. that uses the protocol of the Digital Electronics Corporation's memory link method with the GOT, correct the commands to be used and the device ranges to match the specifications of the GOT.

■ Message Formats

The following shows the message format of the dedicated commands for a microcomputer connection of GOT.

(1) Batch read in word units (R) command

The following shows an example of reading the two points of the virtual devices D100 and D101.
(Assuming D100=0102H, D101=0304H are stored.)



Item	Message format
Request message (host → GOT)	
Response message during normal communication (GOT → host)	

(2) Batch write in word units (WD) command

(a) When writing to a word device

The following shows as example of writing "0064H"and "0065H"to virtual devices D100 and D101.



Item	Message format
Request message (host → GOT)	
Response message during normal communication (GOT → host)	

(3) In the case of interrupt outputs

The following shows an example of an interrupt output when data are written to the interrupt output devices (D13).
(Assuming that "31H" is written to D13.)

Example: When the number of interrupt data bytes is 1



Item	Message format
Interrupt output (GOT → host)	When [Interrupt Data Byte] in "Communication Detail Settings" is set to "1 byte" Output value 1 31H

POINT

Interrupt output

- To disable the interrupt output, turn ON SM52 (interrupt code output disable flag).
  (☞ 3.3.6 SM devices)
- To enable the interrupt output, set 8 bits to the data length at "Communication Detail Settings".
  (☞ 3.5.1 Setting communication interface (Communication settings))
- When "7 bits" is set, the MSB (8th bit) is ignored. (Example: FFH→7FH)

■ Error code list

In the case of format 5 (Digital Electronics Corporation's memory link method), the details (error code) of the error are appended to the response message during faulty communication.
The following shows error code, error contents, cause, and measures.

Error code	Description	Action
10H	Command error An unsupported command was used.	• Review the contents of the message to transmit. • Check the commands in the message. (☞ 3.4.2 List of commands)
12H	Message length error The upper limit of the data length that can be received by the GOT has been exceeded.	
FAH	Address error The start address of the read/write device is out of range.	• Review the contents of the message to transmit. • Check whether the non-existent data is set (e.g. setting "07" at the day of the week) as clock data.
FBH	Exceeded number of points error The read/write range exceeded the device range.	• Review the contents of the message to transmit. • Check the devices that can be used and the device ranges. (☞ 3.3 Device Data Area)
FCH	Message format error The format of the received message has error.	• Check the settings of "Communication Detail Settings". • Review the contents of the message to transmit.
FFH	Timeout error There is no response from the GOT, or the station of the specified address does not exist.	• Check the communication cable and communication module attachment. • Check the settings of "Communication Detail Settings". • Review the contents of the message to transmit.

■ Precautions

(1) Batch reading/writing crossing over different devices
When using the batch read (R) or batch write (W) command, do not batch read/write crossing over the different devices.
This will cause an error response.

(2) Storage order for 32-bit data
To use the program of Digital Electronics Corporation's memory link method with [32bit Order] setting to GOT1000 series, set [HL Order] to [32bit Order] for [Communication Detail Settings] when 32-bit data is set for GOT-A900 series.
With setting [LH Order], the order of upper bits and lower bits are reversed when the GOT displays and writes 32-bit data.

3.4.6 Formats 6, 7 (4E frame)

■ Basic format of data communication

This is the same message format as when communication is performed using the MC protocol (4E frame) of the Q/QnA Series serial communication module.
For details of the basic format of data communication, refer to the following manual:

☞ MELSEC-Q/L MELSEC Communication Protocol Reference Manual

This section describes items whose settings differ from the MC protocol of the Q/QnA Series serial communication module, and the dedicated commands for a GOT microcomputer connection.

Example: Request message for the batch read (0401) command in word units
Device name : D
Head device : 100
Device points : 2
Communication setting of GOT side : Network No.=1, PLC No.=1

(Format 6 (4E frame (ASCII))

Request type				Serial No.				Fixed value				Network No.		PLC No.		Request destination module I/O No.				Request destination module station No.		Following *1
5	4	0	0	0	0	0	0	0	0	0	0	0	1	0	1	0	0	0	0	0	0	
35H	34H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	31H	30H	31H	30H	30H	30H	30H	30H	30H	
(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	–	(H)	(L)	(H)	(L)	(H)	–	–	(L)	(H)	(L)	

*1

Request data length				CPU monitoring timer				Command				
0	0	1	8	0	0	0	0	0	4	0	1	→ 1)
30H	30H	31H	38H	30H	30H	30H	30H	30H	34H	30H	31H	
(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	–	–	(L)	

Data length target range

Character A section

1) →	Sub-command				Device code		Head Device						Device points			
	0	0	0	0	D	*	0	0	0	1	0	0	0	0	0	2
	30H	30H	30H	30H	44H	2AH	30H	30H	30H	31H	30H	30H	30H	30H	30H	32H
	(H)	–	–	(L)	(H)	(L)	(H)	–	–	–	–	(L)	(H)	–	–	(L)

Data length target range

(format 7:4E frame (Binary))

Request type		Serial No.		Fixed value		Network No.	PLC No.	Request destination module I/O No.		Request destination module station No.	Request data length		CPU monitoring timer		Command		Sub-command		Head Device			Device code	Device points	
54H	00H	00H	00H	00H	00H	01H	01H	00H	00H	00H	0CH	00H	00H	00H	01H	04H	00H	00H	64H	00H	00H	A8H	02H	00H

Data length target range

■ Details of data items in message format

POINT

Data code during communication
Communication of format 6 is performed in ASCII code.
Communication of the format 7 is performed in Binary code.

The following table shows the contents of the data items.

<table>
<tr><th rowspan="2">Data item name</th><th colspan="2">Contents</th></tr>
<tr><th>Format 6</th><th>Format 7</th></tr>
<tr><td rowspan="2">Request type (Microcomputer side)</td><td colspan="2">Indicates it is a command message.</td></tr>
<tr><td>Command message: ASCII "5400" (Fixed value)</td><td>Command message: 54H (Upper digit) (Fixed value)</td></tr>
<tr><td rowspan="2">Response type (GOT side)</td><td colspan="2">Indicates it is a response message.</td></tr>
<tr><td>Response message: ASCII "D400" (Fixed value)</td><td>Response message: D4H (Upper digit) (Fixed value)</td></tr>
<tr><td>Serial No.</td><td colspan="2">Arbitrary number for recognition of the message appended at the microcomputer side. GOT sends the response message appending this Serial No.</td></tr>
<tr><td>Fixed value</td><td>Should be ASCII "0000".</td><td>Should be "0000H".</td></tr>
<tr><td rowspan="2">Network No.</td><td colspan="2">Set the same number as the network No. set in the GOT.
For setting method of "Communication Detail Settings", refer to the following.
☞ 3.5.1 Setting communication interface (Communication settings)</td></tr>
<tr><td>Transmit the data converted to a 2-digit ASCII code from the upper digit.</td><td>Transmit the data converted to a 2-digit binary code.</td></tr>
<tr><td rowspan="2">PLC No.</td><td colspan="2">Set the same number as the PLC No. set in the GOT.
For setting method of "Communication Detail Settings", refer to the following.
☞ 3.5.1 Setting communication interface (Communication settings)</td></tr>
<tr><td>Transmit the data converted to a 2-digit ASCII code from the upper digit.</td><td>Transmit the data converted to a 2-digit binary code.</td></tr>
<tr><td>Request destination module I/O No.</td><td colspan="2">Ignore GOT.</td></tr>
<tr><td>Request destination module station No.</td><td colspan="2">Ignore GOT.</td></tr>
<tr><td rowspan="2">Request data length</td><td colspan="2">Number of bytes from the start of CPU monitoring timer to the last request data.</td></tr>
<tr><td>Transmit the data converted to a 4-digit ASCII code from the upper digit.</td><td>Transmit the data converted to a 4-digit binary code from the lower two digits.</td></tr>
<tr><td rowspan="2">Response data length</td><td colspan="2">Appended to the response message from the microcomputer side.
Number of bytes from the start of end code to the last request data.</td></tr>
<tr><td>Transmit the data converted to a 4-digit ASCII code from the upper digit.</td><td>Transmit the data converted to a 4-digit binary code from the lower two digits.</td></tr>
<tr><td>CPU monitoring timer</td><td colspan="2">Ignore GOT.</td></tr>
<tr><td rowspan="2">Command, Sub-command</td><td colspan="2">Specifies the access contents from the microcomputer side to GOT. For details of the commands that can be used, refer to the following.
☞ 3.4.2 List of commands</td></tr>
<tr><td>Transmit the command and sub-command converted to a 4-digit ASCII code, from the upper digit.</td><td>Transmit the data converted to a 4-digit binary code from the lower two digits.</td></tr>
<tr><td rowspan="2">Device code</td><td colspan="2">Specifies the code by which the device data to be read/written is recognized.
For details of the device range that can be accessed, refer to the following.
☞ 3.3 Device Data Area</td></tr>
<tr><td>Transmit the 2-digit ASCII code corresponding to the following device codes.
<table>
<tr><th>Device name</th><th>Device code</th></tr>
<tr><td>M</td><td>M*</td></tr>
<tr><td>SM</td><td>SM</td></tr>
<tr><td>L</td><td>L*</td></tr>
<tr><td>D</td><td>D*</td></tr>
<tr><td>SD</td><td>SD</td></tr>
<tr><td>R</td><td>R*</td></tr>
</table></td><td>Transmit the 2-digit binary code corresponding to the following device codes.
<table>
<tr><th>Device name</th><th>Device code</th></tr>
<tr><td>M</td><td>90H</td></tr>
<tr><td>SM</td><td>91H</td></tr>
<tr><td>L</td><td>92H</td></tr>
<tr><td>D</td><td>A8H</td></tr>
<tr><td>SD</td><td>A9H</td></tr>
<tr><td>R</td><td>AFH</td></tr>
</table></td></tr>
</table>

(Continued to next page)

(From previous page)

Data item name	Contents	
	Format 6	Format 7
Head device	Specifies the head No. of the device data to be read/written. For details of the device range that can be accessed, refer to the following. ☞ 3.3 Device Data Area	
	Transmit the data notated in decimal converted to a 6-digit ASCII code, from the upper digit.	Transmit the data converted to a 6-digit binary code from the lower two digits.
Device points	Specifies the number of device data to be read/written. (Setting range: 1 to 40H) <When using random read/write command> When setting multiple bit accesses, word accesses or double word accesses, limit the total number of access points to within 64 points. <When using multiple block batch read/write commands> When setting multiple blocks, limit the total number of points of all blocks to within 64 points.	
	Transmit the data notated in decimal converted to a 4-digit ASCII code, from the upper digit.	Transmit the data converted to a 4-digit binary code from the lower two digits.
Year, month, day, hour, minute, second and day of the week data	Specifies year, month, day, hour, minute, second, and day of the week to be read/set to the GOT clock data. ☞ ■ Message format (1) Read clock data (1901) command ☞ ■ Message format (2) Set clock data (0901) command	
	Transmit the data notated in decimal converted to a 2-digit ASCII code, from the upper digit.	Transmit the data converted to a 2-digit binary code.
End code (Microcomputer side)	Appended to the response message from the microcomputer side. If an error occurs at the microcomputer side, the error code is displayed. ☞ ■ Error code list	
	Transmit the data notated in hexadecimal converted to a 4-digit ASCII code, from the upper digit.	Transmit the data converted to a 4-digit binary code from the lower two digits.

POINT

When connecting a microcomputer, etc. that uses the MC protocol of the Q/QnA series serial communication module with the GOT

When connecting a microcomputer, etc. that uses the MC protocol of the Q/QnA series serial communication module with the GOT, correct the commands to be used and the device ranges to match the GOT specifications.

■ Message format

The following shows the message format of the dedicated commands for a microcomputer connection of GOT.

(1) Read clock data (1901) command

The following shows an example of reading the clock data of GOT.
(Assuming that the clock data of GOT has been set to "2009, October 1, 18:46:49, Thursday".)



Item	Message format

Request message (host → GOT)

(format 6:4E frame (ASCII))

Request type				Serial No.				Fixed value				Network No.		PLC No.		
5	4	0	0	0	0	0	0	0	0	0	0	0	1	0	1	Following *1
35H	34H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	31H	30H	31H	
(H)	–	–	(L)	(H)	–	–	(L)	(H)	–	–	(L)	(H)	(L)	(H)	(L)	

*1

Request destination module I/O No.				Request destination module station No.		Request data length				CPU monitoring timer				
0	0	0	0	0	0	0	0	0	C	0	0	0	0	→ 1)
30H	30H	30H	30H	30H	30H	30H	30H	30H	43H	30H	30H	30H	30H	
(H)	–	–	(L)	(H)	(L)	(H)	–	–	(L)	(H)	–	–	(L)	

Character A section

1) →	Command				Sub-command			
	1	9	0	1	0	0	0	0
	31H	39H	30H	31H	30H	30H	30H	30H
	(H)	–	–	(L)	(H)	–	–	(L)

(format 7:4E frame (Binary))

Request type		Serial No.		Fixed value		Network No.	PLC No.	Request destination module I/O No.		Request destination module station No.	Request data length		Following *1
54H	00H	00H	00H	00H	00H	01H	01H	00H	00H	00H	06H	00H	

Data length target range

*1

CPU monitoring timer		Command		Sub-command	
00H	00H	01H	19H	00H	00H

(Continued to next page)

(From previous page)

Item	Message format
Response message during normal communication (GOT → host)	(format 6:4E frame (ASCII))

Response type				Serial No.				Fixed value				Network No.		PLC No.		
D	4	0	0	0	0	0	0	0	0	0	0	0	1	0	1	Following *1
44H	34H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	31H	30H	31H	
(H)	–	–	(L)	(H)	–	–	(L)	(H)	–	–	(L)	(H)	(L)	(H)	(L)	

*1

Request destination module I/O No.				Request destination module station No.		Response data length				End code				
0	0	0	0	0	0	0	0	1	2	0	0	0	0	→ 1)
30H	30H	30H	30H	30H	30H	30H	30H	31H	32H	30H	30H	30H	30H	
(H)	–	–	(L)	(H)	(L)	(H)	–	–	(L)	(H)	–	–	(L)	

Character B section

1) →	Year data		Month data		Day data		Hour data		Minute data		Second data		Day-of-week data	
	0	9	1	0	0	1	1	8	4	6	4	9	0	4
	30H	39H	31H	30H	30H	31H	31H	38H	34H	36H	34H	39H	30H	34H
	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)

(format 7:4E frame (Binary))

Request type		Serial No.		Fixed value		Network No.	PLC No.	Request destination module I/O No.		Request destination module station No.	Response data length		Following *1
D4H	00H	00H	00H	00H	00H	01H	01H	00H	00H	00H	09H	00H	

Data length target range

*1

End code		Year data	Month data	Day data	Hour data	Minute data	Second data	Day-of-week data
00H	00H	09H	0AH	01H	12H	2EH	31H	04H

(Continued to next page)

Item	Message format
Response message during faulty communication (GOT → host)	(format 6:4E frame (ASCII))

Response type				Serial No.				Fixed value				Network No.		PLC No.		
D	4	0	0	0	0	0	0	0	0	0	0	0	1	0	1	Following *1
44H	34H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	31H	30H	31H	
(H)	–	–	(L)	(H)	–	–	(L)	(H)	–	–	(L)	(H)	(L)	(H)	(L)	

*1

Request destination module I/O No.				Request destination module station No.		Response data length				End code				
0	0	0	0	0	0	0	0	1	6	0	0	5	6	→ 1)
30H	30H	30H	30H	30H	30H	30H	30H	31H	36H	30H	30H	35H	36H	
(H)	–	–	(L)	(H)	(L)	(H)	–	–	(L)	(H)	–	–	(L)	

1) →

Network No.		PLC No.		Request destination module I/O No.				Request destination module station No.		Command				Sub-command			
0	0	0	0	0	0	0	0	0	0	1	9	0	1	0	0	0	0
30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	31H	39H	30H	31H	30H	30H	30H	30H
(H)	(L)	(H)	(L)	(H)	–	–	(L)	(H)	(L)	(H)	–	–	(L)	(H)	–	–	(L)

(format 7:4E frame (Binary))

Request type		Serial No.		Fixed value		Network No.	PLC No.	Request destination module I/O No.		Request destination module station No.	Response data length		Following *1
D4H	00H	00H	00H	00H	00H	01H	01H	00H	00H	00H	0BH	00H	

Data length target range

*1 ←→

End code		Network No.	PLC No.	Request destination module I/O No.		Request destination module station No.	Command		Sub-command	
56H	00H	00H	00H	00H	00H	00H	01H	19H	00H	00H

(2) Set clock data (0901) command

The following shows an example of setting the clock data of GOT.

(Assuming the clock data of GOT is to be set to "2009, October 1, 18:46:49 Thursday".)



After execution

Item	Message format

Request message (host → GOT)

(format 6:4E frame (ASCII))

Response type				Serial No.				Fixed value				Network No.		PLC No.		Following *1
5	4	0	0	0	0	0	0	0	0	0	0	0	1	0	1	
35H	34H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	31H	30H	31H	
(H)	–	–	(L)	(H)	–	–	(L)	(H)	–	–	(L)	(H)	(L)	(H)	(L)	

*1

	Request destination module I/O No.				Request destination module station No.		Request data length				CPU monitoring timer				Command				
	0	0	0	0	0	0	0	0	1	A	0	0	0	0	0	9	0	1	→ 1)
	30H	30H	30H	30H	30H	30H	30H	30H	31H	41H	30H	30H	30H	30H	31H	39H	30H	31H	
	(H)	–	–	(L)	(H)	(L)	(H)	–	–	(L)	(H)	–	–	(L)	(H)	–	–	(L)	

Character C section

	Sub-command				Year data		Month data		Day data		Hour data		Minute data		Second data		Day-of-week data	
1) →	0	0	0	0	0	9	1	0	0	1	1	8	4	6	4	9	0	4
	30H	30H	30H	30H	30H	39H	31H	30H	30H	31H	31H	38H	34H	36H	34H	39H	30H	34H
	(H)	–	–	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)

(format 7:4E frame (Binary))

Request type		Serial No.		Fixed value		Network No.	PLC No.	Request destination module I/O No.		Request destination module station No.	Request data length		Following *1
54H	00H	00H	00H	00H	00H	01H	01H	00H	00H	00H	0DH	00H	

Data length target range

*1

CPU monitoring timer		Command		Sub-command		Year data	Month data	Day data	Hour data	Minute data	Second data	Day-of-week data
00H	00H	01H	09H	00H	00H	09H	0AH	01H	12H	2EH	31H	04H

(Continued to next page)

(From previous page)

Item	Message format

Response message during normal communication (GOT → host)

(format 6:4E frame (ASCII))

Response type				Serial No.				Fixed value				Network No.		PLC No.		Following *1
D	4	0	0	0	0	0	0	0	0	0	0	0	1	0	1	
44H	34H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	31H	30H	31H	
(H)	–	–	(L)	(H)	–	–	(L)	(H)	–	–	(L)	(H)	(L)	(H)	(L)	

*1

Request destination module I/O No.				Request destination module station No.		Response data length				End code			
0	0	0	0	0	0	0	0	0	4	0	0	0	0
30H	30H	30H	30H	30H	30H	30H	30H	30H	34H	30H	30H	30H	30H
(H)	–	–	(L)	(H)	(L)	(H)	–	–	(L)	(H)	–	–	(L)

(format 7:4E frame (Binary))

Data length target range

Request type		Serial No.		Fixed value		Network No.	PLC No.	Request destination module I/O No.		Request destination module station No.	Response data length		End code	
D4H	00H	00H	00H	00H	00H	01H	01H	00H	00H	00H	02H	00H	00H	00H

(Continued to next page)

(From previous page)

Item	Message format
Response message during faulty communication (GOT → host)	(format 6:4E frame (ASCII))

Response type				Serial No.				Fixed value				Network No.		PLC No.		Following *1
D	4	0	0	0	0	0	0	0	0	0	0	0	1	0	1	
44H	34H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	31H	30H	31H	
(H)	–	–	(L)	(H)	–	–	(L)	(H)	–	–	(L)	(H)	(L)	(H)	(L)	

*1

Request destination module I/O No.				Request destination module station No.		Response data length				End code				
0	0	0	0	0	0	0	0	1	6	0	0	5	6	→ 1)
30H	30H	30H	30H	30H	30H	30H	30H	31H	36H	30H	30H	35H	36H	
(H)	–	–	(L)	(H)	(L)	(H)	–	–	(L)	(H)	–	–	(L)	

1) →

Network No.		PLC No.		Request destination module I/O No.				Request destination module station No.		Command				Sub-command			
0	0	0	0	0	0	0	0	0	0	0	9	0	1	0	0	0	0
30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	39H	30H	31H	30H	30H	30H	30H
(H)	(L)	(H)	(L)	(H)	–	–	(L)	(H)	(L)	(H)	–	–	(L)	(H)	–	–	(L)

(format 7:4E frame (Binary))

Request type		Serial No.		Fixed value		Network No.	PLC No.	Request destination module I/O No.		Request destination module station No.	Response data length		Following *1
D4H	00H	00H	00H	00H	00H	01H	01H	00H	00H	00H	0BH	0H	

Data length target range

*1

End code		Network No.	PLC No.	Request destination module I/O No.		Request destination module station No.	Command		Sub-command	
56H	00H	00H	00H	00H	00H	00H	01H	09H	00H	00H

POINT

When a wrong day of the week has been set by the clock data setting command

If a wrong day of the week is set by the clock data setting commands, the clock data will differ from the time displayed on the utility.

Example: When October 1, 2009 (Tuesday) is set by the clock data setting command (the actual day of the week is Thursday), Thursday (THU) will be displayed on the utility time display.

■ Error code list

The following shows error code, error contents, cause, and measures.

Error code	Description	Action
0002H	Device point error The specification of device range to read/write has error.	• Check the specified head device and number of points, and correct it. (☞ 3.3 Device Data Area)
0050H	Request (command)/Response (response) type code error Code other than the specified value is set for command/response type.	• Check the command/response type set in the microcomputer and correct it.
0056H	Device error A non-existent device has been specified.	• Check the devices that can be used and the device ranges. (☞ 3.3 Device Data Area)
0057H	Device point error • The command number of points specification from the microcomputer exceeds the maximum number of points processed at each process (number of points processed in one communication). • The start address (head device number) to specified number of points exceeds the maximum address (device number, step number) for each process.	• Correct the specified number of points, or the start address (device number). (☞ 3.3 Device Data Area)
	When reading data which the command bit length is longer than the specification, the set number of write data points differs from the specified number of points value.	• Check the command data length and set the data again.
0058H	• The command start address (head device number, start step number) specification from the microcomputer exceeds the range that can be specified. • Value outside the GOT parameter setting range is specified in the microcomputer program and file register (R) reading/writing.	• Correct the values to values that can be specified in each process.
	• Word device is specified in the command for bit device. • In the command for word device, a bit device start number is specified in other than hexadecimal.	• Correct the command or the specified device.
00A1H	Request content cannot be analyzed because the text length or request data length is too short.	• Review the text length or the head request data length.
00A2H	Request cannot be processed.	• Correct the request content and command.
C0D6H	The specification of network No. and station No. have error.	• Review the network No., station No. specification method.

3.4.7 Formats 8, 9 (QnA compatible 3E frame)

■ Basic format of data communication

This is the same message format as when communication is performed using the MC protocol (QnA compatible 3E frame) of the Q/QnA Series serial communication module.
For details of the basic format of data communication, refer to the following manual:

☞ MELSEC-Q/L MELSEC Communication Protocol Reference Manual

This section describes items whose settings differ from the MC protocol of the Q/QnA Series serial communication module, and the dedicated commands for a GOT microcomputer connection.

Example: Request message for the batch read (0401) command in word units
Device name : D
Head device : 100
Device points : 2
Communication setting of GOT side : Network No.=1, PLC No.=1

(Format 8: QnA compatible 3E frame (ASCII))

Subheader				Network No.		PLC No.		Request destination module I/O No.				Request destination module station No.		Request data length				Following *1
5	0	0	0	0	1	0	1	0	0	0	0	0	0	0	0	1	8	
35H	30H	30H	30H	30H	31H	30H	31H	30H	30H	30H	30H	30H	30H	30H	30H	31H	38H	
(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	–	–	(L)	(H)	(L)	(H)	(L)	(H)	(L)	

*1 Character A section

CPU monitoring timer				Command				Sub-command				Device code		Start Device						Device points			
0	0	0	0	0	4	0	1	0	0	0	0	D	*	0	0	0	1	0	0	0	0	0	2
30H	30H	30H	30H	30H	34H	30H	31H	30H	30H	30H	30H	44H	2AH	30H	30H	30H	31H	30H	30H	30H	30H	30H	32H
(H)	(L)	(H)	(L)	(H)	–	–	(L)	(H)	–	–	(L)	(H)	(L)	(H)	–	–	–	–	(L)	(H)	–	–	(L)

Data length target data

(Format 9: QnA compatible 3E frame (Binary))

Subheader		Network No.	PLC No.	Request destination module I/O No.		Request destination module station No.	Request data length		CPU monitoring timer		Command		Sub-command		Start Device			Device code	Device points	
50H	00H	01H	01H	00H	00H	00H	0CH	00H	00H	00H	01H	04H	00H	00H	64H	00H	00H	A8H	02H	00H

Data length target data

■ Details of data items in message format

POINT

Data code during communication
Communication of format 8 is performed in ASCII code.
Communication of the format 9 is performed in Binary code.

The following table shows the contents of the data items.

<table>
<tr><th rowspan="2">Data item name</th><th colspan="2">Contents</th></tr>
<tr><th>Format 8</th><th>Format 9</th></tr>
<tr><td rowspan="2">Subheader (Microcomputer side)</td><td colspan="2">Indicates it is a command message.</td></tr>
<tr><td>Command message: ASCII "5000" (Fixed value)</td><td>Command message: 50H (Upper digit) (Fixed value)</td></tr>
<tr><td rowspan="2">Subheader (GOT side)</td><td colspan="2">Indicates it is a response message.</td></tr>
<tr><td>Response message: ASCII "D000" (Fixed value)</td><td>Response message: D0H (Upper digit) (Fixed value)</td></tr>
<tr><td rowspan="2">Network No.</td><td colspan="2">Set the same number as the network No. set in the GOT.
For setting method of "Communication Detail Settings", refer to the following.
☞ 3.5.1 Setting communication interface (Communication settings)</td></tr>
<tr><td>Transmit the data converted to a 2-digit ASCII code from the upper digit.</td><td>Transmit the data converted to a 2-digit binary code.</td></tr>
<tr><td rowspan="2">PLC No.</td><td colspan="2">Set the same number as the PLC No. set in the GOT.
For setting method of "Communication Detail Settings", refer to the following.
☞ 3.5.1 Setting communication interface (Communication settings)</td></tr>
<tr><td>Transmit the data converted to a 2-digit ASCII code from the upper digit.</td><td>Transmit the data converted to a 2-digit binary code.</td></tr>
<tr><td>Request destination module I/O No.</td><td colspan="2">Ignore GOT.</td></tr>
<tr><td>Request destination module station No.</td><td colspan="2">Ignore GOT.</td></tr>
<tr><td rowspan="2">Request data length</td><td colspan="2">Number of bytes from the start of CPU monitoring timer to the last request data.</td></tr>
<tr><td>Transmit the data converted to a 4-digit ASCII code from the upper digit.</td><td>Transmit the data converted to a 4-digit binary code from the lower two digits.</td></tr>
<tr><td rowspan="2">Response data length</td><td colspan="2">Appended to the response message from the microcomputer side.
Number of bytes from the start of end code to the last request data.</td></tr>
<tr><td>Transmit the data converted to a 4-digit ASCII code from the upper digit.</td><td>Transmit the data converted to a 4-digit binary code from the lower two digits.</td></tr>
<tr><td>CPU monitoring timer</td><td colspan="2">Ignore GOT.</td></tr>
<tr><td rowspan="2">Command, Sub-command</td><td colspan="2">Specifies the access contents from the microcomputer side to GOT. For details of the commands that can be used, refer to the following.
☞ 3.4.2 List of commands</td></tr>
<tr><td>Transmit the command and sub-command converted to a 4-digit ASCII code, from the upper digit.</td><td>Transmit the data converted to a 4-digit binary code from the lower two digits.</td></tr>
<tr><td rowspan="2">Device code</td><td colspan="2">Specifies the code by which the device data to be read/written is recognized.
For details of the device range that can be accessed, refer to the following.
☞ 3.3 Device Data Area</td></tr>
<tr><td>Transmit the 2-digit ASCII code corresponding to the following device codes.
<table>
<tr><th>Device name</th><th>Device code</th></tr>
<tr><td>M</td><td>M*</td></tr>
<tr><td>SM</td><td>SM</td></tr>
<tr><td>L</td><td>L*</td></tr>
<tr><td>D</td><td>D*</td></tr>
<tr><td>SD</td><td>SD</td></tr>
<tr><td>R</td><td>R*</td></tr>
</table></td><td>Transmit the 2-digit binary code corresponding to the following device codes.
<table>
<tr><th>Device name</th><th>Device code</th></tr>
<tr><td>M</td><td>90H</td></tr>
<tr><td>SM</td><td>91H</td></tr>
<tr><td>L</td><td>92H</td></tr>
<tr><td>D</td><td>A8H</td></tr>
<tr><td>SD</td><td>A9H</td></tr>
<tr><td>R</td><td>AFH</td></tr>
</table></td></tr>
<tr><td rowspan="2">Head device</td><td colspan="2">Specifies the head No. of the device data to be read/written.
For details of the device range that can be accessed, refer to the following.
☞ 3.3 Device Data Area</td></tr>
<tr><td>Transmit the data notated in decimal converted to a 6-digit ASCII code, from the upper digit.</td><td>Transmit the data converted to a 6-digit binary code from the lower two digits.</td></tr>
</table>

(Continued to next page)

(From previous page)

<table>
<tr><th rowspan="2">Data item name</th><th colspan="2">Contents</th></tr>
<tr><th>Format 8</th><th>Format 9</th></tr>
<tr><td rowspan="2">Device points</td><td colspan="2">Specifies the number of device data to be read/written. (Setting range: 1 to 40H)
<When using random read/write command>
When setting multiple bit accesses, word accesses or double word accesses, limit the total number of access points to within 64 points.
<When using multiple block batch read/write commands>
When setting multiple blocks, limit the total number of points of all blocks to within 64 points.</td></tr>
<tr><td>Transmit the data notated in decimal converted to a 4-digit ASCII code, from the upper digit.</td><td>Transmit the data converted to a 4-digit binary code from the lower two digits.</td></tr>
<tr><td rowspan="2">Year, month, day, hour,
minute, second and day
of the week data</td><td colspan="2">Specifies year, month, day, hour, minute, second, and day of the week to be read/set to the GOT clock data.
■ Message format (1) Read clock data (1901) command
■ Message format (2) Set clock data (0901) command</td></tr>
<tr><td>Transmit the data notated in decimal converted to a 2-digit ASCII code, from the upper digit.</td><td>Transmit the data converted to a 2-digit binary code.</td></tr>
<tr><td rowspan="2">End code
(Microcomputer side)</td><td colspan="2">Appended to the response message from the microcomputer side. If an error occurs at the microcomputer side, the error code is displayed.
■ Error code list</td></tr>
<tr><td>Transmit the data notated in hexadecimal converted to a 4-digit ASCII code, from the upper digit.</td><td>Transmit the data converted to a 4-digit binary code from the lower two digits.</td></tr>
</table>

POINT

When connecting a microcomputer, etc. that uses the MC protocol of the Q/QnA series serial communication module with the GOT

When connecting a microcomputer, etc. that uses the MC protocol of the Q/QnA series serial communication module with the GOT, correct the commands to be used and the device ranges to match the GOT specifications.

■ Message format

The following shows the message format of the dedicated commands for a microcomputer connection of GOT.

(1) Read clock data (1901) command

The following shows an example of reading the clock data of GOT.
(Assuming that the clock data of GOT has been set to "2009, October 1, 18:46:49, Thursday".)



<table>
<tr><th>Item</th><th>Message format</th></tr>
<tr><td>Request message
(host → GOT)</td><td>
(format 8:QnA compatible 3E frame (ASCII))
<table>
<tr><th colspan="4">Subheader</th><th colspan="2">Network No.</th><th colspan="2">PLC No.</th><th colspan="4">Request destination module I/O No.</th><th colspan="2">Request destination module station No.</th><th rowspan="2">Following *1</th></tr>
<tr><td>5</td><td>0</td><td>0</td><td>0</td><td>0</td><td>1</td><td>0</td><td>1</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td></tr>
<tr><td>35H</td><td>30H</td><td>30H</td><td>30H</td><td>30H</td><td>31H</td><td>30H</td><td>31H</td><td>30H</td><td>30H</td><td>30H</td><td>30H</td><td>30H</td><td>30H</td><td></td></tr>
<tr><td>(H)</td><td>–</td><td>–</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>(L)</td><td>(H)</td><td>–</td><td>–</td><td>(L)</td><td>(H)</td><td>(L)</td><td></td></tr>
</table>
*1
<table>
<tr><th colspan="4">Request data length</th><th colspan="4">CPU monitoring timer</th><th colspan="4">Command</th><th colspan="4">Sub-command</th></tr>
<tr><td>0</td><td>0</td><td>0</td><td>C</td><td>0</td><td>0</td><td>0</td><td>0</td><td>1</td><td>9</td><td>0</td><td>1</td><td>0</td><td>0</td><td>0</td><td>0</td></tr>
<tr><td>30H</td><td>30H</td><td>30H</td><td>43H</td><td>30H</td><td>30H</td><td>30H</td><td>30H</td><td>31H</td><td>39H</td><td>30H</td><td>31H</td><td>30H</td><td>30H</td><td>30H</td><td>30H</td></tr>
<tr><td>(H)</td><td>–</td><td>–</td><td>(L)</td><td>(H)</td><td>–</td><td>–</td><td>(L)</td><td>(H)</td><td>–</td><td>–</td><td>(L)</td><td>(H)</td><td>–</td><td>–</td><td>(L)</td></tr>
</table>
Character A section
Data length target data
(format 9:QnA compatible 3E frame (Binary))
<table>
<tr><th colspan="2">Subheader</th><th>Network No.</th><th>PLC No.</th><th colspan="2">Request destination module I/O No.</th><th>Request destination module station No.</th><th colspan="2">Request data length</th><th colspan="2">CPU monitoring timer</th><th colspan="2">Command</th><th colspan="2">Sub-command</th></tr>
<tr><td>50H</td><td>00H</td><td>01H</td><td>01H</td><td>00H</td><td>00H</td><td>00H</td><td>06H</td><td>00H</td><td>00H</td><td>00H</td><td>01H</td><td>19H</td><td>00H</td><td>00H</td></tr>
</table>
Data length target data
</td></tr>
</table>

(Continued to next page)

(From previous page)

Item	Message format
Response message during normal communication (GOT → host)	(format 8:QnA compatible 3E frame (ASCII))

Subheader				Network No.		PLC No.		Request destination module I/O No.				Request destination module station No.		Response data length				Following *1
D	0	0	0	0	1	0	1	0	0	0	0	0	0	0	0	1	2	
44H	30H	30H	30H	30H	31H	30H	31H	30H	30H	30H	30H	30H	30H	30H	30H	31H	32H	
(H)	–	–	(L)	(H)	(L)	(H)	(L)	(H)	–	–	(L)	(H)	(L)	(H)	–	–	(L)	

*1 Character B section

End code				Year data		Month data		Day data		Hour data		Minute data		Second data		Day-of-week data	
0	0	0	0	0	9	1	0	0	1	1	8	4	6	4	9	0	4
30H	30H	30H	30H	30H	39H	31H	30H	30H	31H	31H	38H	34H	36H	34H	39H	30H	34H
(H)	–	–	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)

Data length target data

(format 9:QnA compatible 3E frame (Binary))

Subheader		Network No.	PLC No.	Request destination module I/O No.		Request destination module station No.	Response data length		End code		Year data	Month data	Day data	Hour data	Minute data	Second data	Day-of-week data
D0H	00H	01H	01H	00H	00H	00H	09H	00H	00H	00H	09H	0AH	01H	12H	2EH	31H	04H

Data length target data

(Continued to next page)

Item	Message format
Response message during faulty communication (GOT → host)	(format 8:QnA compatible 3E frame (ASCII))

Subheader				Network No.		PLC No.		Request destination module I/O No.				Request destination module station No.		Response data length				Following *1
D	0	0	0	0	1	0	1	0	0	0	0	0	0	0	0	1	6	
44H	30H	30H	30H	30H	31H	30H	31H	30H	30H	30H	30H	30H	30H	30H	30H	31H	36H	
(H)	–	–	(L)	(H)	(L)	(H)	(L)	(H)	–	–	(L)	(H)	(L)	(H)	–	–	(L)	

*1

	End code				Network No.		PLC No.		Request destination module I/O No.				Request destination module station No.		
	0	0	5	6	0	0	0	0	0	0	0	0	0	0	→ 1)
	30H	30H	35H	36H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	
	(H)	–	–	(L)	(H)	(L)	(H)	(L)	(H)	–	–	(L)	(H)	(L)	

Data length target data

1) →	Command				Sub-command			
	1	9	0	1	0	0	0	0
	31H	39H	30H	31H	30H	30H	30H	30H
	(H)	–	–	(L)	(H)	–	–	(L)

Data length target data

(format 9:QnA compatible 3E frame (Binary))

Subheader		Network No.	PLC No.	Request destination module I/O No.		Request destination module station No.	Response data length		Following *1
D0H	00H	01H	01H	00H	00H	00H	0BH	00H	

*1

	End code		Network No.	PLC No.	Request destination module I/O No.		Request destination module station No.	Command		Sub-command	
	56H	00H	00H	00H	00H	00H	00H	01H	19H	00H	00H

Data length target data

(2) Set clock data (0901) command

The following shows an example of setting the clock data of GOT.

(Assuming the clock data of GOT is to be set to "2009, October 1, 18:46:49 Thursday".)



After execution

Item	Message format
Request message (host → GOT)	(format 8:QnA compatible 3E frame (ASCII))

Subheader				Network No.		PLC No.		Request destination module I/O No.				Request destination module station No.		Following *1
5	0	0	0	0	1	0	1	0	0	0	0	0	0	
35H	30H	30H	30H	30H	31H	30H	31H	30H	30H	30H	30H	30H	30H	
(H)	–	–	(L)	(H)	(L)	(H)	(L)	(H)	–	–	(L)	(H)	(L)	

*1

Response data length				CPU monitoring timer				Command				
0	0	1	A	0	0	0	0	0	9	0	1	→ 1)
30H	30H	31H	41H	30H	30H	30H	30H	31H	39H	30H	31H	
(H)	–	–	(L)	(H)	–	–	(L)	(H)	–	–	(L)	

Data length target data

Character C section

1) →

Sub-command				Year data		Month data		Day data		Hour data		Minute data		Second data		Day-of-week data	
0	0	0	0	0	9	1	0	0	1	1	8	4	6	4	9	0	4
30H	30H	30H	30H	30H	39H	31H	30H	30H	31H	31H	38H	34H	36H	34H	39H	30H	34H
(H)	–	–	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)	(H)	(L)

Data length target data

(format 9:QnA compatible 3E frame (Binary))

Subheader		Network No.	PLC No.	Request destination module I/O No.		Request destination module station No.	Request data length		Following *1
50H	00H	01H	01H	00H	00H	00H	0DH	00H	

*1

CPU monitoring timer		Command		Sub-command		Year data	Month data	Day data	Hour data	Minute data	Second data	Day-of-week data
00H	00H	01H	09H	00H	00H	09H	0AH	01H	12H	2EH	31H	04H

Data length target data

(Continued to next page)

(From previous page)

Item	Message format
Response message during normal communication (GOT → host)	(format 8:QnA compatible 3E frame (ASCII))

Subheader				Network No.		PLC No.		Request destination module I/O No.				Request destination module station No.		Following *1
D	0	0	0	0	1	0	1	0	0	0	0	0	0	
44H	30H	30H	30H	30H	31H	30H	31H	30H	30H	30H	30H	30H	30H	
(H)	–	–	(L)	(H)	(L)	(H)	(L)	(H)	–	–	(L)	(H)	(L)	

*1

	Response data length				End code			
	0	0	0	4	0	0	0	0
	30H	30H	30H	34H	30H	30H	30H	30H
	(H)	–	–	(L)	(H)	–	–	(L)

Data length target data

(format 9:QnA compatible 3E frame (Binary))

Subheader		Network No.	PLC No.	Request destination module I/O No.		Request destination module station No.	Response data length		End code	
D0H	00H	01H	01H	00H	00H	00H	02H	00H	00H	00H

Data length target data

(Continued to next page)

(From previous page)

Item	Message format
Response message during faulty communication (GOT → host)	(format 8:QnA compatible 3E frame (ASCII))

Subheader				Network No.		PLC No.		Request destination module I/O No.				Request destination module station No.		Response data length				Following *1
D	0	0	0	0	1	0	1	0	0	0	0	0	0	0	0	1	6	
44H	30H	30H	30H	30H	31H	30H	31H	30H	30H	30H	30H	30H	30H	30H	30H	31H	36H	
(H)	–	–	(L)	(H)	(L)	(H)	(L)	(H)	–	–	(L)	(H)	(L)	(H)	–	–	(L)	

*1

	End code				Network No.		PLC No.		Request destination module I/O No.				Request destination module station No.		
	0	0	5	6	0	0	0	0	0	0	0	0	0	0	→ 1)
	30H	30H	35H	36H	30H	30H	30H	30H	30H	30H	30H	30H	30H	30H	
	(H)	–	–	(L)	(H)	(L)	(H)	(L)	(H)	–	–	(L)	(H)	(L)	

Data length target data

1) →	Command				Sub-command			
	0	9	0	1	0	0	0	0
	30H	39H	30H	31H	30H	30H	30H	30H
	(H)	–	–	(L)	(H)	–	–	(L)

Data length target data

(format 9:QnA compatible 3E frame (Binary))

Subheader		Network No.	PLC No.	Request destination module I/O No.		Request destination module station No.	Response data length		Following *1
D0H	00H	01H	01H	00H	00H	00H	0BH	00H	

*1

	End code		Network No.	PLC No.	Request destination module I/O No.		Request destination module station No.	Command		Sub-command	
	56H	00H	00H	00H	00H	00H	00H	01H	09H	00H	00H

Data length target data

POINT

When a wrong day of the week has been set by the clock data setting command

If a wrong day of the week is set by the clock data setting commands, the clock data will differ from the time displayed on the utility.

Example: When October 1, 2009 (Tuesday) is set by the clock data setting command (the actual day of the week is Thursday), Thursday (THU) will be displayed on the utility time display.

■ Error code list

For the error codes, refer to the following.

☞ 3.4.6 Formats 6, 7 (4E frame) ■Error code list

3.5 GOT Side Settings

3.5.1 Setting communication interface (Communication settings)

Set the channel of the equipment to be connected to the GOT.



1. Select [Common] → [Controller Setting] from the menu.
2. The Controller Setting window is displayed. Select the channel to be used from the list menu.
3. Set the following items.
   - Manufacturer: Others
   - Controller Type: Computer
   - I/F: Interface to be used
   - Driver: Ethernet (MICROCOMPUTER)
4. The detailed setting is displayed after Manufacturer, Controller Type, I/F, and Driver are set.
   Make the settings according to the usage environment.
   ☞ 3.5.2 Communication detail settings

Click the [OK] button when settings are completed.

POINT

The settings of connecting equipment can be set and confirmed in [I/F Communication Setting]. For details, refer to the following.

☞ 1.1.2 I/F communication setting

3.5.2 Communication detail settings

Make the settings according to the usage environment.

Property	Value
GOT Net No.	1
GOT Station	1
GOT Ethernet Setting	192.168.3.18
GOT Communication Port No.	5021
Startup Time(Sec)	3
Delay Time(ms)	0
32bit Storage	LH Order
Protocol	UDP/IP
Format	1
Interrupt Data Byte	1
Special Interrupt Code	No
Living Confirmation	No
Living Confirmation Cycle(Sec)	20

Item	Description	Range
GOT NET No.	Set the network No. of the GOT. (Default: 1)	1 to 239
GOT 局番	Set the station No. of the GOT. (Default: 1)	1 to 64
GOT IP Address	Set the IP address of the GOT. (Default: 192.168.3.18)	0.0.0.0 to 255.255.255.255
GOT Communication Port No.	Set the GOT port No. for the connection with the Ethernet module. (Default: 5021)	1024 to 5010. 5014 to 65534 (Except for 5011, 5012, 5013 and 49153)
Startup Time	Specify the time period from the GOT startup until GOT starts the communication with the PLC CPU. (Default: 3sec)	3 to 255sec
Delay Time	Set the delay time for reducing the load of the network/ destination PLC. (Default: 0ms)	0 to 10000 (× 10ms)
32bit Storage	Select the steps to store two words (32-bit data). (Default: LH Order)	LH Order/ HL Order
Protocol*2	Select the communication protocol (Default: UDP/IP)	TCP/IP UDP/IP
Format	Select the communication format. (Default: 1)	1 to 9
Interrupt Data Length	Specify the number of bytes of interrupt data. (Default: 1)	1 / 2 / 4
Special Interrupt Output	Set whether or not to output the special interrupt code. (Default: none)	Yes or No

Item	Description	Range
Living Confirmation*3	Set whether or not to perform a living confirmation. (Default: No)	Yes/No
Living Confirmation Cycle*4	Set the sampling to perform a living confirmation. (Default: 20s)	10 to 100s

*2 For the interrupt output, select [TCP/IP].
*3 Select [Yes] only when [Protocol] is [TCP/IP].
*4 The setting value can be changed when the [Living Confirmation] is [Yes].

POINT

(1) Special Interrupt Code
The following shows the compatibility between the special interrupt codes and the event types.

Special Interrupt Code (Hex)	Event type
20H	Base Screen*1 and Overlap Window*1 Output when the screens are switched according to the change in the switching device values assigned to 1/2. *1: Base Screen or Overlap Window 1/2 switches independently without being interlocked. (Example of output) When all the switching device values assigned to the Base Screen and Overlap Window1/2 are changed, 3 special interrupt codes are output.
21H	Output when Numerical/ASCII Input is completed.
22H	Output when Recipe data transfer (read-out, write-in) is completed.
23H	Output when Bar code, RFID data has been imported into GOT

(1) Communication interface setting by the Utility
The communication interface setting can be changed on the Utility's [Communication setting] after writing [Communication Settings] of project data.
For details on the Utility, refer to the following manual.

GOT2000 Series User's Manual (Utility)

(2) Precedence in communication settings
When settings are made by GT Designer3 or the Utility, the latest setting is effective.

3.5.3 GOT Ethernet settings



Item	Description	Range
GOT IP Address	Set the IP address of the GOT. (Default: 192.168.0.18)	0.0.0.0 to 255.255.255.255
Subnet Mask	Set the subnet mask for the sub network. (Only for connection via router) If the sub network is not used, the default value is set. (Default: 255.255.255.0)	0.0.0.0 to 255.255.255.255
Default Gateway	Set the router address of the default gateway where the GOT is connected. (Only for connection via router) (Default: 0.0.0.0)	0.0.0.0 to 255.255.255.255
Peripheral S/W Communication Port No.	Set the GOT port No. for the S/W communication. (Default: 5015)	1024 to 5010. 5014 to 65534 (Except for 5011, 5012, 5013 and 49153)
Transparent Port No.	Set the GOT port No. for the transparent function. (Default: 5014)	1024 to 5010. 5014 to 65534 (Except for 5011, 5012, 5013 and 49153)

3.6 System Configuration Examples

The following shows a system configuration example in the case of the microcomputer connection (Ethernet).

■ System configuration

The system configuration example illustrated below is explained in this section.



■ Communication settings on GOT side and monitor screen settings

(1) Transmission settings

Set the transmission settings of the GOT.

The transmission settings in the microcomputer connection (Ethernet) are made at [Detail Setting] on GT Designer3.

☞ 3.5.2 Communication detail settings

(2) Monitor screen settings

For the monitor screen settings in this system configuration example, refer to the example of the system configuration of the microcomputer connection (serial).

☞ 2.7 System Configuration Examples

3.7 Device Range that Can Be Set

The device ranges of controller that can be used for GOT are as follows.
Note that the device ranges in the following tables are the maximum values that can be set in GT Designer3.
The device specifications of controllers may differ depending on the models, even though belonging to the same series.
Please make the setting according to the specifications of the controller actually used.
When a non-existent device or a device number outside the range is set, other objects with correct device settings may not be monitored.

■ Setting item



Item	Description
Device	Set the device name, device number, and bit number. The bit number can be set only when specifying the bit of word device.
Information	Displays the device type and setting range which are selected in [Device].

Device name		Setting range			Device No. representation
Bit device	Internal relay (M)	M0	to	M2047	Decimal
	Special relay (SM)	SM0	to	SM63	
	Latch relay (L)	L0	to	L2047	
	Word device bit	Specified bit of the following word devices			
Word device	Data register (D)	D0	to	D4095	Decimal
	Link special register (SD)	SD0	to	SD15	
	File register (R)	R0	to	R4095	
	Bit device word	Converting bit devices into word			

3.8 Precautions

■ GOT clock control

The settings of "time adjusting" or "time broadcast" made on the GOT will be disabled on the PLC.
Use the dedicated commands to set or read out the clock data of microcomputer.

■ UDP/IP connection

When the commands are sent from multiple controllers simultaneously, the GOT may not receive all the commands.
Retry sending the commands on the controller, to receive them on the GOT again.

■ Station monitoring function

The microcomputer connection (Ethernet) does not support the station monitoring function.

■ Interrupt output

The interrupt output is effective only at TCP/IP connection.
At UDP/IP connection, the interrupt output is not enabled.


MEMO

MODBUS CONNECTIONS

4. MODBUS(R)/RTU CONNECTION . . . . . 4 - 1
5. MODBUS(R)/TCP CONNECTION . . . . . 5 - 1


MEMO

4

MODBUS(R)/RTU CONNECTION

4.1 Connectable Model List . . . . . 4 - 2
4.2 System Configuration . . . . . 4 - 3
4.3 Connection Diagram . . . . . 4 - 4
4.4 GOT Side Settings . . . . . 4 - 8
4.5 MODBUS(R)/RTU Equipment Side Setting . . . . . 4 - 10
4.6 Precautions . . . . . 4 - 13

4. MODBUS(R)/RTU CONNECTION

4.1 Connectable Model List

GOT2000 Series products support the master function of MODBUS® communication, the open FA network.
Thus, the GOT can be connected with each MODBUS® slave.
For applicable MODBUS®/RTU equipment, refer to the following Technical News.

☞ List of Valid Devices Applicable for GOT2000 Series with MODBUS Connection (GOT-A-0037)

4.2 System Configuration

4.2.1 Connecting to MODBUS(R)/RTU equipment



Controller	Communication Type	Connection cable		GOT		Number of connectable equipment
		Cable model Connection diagram number	Max. distance	Option device	Model	
MODBUS®/RTU equipment	RS-232	User preparing RS-232 connection diagram 1)	15m*1	- (Built into GOT)	GT27 GT23 GS	1 MODBUS equipment for 1 GOT
				GT15-RS2-9P	GT27 GT23 GS	
	RS-422/485	User preparing RS-422/485 cable 1) (2 pair wiring)	1200m*1	FA-LTBGT2R4CBL05(0.5m)*2 FA-LTBGT2R4CBL10(1m)*2 FA-LTBGT2R4CBL20(2m)*2	GT27 GT23 GS	Up to 31 MODBUS equipment for 1 GOT *3
		User preparing RS-422/485 cable 2) (2 pair wiring)	1200m*1	- (Built into GOT)	GT27 GT23 GS	
				GT15-RS4-9S	GT27 GT23 GS	
		User preparing RS-422/485 connection diagram 3)	1200m*1	GT15-RS4-TE	GT27 GT23 GS	

*1 The shortest specification on the MODBUS®/RTU equipment side is prioritized.
*2 Product manufactured by MITSUBISHI ELECTRIC ENGINEERING COMPANY LIMITED.
For details of the product, contact MITSUBISHI ELECTRIC ENGINEERING COMPANY LIMITED.
*3 When it is less than 31 units, the number of the maximum connectable units on the MODBUS®/RTU equipment side will apply.

4.3 Connection Diagram

The following diagram shows the connection between the GOT and the PLC.

4.3.1 RS-232 cable

■ Connection diagram

(1) RS-232 connection diagram 1)



*1 Some MODBUS®/RTU equipment require the control line (CS, RS, etc.) to be controlled.
Make sure to connect the cables and wires as described in the MODBUS®/RTU equipment manual.

■ Precautions when preparing a cable

(2) Cable length
The length of the RS-232 cable must be 15m or less.

(3) GOT side connector
For the GOT side connector, refer to the following.
1.4.1 GOT connector specifications

(4) MODBUS equipment side connector
Use the connector compatible with the MODBUS®/RTU equipment side module.
For details, refer to the MODBUS®/RTU equipment user's manual.

4.3.2 RS-422/485 cable

The following shows the connection diagrams and connector specifications of the RS-422/485 cable used for connecting the GOT to a PLC.

(1) RS-422/485 cable 1) (2 pair wiring)



*1 Some MODBUS®/RTU equipment doesn't have SG.In this case, the wiring between GOT and SG is unnecessary.

*2 Some MODBUS®/RTU equipment require the control line (CS, RS, etc.) to be controlled. Make sure to connect the cables and wires as described in the MODBUS®/RTU equipment manual.

*3 A terminating resistor is required. Set the terminating resistor selector of the main unit to "Disable" and connect a 110Ω terminating resistor. (1.4.3 Terminating resistors of GOT)

*4 For the terminating resistor of MODBUS®/RTU equipment, refer to the manual of MODBUS®/RTU equipment to be used.

*5 Use the twisted pair cable for SDA1/SDB1 and RDA1/RDB1.

(2) RS-422/485 cable 1) (1 pair wiring)



*1 The actual terminal layout on the MODBUS®/RTU equipment may differ from the example shown above. SDA/B(+/-) and RDA/B(+/-) terminals can be separated from each other. Make sure to connect the cables and wires as described in the MODBUS®/RTU equipment manual.

*2 Some MODBUS®/RTU equipment doesn't have SG. In this case, the wiring between GOT and SG is unnecessary.

*3 A terminating resistor is required. Set the terminating resistor selector of the main unit to "Disable" and connect a 110Ω terminating resistor. (☞ 1.4.3 Terminating resistors of GOT)

*4 For the terminating resistor of MODBUS®/RTU equipment, refer to the manual of MODBUS®/RTU equipment to be used.

*5 Use the twisted pair cable for SDA1/SDB1.

(3) RS-422/485 cable 2) (2 pair wiring)



*1 Some MODBUS®/RTU equipment doesn't have SG. In this case, the wiring between GOT and SG is unnecessary.

*2 Some MODBUS®/RTU equipment require the control line (CS, RS, etc.) to be controlled.
Make sure to connect the cables and wires as described in the MODBUS®/RTU equipment manual.

*3 A terminating resistor is required. For GT27, set the terminating resistor selector of the main unit to "Disable" and connect a 330Ω terminating resistor. (☞ 1.4.3 Terminating resistors of GOT)

*4 For the terminating resistor of MODBUS®/RTU equipment, refer to the manual of MODBUS®/RTU equipment to be used.

(4) RS-422/485 connection diagram 3)



*1 The actual terminal layout on the MODBUS®/RTU equipment may differ from the example shown above. SDA/B(+/-) and RDA/B(+/-) terminals can be separated from each other. Make sure to connect the cables and wires as described in the MODBUS®/RTU equipment manual.

*2 Some MODBUS®/RTU equipment doesn't have SG. In this case, the wiring between GOT and SG is unnecessary.

*3 When placing the GOT to the terminal in the system configuration, set the terminating resistor to "100 OHM".
When placing the GOT to the position other than the terminal, set the terminating resistor of the GOT to "No".
1.4.3 Terminating resistors of GOT

*4 For the terminating resistor of MODBUS®/RTU equipment, refer to the manual of MODBUS®/RTU equipment.

■ Precautions when preparing a cable

(1) Cable length
The length of the RS-422/485 cable must be 1200m or less.

(2) GOT side connector
For the GOT side connector, refer to the following.
1.4.1 GOT connector specifications

(3) MODBUS®/RTU equipment side connector
Use the connector compatible with the MODBUS®/RTU equipment side module.
For details, refer to the MODBUS equipment user's manual.

■ Connecting terminating resistors

(1) GOT side
Set the terminating resistor using the terminating resistor setting switch.
For the procedure to set the terminating resistor, refer to the following.
1.4.3 Terminating resistors of GOT

(2) MODBUS®/RTU equipment side
When connecting a MODBUS®/RTU equipment to the GOT, a terminating resistor must be connected to the MODBUS®/RTU equipment.
For details, refer to the MODBUS®/RTU equipment user's manual.

4.4 GOT Side Settings

4.4.1 Setting communication interface (Communication settings)

Set the channel of the equipment to be connected to the GOT.



1. Select [Common] → [Controller Setting] from the menu.
2. The Controller Setting window is displayed. Select the channel to be used from the list menu.
3. Set the following items.
   - Manufacturer: MODBUS
   - Controller Type: MODBUS
   - I/F: Interface to be used
   - Driver: MODBUS/RTU
4. The detailed setting is displayed after Manufacturer, Controller Type, I/F, and Driver are set.
   Make the settings according to the usage environment.
   4.4.2 Communication detail settings

Click the [OK] button when settings are completed.

POINT

The settings of connecting equipment can be set and confirmed in [I/F Communication Setting]. For details, refer to the following.

1.1.2 I/F communication setting

4.4.2 Communication detail settings

Make the settings according to the usage environment.

Property	Value
Transmission Speed(BPS)	19200
Data Bit	8 bit
Stop Bit	1 bit
Parity	Even
Retry(Times)	3
Timeout Time(Sec)	3
Host Address	1
Delay Time(ms)	0
32bit Storage	LH Order
FunctionCode[0F]	Used
FunctionCode[10]	Used
Coil read times(Points)	2000
Input relay read times(Points)	2000
Holding rehister read times(Points)	125
Input register read times(Points)	125
Coil write times(Points)	800
Holding register wrtite times(Point	100

Item	Description	Range
Transmission Speed	Set this item when change the transmission speed used for communication with the connected equipment. (Default: 19200bps)	9600bps, 19200bps, 38400bps, 57600bps, 115200bps
Data Bit	Set this item when change the data length used for communication with the connected equipment. (Default: 8bits)	7bits/8bits
Stop Bit	Specify the stop bit length for communications. (Default: 1bit)	1bit/2bits
Parity	Specify whether or not to perform a parity check, and how it is performed during communication. (Default: Even)	None Even Odd
Retry	Set the number of retries to be performed when a communication error occurs. (Default: 3times)	0 to 5times
Timeout Time	Set the time period for a communication to time out. (Default: 3sec)	1 to 30sec
Host Address	Specify the host address in the network of the GOT. (Default: 1)	1 to 247
Delay Time*1	Set this item to adjust the transmission timing of the communication request from the GOT. (Default: 0ms)	0 to 300ms
32bit Storage	Select the steps to store two words (32-bit data). (Default: LH Order)	LH Order/HL Order
FunctionCode[0F]	Select the FunctionCode [0F]. (Default: Used)	Used/Unused
FunctionCode[10]	Select the FunctionCode [10]. (Default: Used)	Used/Unused
Coil read times	Set the Coil read time. (Default: 2000)	1 to 2000 points
Input relay read time	Set the Input relay read time. (Default: 2000)	1 to 2000 points
Holding register read times	Set the Holding register read times. (Default: 125)	1 to 125 points

Input register read times	Set the Input register read times. (Default: 125)	1 to 125 points
Coil write times	Set the Coil write times. (Default: 800)	1 to 1968 points
Holding register write times	Set the Holding register write times. (Default: 100)	1 to 123 points

*1 The GOT ensures in advance the minimum interval (3.5 characters time) for communication frame defined in the MODBUS®/RTU.
Therefore, the actual send delay time is as follows.

Actual send delay time = Send delay time set in the communication detail setting + 3.5 character time

Minimum interval for communication frame defined in MODBUS/RTU

When connecting to MODBUS®/RTU equipment which requires a delay longer than 3.5 character time, adjust the send delay time.

HINT

If the communication with MODBUS®/RTU equipment is not established, some equipment which requires a delay longer than 3.5 character time may be connected.
Adjust the send delay time in the communication detail setting.

POINT

(1) Communication interface setting by the Utility
The communication interface setting can be changed on the Utility's [Communication setting] after writing [Communication Settings] of project data.
For details on the Utility, refer to the following manual.
☞ GOT2000 Series User's Manual (Utility)

(2) Precedence in communication settings
When settings are made by GT Designer3 or the Utility, the latest setting is effective.

4.5 MODBUS(R)/RTU Equipment Side Setting

POINT

MODBUS®/RTU equipment

For details of the MODBUS®/RTU equipment, refer to the manual of MODBUS®/RTU equipment to be used.

4.5.1 Communication settings

■ Device setting items for GT Designer3



Item		Description
Device		Set the device name, device number, and bit number. The bit number can be set only when specifying the bit of word device.
	File No.	Set the file No. The file No. can be set only when select 6 at [Device].
Information		Displays the device type and setting range which are selected in [Device].
Network		Set the station number of the controller to be monitored.
	Host	Select this item for monitoring the host controller.
	Other	Select this for monitoring other controllers. After selecting the item, set the station number and network number of the controller to be monitored. NW No.: For the MODBUS®/RTU connection, set "1". For the MODBUS®/TCP connection, set the network No. Station No.: Set the station No.

■ Function Code

The GOT supports the following function codes.

Function Code	Function	Number of device that is accessible with one message [Unit: point(s)]
0x01	Read Coils	1 to 2000
0x02	Read Discrete Inputs	1 to 2000
0x03	Read Holding Registers	1 to 125
0x04	Read Input Registers	1 to 125
0x05	Write Single Coil	1
0x06	Write Single Register	1
0x0F	Write Multiple Coils	1 to 1968
0x10	Write Multiple Register	1 to 123
0x14	Read File Record	1 to 124
0x15	Write File Record	1 to 122

■ Address

GT Designer3 converts the device numbers into decimal format according to the address map of the MODBUS®/RTU equipment to be used.

The table below shows the representations on the MODBUS®/RTU communication protocol and GT Designer3.

MODBUS/RTU Communication protocol				Representation on GT Designer3
Device name	Function code to be used		Address	
	Read	Write		
Coil	0x01	0x05 0x0F	0000 0001 to FFFE FFFF	000001 000002 to 065535 065536
Input relay	0x02	-	0000 0001 to FFFE FFFF	100001 100002 to 165535 165536
Input register	0x04	-	0000 0001 to FFFE FFFF	300001 300002 to 365535 365536
Holding register	0x03	0x06 0x10	0000 0001 to FFFE FFFF	400001 400002 to 465535 465536
Extension file register	0x14	0x15	0000 0001 to 270E 270F	600000 600001 to 609998 609999

POINT

Address conversion example

When monitoring the holding register's address "1234H", GT Designer3 displays "4*****" since GT Designer3 processes the internal conversion in decimal format as follows:

GT Designer3 converts the holding register's address "1234H" to "04660" in decimal format.

Then, "+1" is added to this decimal address since the holding register's address on GT Designer3 always starts from "1."

Therefore, the holding register's address "1234H" is displayed as "404661" on GT Designer3.



■ MODBUS communication control function on the GS device

(1) Function overview

This function is to prevent the communication response delay that occurs because the devices on the MODBUS network differs from each other in network specification.

This function is effective for the MODBUS network conditions as described below:

- When only a part of function codes is supported (Example: "0F" is not supported)
- When the maximum transfer size of function code is small (Example: The maximum number of coil read times is 1000)

(2) Communication setting

When the MODBUS/RTU communication driver is assigned to multiple channel numbers using the multi-channel function, the following cases are possible. The communication settings are shared between the assigned multiple channel numbers, or the individual communication setting is configured to a specific channel number.

By setting the device GS579, either the GS device used for sharing communication settings (GS570 to GS576) or the GS device used for individual communication setting (GS590 to GS617) is validated.

GS device	Description	Set value
GS579	Validity of setting channel number	Bit0: 0 Configure the Ch1 communication settings between GS570 to GS576. 1 Configure the Ch1 communication settings between GS590 to GS596. Bit1: 0 Configure the Ch2 communication settings between GS570 to GS576. 1 Configure the Ch2 communication settings between GS590 to GS603. Bit2: 0 Configure the Ch3 communication settings between GS570 to GS576. 1 Configure the Ch3 communication settings between GS604 to GS610 Bit3: 0 Configure the Ch4 communication settings between GS570 to GS576. 1 Configure the Ch4 communication settings between GS611 to GS617.

For details of GS devices (GS570 to GS576) and GS devices (GS590 to GS617), refer to the next page.

(a) When sharing communication settings between multiple channel numbers
The table below shows the settings for the GS device.

GS device	Description	Set value
GS570	Command selection	Bit0: 0 Using Function Code "0F" 1 Not using Function Code "0F" Bit1: 0 Using Function Code "10" 1 Not using Function Code "10"
GS571	Function Code "01" Specification for the max. number of coil read times	0:2000 1 to 2000: Specify the maximum number. Other than above: 2000
GS572	Function Code "02" Specification for the max. number of input relay read times	0:2000 1 to 2000: Specify the maximum number. Other than above: 2000
GS573	Function Code "03" Specification for the max. number of holding register read times	0:125 1 to 125: Specify the maximum number. Other than above: 125
GS574	Function Code "04" Specification for the max. number of input register read times	0:125 1 to 125: Specify the maximum number. Other than above: 125
GS575	Function Code "0F" Specification for the max. number of multiple-coil write times	0:800 1 to 1968: Specify the maximum number. Other than above: 1968 When Bit0 of GS570 is "1", the function code "0F" is not used, and therefore the setting of GS575 will be disabled.
GS576	Function Code "10" Specification for the max. number of multiple-holding register write times	0:100 1 to 123: Specify the maximum number. Other than above: 123 When Bit1 of GS570 is "1", the function code "10F" is not used, and therefore the setting of GS576 will be disabled.

(b) When configuring individual communication settings for specific channel numbers
The table below shows the settings for the GS device.

GS device				Description	Set value
Ch1	Ch2	Ch3	Ch4		
GS590	GS597	GS604	GS611	Command selection	Bit0: 0 Using Function Code "0F" 1 Not using Function Code "0F" Bit1: 0 Using Function Code "10" 1 Not using Function Code "10"
GS591	GS598	GS605	GS612	Function Code "01" Specification for the max. number of coil read times	0:2000 1 to 2000: Specify the maximum number. Other than above: 2000
GS592	GS599	GS606	GS613	Function Code "02" Specification for the max. number of input relay read times	0:2000 1 to 2000: Specify the maximum number. Other than above: 2000
GS593	GS600	GS607	GS614	Function Code "03" Specification for the max. number of holding register read times	0:125 1 to 125: Specify the maximum number. Other than above: 125
GS594	GS601	GS608	GS615	Function Code "04" Specification for the max. number of input register read times	0:125 1 to 125: Specify the maximum number. Other than above: 125
GS595	GS602	GS609	GS616	Function Code "0F" Specification for the max. number of multiple-coil write times	0:800 1 to 1968: Specify the maximum number. Other than above: 1968 When Bit0 of GS570 is "1", the function code "0F" is not used, and therefore the setting of GS575 will be disabled.
GS596	GS603	GS610	GS617	Function Code "10" Specification for the max. number of multiple-holding register write times	0:100 1 to 123: Specify the maximum number. Other than above: 123 When Bit1 of GS570 is "1", the function code "10F" is not used, and therefore the setting of GS576 will be disabled.

4.5.2 Station number setting

In the MODBUS network, a maximum of 31 MODBUS®/RTU equipment can be connected to one GOT.

Assign a non-overlapped station number ranging from 1 to 247 arbitrarily to each MODBUS®/RTU equipment.

In the system configuration, the MODBUS®/RTU equipment with the station number set with the host address must be included.

The station number can be set without regard to the cable connection order. There is no problem even if station numbers are not consecutive.



Examples of station number setting

4.6 Precautions

■ Reading the holding registers

The GOT reads the holding registers (400001) for checking whether the GOT can communicate with the controller.
Therefore, if the equipment does not have holding registers (400001), normal communication may not be performed.

■ Station No. settings of the MODBUS®/RTU equipment side

In the system configuration, the MODBUS®/RTU equipment with the station number set with the host address must be included.For details of host address setting, refer to the following.

☞ 4.4.1 Setting communication interface (Communication settings)

■ GOT clock control

The settings of "time adjusting" or "time broadcast" made on the GOT will be disabled on the PLC.

■ Disconnecting some of multiple connected equipment

The GOT can disconnect some of multiple connected equipment by setting GOT internal device. For example, the faulty station where a communication timeout error occurs can be disconnected from connected equipment. For details of GOT internal device setting, refer to the following manual.

☞ GT Designer3 (GOT2000) Help

■ MODBUS communication control function on the GS device

At GOT startup, set MODBUS communication control function with project scripts, etc.
If settings are changed after communication start, a communication error may occur.



Setting example for project script


MEMO

5

MODBUS(R)/TCP CONNECTION

5.1 Connectable Model List . . . . . 5 - 2
5.2 System Configuration . . . . . 5 - 3
5.3 GOT Side Settings . . . . . 5 - 4
5.4 MODBUS(R)/TCP Equipment Setting . . . . . 5 - 7
5.5 Device Range that Can Be Set . . . . . 5 - 7
5.6 Example of Connection . . . . . 5 - 11
5.7 Precautions . . . . . 5 - 16

5. MODBUS(R)/TCP CONNECTION

5.1 Connectable Model List

GOT2000 Series products support the master function of MODBUS®/TCP communication, the open FA network.
Thus, the GOT can be connected with each MODBUS®/TCP slave.
For applicable MODBUS®/TCP equipment, refer to the following Technical News.

☞ List of Valid Devices Applicable for GOT2000 Series with MODBUS Connection (GOT-A-0037)

5.2 System Configuration

5.2.1 Connecting to MODBUS(R)/TCP equipment



Controller	Communication Type	Connection cable		External device	Connection cable		GOT*2		Number of connectable equipment
		Cable model*4	Maximum segment length*3		Cable model*4	Maximum segment length*3	Option device	GOT model	
MODBUS® /TCP equipment	Ethernet	• 100BASE-TX Shielded twisted pair cable (STP) or unshielded twisted pair cable (UTP) of category 5 or higher • 10BASE-T Shielded twisted pair cable (STP) or unshielded twisted pair cable (UTP) of category 3 or higher	100m	Hub*1	• 100BASE-TX Shielded twisted pair cable (STP) or unshielded twisted pair cable (UTP) of category 5 or higher • 10BASE-T Shielded twisted pair cable (STP) or unshielded twisted pair cable (UTP) of category 3 or higher	100m	- (Built into GOT)	GT27 GT23 GS	When controller:GOT is N:1 The number of controllers for 1 GOT is TCP: 128 or less. When controller:GOT is 1:N The following shows the number of GOTs for 1 controller Depends on the MODBUS®/TCP equipment used.*5

*1 Connect the GOT to the MODBUS®/TCP equipment via a hub.
Use cables, connectors, and hubs that meet the IEEE802.3 10BASE-T/100BASE-TX standards.

*2 When connecting GT2000 to an equipment that meets the 10BASE (-T/2/5) standard, use the switching hub and operate in an environment where 10Mbps and 100Mbps can be mixed.

*3 A length between a hub and a node.
The maximum distance differs depending on the Ethernet device to be used.
The following shows the number of the connectable nodes when a repeater hub is used.
- 10BASE-T: Max. 4 nodes for a cascade connection (500m)
- 100BASE-TX: Max. 2 nodes for a cascade connection (205m)

When switching hubs are used, the cascade connection between the switching hubs has no logical limit for the number of cascades.
For the limit, contact the switching hub manufacturer.

*4 Use the straight cable.

*5 For details, refer to the MODBUS®/TCP equipment manual.

5.3 GOT Side Settings

5.3.1 Setting communication interface (Communication settings)

Set the channel of the equipment to be connected to the GOT.



1. Select [Common] → [Controller Setting] from the menu.
2. The Controller Setting window is displayed. Select the channel to be used from the list menu.
3. Set the following items.
   - Manufacturer: MODBUS
   - Controller Type: MODBUS
   - I/F: Interface to be used
   - Driver: MODBUS/TCP, Gateway
4. The detailed setting is displayed after Manufacturer, Controller Type, I/F, and Driver are set.
   Make the settings according to the usage environment.
   5.3.2 Communication detail settings

Click the [OK] button when settings are completed.

POINT

The settings of connecting equipment can be set and confirmed in [I/F Communication Setting].For details, refer to the following.

1.1.2 I/F communication setting

5.3.2 Communication detail settings

Make the settings according to the usage environment.

Property	Value
GOT Net No.	1
GOT Station	1
GOT Ethernet Setting	192.168.3.18
GOT Communication Port No.	5020
Startup Time(Sec)	3
Timeout Time(Sec)	3
Delay Time(ms)	0
32bit Storage	LH Order
FunctionCode[0F]	Used
FunctionCode[10]	Used
Coil read times(Points)	1000
Input relay read times(Points)	1000
Holding rehister read times(Points)	125
Input register read times(Points)	125
Coil write times(Points)	800
Holding register wrtite times(Point	100

Item	Description	Range
GOT Net No.	Set the network No. of the GOT. (Default: 1)	1 to 239
GOT Station	Set the station No. of the GOT. (Default: 1)	1 to 247
GOT Ethernet Setting	Set the GOT IP address, subnet mask, default gateway, peripheral S/W communication port No., transparent port No	5.3.3GOT Ethernet Setting
GOT Communication Port No.	Set the GOT port No. for the connection with the Ethernet module. (Default: 5020)	1024 to 5010, 5014 to 65534 (Except for 5011, 5012, 5013 and 49153)
Startup Time	Specify the time period from the GOT startup until GOT starts the communication with the PLC CPU. (Default: 3sec)	3 to 255sec
Timeout Time	Set the time period for a communication to time out. (Default: 3sec)	3 to 90sec
Delay Time	Set the delay time for reducing the load of the network/destination PLC. (Default: 0ms)	0 to 10000 (× 10 ms)
32bit Storage	Select the steps to store two words (32-bit data). (Default: LH Order)	LH Order/HL Order
FunctionCode[0F]	Set whether to use the function code [0F]. (Default: Used)	Used/Unused
FunctionCode[10]	Set whether to use the function code [10]. (Default: Used)	Used/Unused
Coil read times	Set the read points of the coil. (Default: 1000 points)	1 to 2000 (points)
Input relay read times	Set the read points of the input relay. (Default: 1000 points)	1 to 2000 (points)

Holding registor read times	Set the read points of the holding register. (Default: 125 points)	1 to 125 (points)
Input register read times	Set the read points of the input register. (Default: 125 points)	1 to 125 (points)
Coil write times	Set the write points of the coil. (Default: 800 points)	1 to 800(points)
Holding register write times	Set the write points of the holding register. (Default: 100 points)	1 to 100(points)

POINT

(1) Communication interface setting by the Utility
The communication interface setting can be changed on the Utility's [Communication setting] after writing [Communication Settings] of project data.
For details on the Utility, refer to the following manual.

☞ GOT2000 Series User's Manual (Utility)

(2) Precedence in communication settings
When settings are made by GT Designer3 or the Utility, the latest setting is effective.

5.3.3 GOT Ethernet Setting



Item	Description	Range
GOT IP Address	Set the IP address of the GOT. (Default: 192.168.0.18)	0.0.0.0 to 255.255.255.255
Subnet Mask	Set the subnet mask for the sub network.(Only for connection via router) If the sub network is not used, the default value is set. (Default: 255.255.255.0)	0.0.0.0 to 255.255.255.255
Default Gateway	Set the router address of the default gateway where the GOT is connected.(Only for connection via router) (Default: 0.0.0.0)	0.0.0.0 to 255.255.255.255
Peripheral S/W Communicatio n Port No.	Set the GOT port No. for the S/W communication. (Default: 5015)	1024 to 5010, 5014 to 65534 (Except for 5011, 5012, 5013, and 49153)
Transparent Port No.	Set the GOT port No. for the transparent function. (Default: 5014)	1024 to 5010, 5014 to 65534 (Except for 5011, 5012, 5013, and 49153)

5.3.4 Ethernet setting



Item	Description	Range
Host	The host is displayed.(The host is indicated with an asterisk (*).)	—
N/W No.	Set the network No. of the connected Ethernet module. (Default: blank)	1 to 239
PLC No.	Set the station No. of the connected Ethernet module. (Default: blank)	1 to 247
Type*1	MODBUS/TCP (fixed)	MODBUS/TCP (fixed)
IP Address	Set the IP address of the connected Ethernet module. (Default: blank)	PLC side IP address
Port No.	502 (fixed)	502 (fixed)
Communication format	TCP (fixed)	TCP (fixed)

*1 Select [MODBUS/TCP] for [Controller Type].
For the applicable Ethernet module, refer to the following.

5.2 System Configuration

POINT

Changing the host with GOT module

The host can be changed by the GOT module Utility. For details of settings, refer to the following.

GOT2000 Series User's Manual (Utility)



5.4 MODBUS(R)/TCP Equipment Setting

For details of the MODBUS®/TCP equipment, refer to the manual of MODBUS®/RTU equipment to be used.

5.5 Device Range that Can Be Set

The device ranges of controller that can be used for GOT are as follows.
Note that the device ranges in the following tables are the maximum values that can be set in GT Designer3.
The device specifications of controllers may differ depending on the models, even though belonging to the same series.
Please make the setting according to the specifications of the controller actually used.
When a non-existent device or a device number outside the range is set, other objects with correct device settings may not be monitored.

■ Setting item



Item	Description	
Device	Set the device name, device number, and bit number. The bit number can be set only when specifying the bit of word device.	
	File No.	Set the file No. The file No. can be set only when select 6 at [Device].
Information	Displays the device type and setting range which are selected in [Device].	
Network	Set the station number of the controller to be monitored.	
	Host	Select this item for monitoring the host controller.
	Other	Select this for monitoring other controllers. After selecting the item, set the station number and network number of the controller to be monitored. NW No.: For the MODBUS® /RTU connection, set "1". For the MODBUS®/TCP connection, set the network No. Station No.: Set the station No.

	Device name	Setting range	Device No. representation
Bit device	Coils (0)	000001 to 065536	Decimal
	Discretes input (1)*1	100001 to 165536	
Word device	Input registers (3)*1	300001 to 365536	Decimal
	Holding registers (4)	400001 to 465536	
	Extension file register (6)	File No.: 0 to104 600000 to 609999	

*1 Only reading is possible.

POINT

(1) Range of coils and input relays that can be monitored
The device range of MODBUS equipment differs depending on the type.
When using types that the device range for coils and input relays are other than hexadecimal, monitoring to the device maximum range may not be possible.
In this case, the device range extends to the last number divisible by 16.
Example: For a type whose coil device range is from 0 to 9999.
The range that can be actually monitored is from 0 to 9984.

(2) Address conversion example
When monitoring the holding register's address "1234H", GT Designer3 displays "4*****" since GT Designer3 processes the internal conversion in decimal format as follows:
GT Designer3 converts the holding register's address "1234H" to "04660" in decimal format.
Then, "+1" is added to this decimal address since the holding register's address on GT Designer3 always starts from "1."
Therefore, the holding register's address "1234H" is displayed as "404661" on GT Designer3.



■ MODBUS communication control function on the GS device

(1) Function overview

This function is to prevent the communication response delay that occurs because the devices on the MODBUS network differ from each other in network specification.

This function is effective for the MODBUS network conditions as described below:

When only a part of function codes is supported (Example: "0F" is not supported)

When the maximum transfer size of function code is small (Example: The maximum number of coil read times is 1000)

(2) Communication setting

When the MODBUS®/TCP communication driver is assigned to multiple channel numbers using Ethernet multiple connection, the following cases are possible. The communication settings are shared between the assigned multiple channel numbers, or the individual communication setting is configured for a specific channel number.

By setting the device GS579, either the GS device used for sharing communication settings (GS570 to GS576) or the GS device used for individual communication setting (GS590 to GS617) is validated.

GS device	Description	Set value
GS579	Validity of setting channel number	Bit0: 0 Configure the Ch1 communication settings between GS570 to GS576. 1 Configure the Ch1 communication settings between GS590 to GS596. Bit1: 0 Configure the Ch2 communication settings between GS570 to GS576. 1 Configure the Ch2 communication settings between GS590 to GS603. Bit2: 0 Configure the Ch3 communication settings between GS570 to GS576. 1 Configure the Ch3 communication settings between GS604 to GS610 Bit3: 0 Configure the Ch4 communication settings between GS570 to GS576. 1 Configure the Ch3 communication settings between GS611 to GS617.

For details of GS devices (GS570 to GS576) and GS devices (GS590 to GS617), refer to the next page.

(a) When sharing communication settings between multiple channel numbers
The table below shows the settings for the GS device.

GS device	Description	Set value
GS570	Command selection	Bit0: 0 Using Function Code "0F" 1 Not using Function Code "0F" Bit1: 0 Using Function Code "10" 1 Not using Function Code "10"
GS571	Function Code "01" Specification for the max. number of coil read times	0:1000 1 to 2000: Specify the maximum number. Other than above: 2000
GS572	Function Code "02" Specification for the max. number of input relay read times	0:1000 1 to 2000: Specify the maximum number. Other than above: 2000
GS573	Function Code "03" Specification for the max. number of holding register read times	0:125 1 to 125: Specify the maximum number. Other than above: 125
GS574	Function Code "04" Specification for the max. number of input register read times	0:125 1 to 125: Specify the maximum number. Other than above: 125
GS575	Function Code "0F" Specification for the max. number of multiple-coil write times	0:800 1 to 800: Specify the maximum number. Other than above: 800 When Bit0 of GS570 is "1", the function code "0F" is not used, and therefore the setting of GS575 will be disabled.
GS576	Function Code "10" Specification for the max. number of multiple-holding register write times	0:100 1 to 100: Specify the maximum number. Other than above: 100 When Bit1 of GS570 is "1", the function code "10F" is not used, and therefore the setting of GS576 will be disabled.

(b) When configuring individual communication settings for specific channel numbers
The table below shows the settings for the GS device.

GS device				Description	Set value
Ch1	Ch2	Ch3	Ch4		
GS590	GS597	GS604	GS611	Command selection	Bit0: 0 Using Function Code "0F" 1 Not using Function Code "0F" Bit1: 0 Using Function Code "10" 1 Not using Function Code "10"
GS591	GS598	GS605	GS612	Function Code "01" Specification for the max. number of coil read times	0:1000 1 to 2000: Specify the maximum number. Other than above: 2000
GS592	GS599	GS606	GS613	Function Code "02" Specification for the max. number of input relay read times	0:1000 1 to 2000: Specify the maximum number. Other than above: 2000
GS593	GS600	GS607	GS614	Function Code "03" Specification for the max. number of holding register read times	0:125 1 to 125: Specify the maximum number. Other than above: 125
GS594	GS601	GS608	GS615	Function Code "04" Specification for the max. number of input register read times	0:125 1 to 125: Specify the maximum number. Other than above: 125
GS595	GS602	GS609	GS616	Function Code "0F" Specification for the max. number of multiple-coil write times	0:800 1 to 800: Specify the maximum number. Other than above: 800 When Bit0 of GS570 is "1", the function code "0F" is not used, and therefore the setting of GS575 will be disabled.
GS596	GS603	GS610	GS617	Function Code "10" Specification for the max. number of multiple-holding register write times	0:100 1 to 100: Specify the maximum number. Other than above: 100 When Bit1 of GS570 is "1", the function code "10F" is not used, and therefore the setting of GS576 will be disabled.

5.6 Example of Connection

5.6.1 Connecting to SCHNEIDER PLC (Modicon Premium series and Modicon Quantum series)

■ System Configuration



controller	Ethernet module*4	Communication Type	Connection cable		External device	Connection cable		GOT*2		Number of connectable equipment
			Cable model*5	Max. distance*3		Cable model*5	Max. distance*3	Option device	GOT model	
Modicon Premium Series	TSX ETY 4102 TSX ETY 5102	Ethernet	• 100BASE-TX Shielded twisted pair cable (STP) or unshielded twisted pair cable (UTP) of category 5 or higher • 10BASE-T Shielded twisted pair cable (STP) or unshielded twisted pair cable (UTP) of category 3 or higher	100m	Hub*1	• 100BASE-TX Shielded twisted pair cable (STP) or unshielded twisted pair cable (UTP) of category 5 or higher • 10BASE-T Shielded twisted pair cable (STP) or unshielded twisted pair cable (UTP) of category 3 or higher	100m	- (Built into GOT)	GT27 GT23 GS	64 GOTs for 1 PLC
Modicon Quantum Series	140 NOE 771 00 140 NOE 771 10 140 NWM 100 00									

*1 Connect the GOT to the Ethernet module via a hub.
Use cables, connectors, and hubs that meet the IEEE802.3 10BASE-T/100BASE-TX standards.

*2 When connecting GT2000 to an equipment that meets the 10BASE (-T/2/5) standard, use the switching hub and operate in an environment where 10Mbps and 100Mbps can be mixed.

*3 A length between a hub and a node.
The maximum distance differs depending on the Ethernet device to be used.
The following shows the number of the connectable nodes when a repeater hub is used.
- 10BASE-T: Max. 4 nodes for a cascade connection (500m)
- 100BASE-TX: Max. 2 nodes for a cascade connection (205m)

When switching hubs are used, the cascade connection between the switching hubs has no logical limit for the number of cascades.
For the limit, contact the switching hub manufacturer.

*4 Product manufactured by SCHNEIDER ELECTRIC SA.For details of the product, contact SCHNEIDER ELECTRIC SA.

*5 Use the straight cable.

■ PLC Side Setting

POINT

SCHNEIDER ELECTRIC PLC

For details of SCHNEIDER PLC, refer to the following manual.

☞ SCHNEIDER PLC user's Manual

(1) Parameter settings

Set the parameter settings with programming software for SCHNEIDER PLC.

(a) For Modicon Premium series

Set for PL7 Pro programming software.

Item	Set value
Processors	Connected CPU module
Memory cards	Memory card to be used
Module	Connected Ethernet module
IP Address	IP address for Ethernet module
Size of global address fields	Setting for device points Bits: Coil, Input Words: Input register, Maintenance register

(b) For Modicon Quantum series

Set for Concept programming software.

Item	Set value
PLC Selection	Connected CPU module
TCP/IP Ethernet	Numbers of unit
I/O Module Selection	Connected Ethernet module
Internet Address	IP address for Ethernet module

5.6.2 Connecting to YOKOGAWA PLC (STARDOM)

■ System Configuration



controller	Communication Type	Connection cable		External device	Connection cable		GOT*3		Number of connectable equipment
		Cable model*5	Max. distance*4		Cable model*5	Max. distance*4	Option device	GOT Model	
STARDOM*1 (NFCP100, NFJT100)	Ethernet	Twisted pair cable • 10BASE-T Shielded twisted pair cable (STP) or unshielded twisted pair cable (UTP): Category 3, 4, and 5 • 100BASE-TX Shielded twisted pair cable (STP): Category 5 and 5e	100m	Hub*2	Twisted pair cable • 10BASE-T Shielded twisted pair cable (STP) or unshielded twisted pair cable (UTP): Category 3, 4, and 5 • 100BASE-TX Shielded twisted pair cable (STP): Category 5 and 5e	100m	- (Built into GOT)	GT27 GT23 GS	126 GOTs for 1 PLC

*1 When connecting STARDOM to MODBUS®/TCP, Modbus Communication Portfolio License is required.
For details, refer to the following manual.

☞ YOKOGAWA PLC user's Manual

*2 When connect a GOT to a PLC, connect to the PCL Ethernet port via a hub.
Use cables, connectors, and hubs that meet the IEEE802.3 10BASE-T/100BASE-TX standards.

*3 When connecting GT2000 to an equipment that meets the 10BASE (-T/2/5) standard, use the switching hub and operate in an environment where 10Mbps and 100Mbps can be mixed.

*4 A length between a hub and a node.
The maximum distance differs depending on the Ethernet device to be used.
The following shows the number of the connectable nodes when a repeater hub is used.
- 10BASE-T: Max. 4 nodes for a cascade connection (500m)
- 100BASE-TX: Max. 2 nodes for a cascade connection (205m)

When switching hubs are used, the cascade connection between the switching hubs has no logical limit for the number of cascades.
For the limit, contact the switching hub manufacturer.

*5 Use the straight cable.

■ PLC Side Setting

Make the communication settings as shown below. For details of the communication settings, refer to the following manual.

☞ Peripheral Software Manual for YOKOGAWA PLC

POINT

Connection between STARDOM and the PC for communication settings

For the communication settings of STARDOM, STARDOM and the PC for communication settings must be connected to Ethernet using the Resource Configurator (peripheral software).

(1) Modbus Communication Portfolio License

To set the communication settings for STARDOM, an installation of Modbus Communication Portfolio License is required.

For details of the communication settings, refer to the following manual.

☞ STARDOM FCN/FCJ Guide

(2) Defining Logic POU

Define Logic POU using Logic Designer (peripheral software), and download the project to STARDOM.

(a) Start Logic Designer and create a new project using a template.
Use [STARDOM Serial Communication] template.

(b) Insert Firmware Library to the new project.
- Right-click [Library] under the project tree in Logic Designer.
- Right-click [Insert] and select [Firmware Library].
- Double-click the [SD_FCXPLCE_LIB] folder and double-click [SD_FCXPLCE_LIB.fwl] to select it.
- The library path inserted in the procedures above is as follows.
  {Install Folder}\LogicDesigner\Mwt\Plc\Fw_lib\SD_FCXPLCE_LIB\SD_FCXPLCE_LIB.fwl

(c) Insert User Library to the new project.
- Right-click [Library] under the project tree in Logic Designer.
- Right-click [Insert] and select [User Library].
- Double-click [SD_CMODBUSE_PF.mwt], [SD_CUTIL_PF.mwt] and [SD_CMODBUSS_PF.mwt] to select it.
  (When [STARDOM Serial Communication] is used for the template, [SD_CUTIL_PF.mwt] is inserted as default.)
- The library path inserted in the procedures above is as follows.
  {Install Folder}\LogicDesigner\Libraries\SD_CMODBUSE_PF.mwt
  {Install Folder}\LogicDesigner\Libraries\SD_CUTIL_PF.mwt
  {Install Folder}\LogicDesigner\Libraries\SD_CMODBUSS_PF.mwt

(d) Copy a sample project POU to the new project.
- Open "SD_CMODBUSE_Sample1.mwt".
- Right-click [ComEServerModbus*] in the Logic POU under the project tree in the SD_CMODBUSE_Sample1 project, and select [Copy].
- Right-click the [Logic POU] under the project tree in the previously created project, and select [Paste].
- Double-click the [ComEServerModbus*] file in the [ComEServerModbus*] folder.
- For the following terminals, set as shown below.



(e) Set devices to be monitored by a GOT.
- Right-click the [ComEServerModbus*] file in the [ComEServerModbus*] folder in the logic POU under the project tree and select [Insert] - [Cord worksheet].
- Set the variable devices to be monitored.
  Instantiate Logic POU.Define an already defined instance to Task0.
- Right-click [Physical hardware] - [Configuration:IPC_33/FCX01:FCX/Tasks/Task0:CYCLIC] and select [Insert] - [Program instance].
- Define the program instance name and select ComEServerModbus for the program type.

(f) Defining Target Setting
Define the IP address of STARDOM to set the communication settings.
Double-click [Physical hardware] - [Configuration:IPC_33/FCX01:FCX/Target Setting] and input the IP address or the host name.

(g) Downloading the project
- Execute [Build] - [Make].
  (Same as when pressing the function key F9).
- Download after confirming that the compile error does not occur. Select [Download] in the project control dialog displayed when [Online] - [Project control] is selected.
- When the download is completed, select [Cold] and start STARDOM.

■ Device range

When performing monitoring with the GOT connected to a YOKOGAWA PLC and setting devices for objects, use devices within the device range of the YOKOGAWA PLC.
When a device outside the range is set on an object, an indefinite value is displayed on the object.
(No error is displayed in the system alarm.)
For details on the device range of YOKOGAWA PLCs, refer to the following manual:

☞ YOKOGAWA PLC user's Manual

■ Precautions

(1) For dual-redundant configuration
When STARDOM is configured with a redundant system, the connection is not supported.

(2) Not communicating with GOT and STARDOM in a specified period
When the GOT does not communicate with STARDOM in a specified period during the GOT is turned on, STARDOM disconnects the line for the GOT. As the line is disconnected, the GOT displays an error when the GOT monitors STARDAM after the disconnection.
After the error displayed as the system alarm (No.402: timeout error) on the GOT, the normal communication is recovered and the GOT can monitor STARDOM.

5.7 Precautions

■ When connecting to multiple GOTs

(1) Setting PLC No.

When connecting two or more GOTs in the MODBUS®/TCP network, set each [PLC No.] to the GOT.

☞ 5.3.1 Setting communication interface (Communication settings)

(2) Setting IP address

Do not use the IP address "192.168.3.18" when using multiple GOTs.
A communication error may occur on the GOT with the IP address.

■ When setting IP address

Do not use "0" and "255" at the end of an IP address.

(Numbers of *.*.*.0 and *.*.*.255 are used by the system)

The GOT may not monitor the controller correctly with the above numbers.

Consult with the administrator of the network before setting an IP address to the GOT and controller.

■ When connecting to the multiple network equipment (including GOT) in a segment

By increasing the network load, the transmission speed between the GOT and PLC may be reduced.

The following actions may improve the communication performance.

- Using a switching hub
- More high speed by 100BASE-TX (100Mbps)
- Reduction of the monitoring points on GOT

■ MODBUS communication control function on the GS device

At GOT startup, set MODBUS communication control function with project scripts, etc.
If settings are changed after communication start, a communication error may occur.



Setting example for project script

CONNECTIONS TO PERIPHERAL EQUIPMENT

6. CONNECTION TO SOUND OUTPUT UNIT . . . . . 6 - 1
7. CONNECTION TO EXTERNAL I/O DEVICE . . . . . 7 - 1
8. BAR CODE READER CONNECTION . . . . . 8 - 1
9. PC REMOTE CONNECTION . . . . . 9 - 1
10. VNC(R) SERVER CONNECTION . . . . . 10 - 1
11. VIDEO/RGB CONNECTION . . . . . 11 - 1
12. PRINTER CONNECTION . . . . . 12 - 1
13. MULTIMEDIA CONNECTION . . . . . 13 - 1
14. RFID CONNECTION . . . . . 14 - 1
15. WIRELESS LAN CONNECTION . . . . . 15 - 1


MEMO

6

CONNECTION TO SOUND OUTPUT UNIT

6.1 Connectable Model List . . . . . 6 - 2
6.2 System Configuration . . . . . 6 - 2
6.3 GOT Side Settings . . . . . 6 - 3
6.4 Precautions . . . . . 6 - 4

6. CONNECTION TO SOUND OUTPUT UNIT

6.1 Connectable Model List

For applicable speakers, refer to the following Technical News.

☞ List of valid devices applicable for GOT2000 series (GOT-A-0064)

6.2 System Configuration

6.2.1 Connecting to sound output unit



Speaker	Connection cable	GOT		PLC	Number of connectable equipment
Model name		Option device	Model		
For applicable speakers, refer to the following Technical News. ☞ List of valid devices applicable for GOT2000 series (GOT-A-0064)		GT15-SOUT	GT27 GT23 GS	For the system configuration between the GOT and PLC, refer to each chapter.	1 speaker for 1 GOT

HINT

System configuration between the GOT and PLC

For the system configuration between the GOT and PLC, refer to each chapter.

☞ Mitsubishi Products

☞ Non-Mitsubishi Products 1, Non-Mitsubishi Products 2

☞ Microcomputer, MODBUS Products, Peripherals

6.3 GOT Side Settings

6.3.1 Setting communication interface

■ Controller setting

Set the channel of the equipment to be connected to the GOT.



1. Select [Common] → [Controller Setting] from the menu.
2. The Controller Setting window is displayed. Select the channel to be used from the list menu.
3. Set Manufacturer, Controller Type, I/F, and Driver according to the connected equipment to be used.
4. The detailed setting is displayed after Manufacturer, Controller Type, I/F, and Driver are set.
   Make the settings according to the usage environment.

Click the [OK] button when settings are completed.

POINT

The settings of connecting equipment can be set and confirmed in [II/F Communication Setting]. For details, refer to the following.

1.1.2 I/F communication setting

■ Sound output unit setting



1. Select [Common] → [Peripheral Setting] → [Sound Output] from the menu.
2. Set the interface to which the sound output unit is connected.

Click the [OK] button when settings are completed.

POINT

(1) Communication interface setting by the Utility
The communication interface setting can be changed on the Utility's [Communication setting] after writing [Communication Settings] of project data.
For details on the Utility, refer to the following manual.

GOT2000 Series User's Manual (Utility)

(2) Precedence in communication settings
When settings are made by GT Designer3 or the Utility, the latest setting is effective.

6.4 Precautions

■ Sound output function setting on GT Designer3

Before connecting the sound output unit, make the sound output file setting.

For details, refer to the following manual.

☞ GT Designer3 (GOT2000) Help

7

CONNECTION TO EXTERNAL I/O DEVICE

7.1 Connectable Model List . . . . . 7 - 2
7.2 System Configuration . . . . . 7 - 3
7.3 Connection Diagram . . . . . 7 - 5
7.4 GOT Side Settings . . . . . 7 - 14
7.5 Precautions . . . . . 7 - 15

7. CONNECTION TO EXTERNAL I/O DEVICE

7.1 Connectable Model List

The following table shows the connectable models.

Series	Clock	Connectable GOT	Refer to
External I/O device	*1	GT27 GT23 GS	7.2.1

*1 Varies with the connected type.

7.2 System Configuration

7.2.1 Connecting to the external I/O device

■ When inputting and outputting



Name	Connection cable 1) Connection diagram number	Connector/terminal block converter module*1*2	Connection cable 2) Connection diagram number	GOT*3 Option device	GOT*3 Model
General input device (Push button, etc.) Operation panel General output device (Lamp, relay)	User preparing Connection diagram 3)	A6TBY36-E Connection diagram 3)	User preparing Connection diagram 1)	GT15-DIO	GT27 GT23 GS
	User preparing Connection diagram 4)	A6TBY54-Es Connection diagram 4)			
	User preparing Connection diagram 5)	A6TBY36-E Connection diagram 5)	User preparing Connection diagram 2)	GT15-DIOR	
	User preparing Connection diagram 6)	A6TBY54-Es Connection diagram 6)			

*1 The power supply of 24VDC must be applied for the external I/O unit.
When the power supply of the external I/O unit is stopped in the operation, the operation panel becomes nonfunctional.
For using the operation panel again, reset the GOT after supplying the power to the external I/O unit.

*2 When the connector/terminal block converter module is used, the maximum input points are 64 points.

*3 When starting, turn on the external power supply to the external I/O unit and turn on the GOT.
When turning off the external power supply, a system alarm occurs.
When a system alarm is generated, input/output cannot be performed.
In this case, turn on the main power of the GOT or reset the GOT.
(When bus connection is used, the reset switch on the GOT does not function.)

■ When only inputting

Extended function OS

External I/O /Operation panel



External device		Connection cable*1	GOT*2	
Name	Connection diagram number	Connection diagram number	Option device	Model
Operation panel	User preparing Connection diagram 8)	User preparing Connection diagram 7)	GT15-DIO	GT27 GT23 GS
	User preparing Connection diagram 10)	User preparing Connection diagram 9)	GT15-DIOR	

*1 The power supply of 24VDC must be applied for the external I/O unit.
When the power supply of the external I/O unit is stopped in the operation, the operation panel becomes nonfunctional.
For using the operation panel again, reset the GOT after supplying the power to the external I/O unit.

*2 When starting, turn on the external power supply to the external I/O unit and turn on the GOT.
When turning off the external power supply, a system alarm occurs.
When a system alarm is generated, input/output cannot be performed.
In this case, turn on the main power of the GOT or reset the GOT.
(When bus connection is used, the reset switch on the GOT does not function.)

7.3 Connection Diagram

7.3.1 Connection cable between external I/O unit and connector/terminal block converter module

The connection cable between the external I/O unit and the connector/terminal block converter module must be prepared by the user referring to the followings.

■ For GT15-DIO

Connection diagram 1)



■ For GT15-DIOR

Connection diagram 2)



■ Connector specifications



No.	Name	Model name	Manufacturer
1)	Connector	PCR-E50FS+ (GT15-DIO)	Honda Tsushin Kogyo Co., Ltd.
		PCS-E50FS+ (GT15-DIOR)	
2)	Connector cover	PCS-E50LA	
3) 4)	Connector (with a cover)	A6CON1	Mitsubishi Electric Corporation
5)	Connector	FCN-361J040-AU	FUJITSU COMPONENT LIMITED
6)	Connector cover	FCN-360C040-B	
7)	Cable	UL 2464 AWG28 or equivalent	-

■ Precautions when preparing a cable

(1) Cable length

Maximum cable length differs depending on the cable used. Make the cable length within the range that can satisfy the I/O specifications of the external I/O unit.

(2) GOT side connector

For the GOT side connector, refer to the following.

☞ 1.4.1 GOT connector specifications

7.3.2 Connection diagram between connector/terminal block converter module and user-created original operation panel

The connection cable among the original operation panel, the connector/terminal block converter module and the general output device must be prepared by the user referring to the followings.

■ For GT15-DIO

Connection diagram 3)

When using A6TBY36-E connector/terminal block module



Connection diagram 4)

When using A6TBY54-E connector/terminal block module



■ For GT15-DIOR

Connection diagram 5)

When using A6TBY36-E connector/terminal block module



Connection diagram 6)

When using A6TBY54-E connector/terminal block module



7.3.3 Connection cable between external I/O unit and operation panel

The connection cable between the external I/O unit and the operation panel must be prepared by the user referring to the followings.

■ For GT15-DIO

Connection diagram 7)



Connection diagram 8)

For 16-point input



For 128-point input*1



*1 The 128-point input can be executed with using a 16-point input signal (XD00 to XD0F) with an 8-point scan signal (XSCN00 to XSCN07).

*2 When two or more switches are pressed simultaneously, be sure to put the diode to each switch. (Only for 128-point input)

■ For GT15-DIOR

Connection diagram 9)



Connection diagram 10)

For 16-point input


XD00 XD01 XD02 XD03 XD04 XD05 XD06 XD07 XD08 XD09 XD0A XD0B XD0C XD0D XD0E XD0F
XSCN00 XSCN01 XSCN02 XSCN03 XSCN04 XSCN05 XSCN06 XSCN07

For 128-point input*1



*1 The 128-point input can be executed with using a 16-point input signal (XD00 to XD0F) with an 8-point scan signal (XSCN00 to XSCN07).

*2 When two or more switches are pressed simultaneously, be sure to put the diode to each switch. (Only for 128-point input)

■ Connector specifications



No.	Name	Model name	Manufacturer
1)	Connector	PCR-E50FS+ (GT15-DIO)	Honda Tsushin Kogyo Co., Ltd.
		PCS-E50FS+ (GT15-DIOR)	
2)	Connector cover	PCS-E50LA	
3)	Cable	UL 2464 AWG28 or equivalent	——
4)	Cable for connecting an external input power supply	UL 1007 AWG24 or equivalent	——

■ Precautions when preparing a cable

(1) Cable length

Maximum cable length differs depending on the cable used.Make the cable length within the range that can satisfy the I/O specifications of the external I/O unit.

(2) GOT side connector

For the GOT side connector, refer to the following.

☞ 1.4.1 GOT connector specifications

7.4 GOT Side Settings

7.4.1 Setting communication interface

■ Controller setting

Set the channel of the equipment to be connected to the GOT.



1. Select [Common] → [Controller Setting] from the menu.
2. The Controller Setting window is displayed. Select the channel to be used from the list menu.
3. Set Manufacturer, Controller Type, I/F, and Driver according to the connected equipment to be used.
4. The detailed setting is displayed after Manufacturer, Controller Type, I/F, and Driver are set.
   Make the settings according to the usage environment.

Click the [OK] button when settings are completed.

POINT

The settings of connecting equipment can be set and confirmed in [I/F Communication Setting]. For details, refer to the following.

1.1.2 I/F communication setting

■ External I/O device setting



1. Select [Common] → [Peripheral Setting] → [External I/O / Operation Panel] from the menu.
2. Set the interface to which the external I/O device is connected.
3. Check the [Use Operation Panel] to set the operation panel.
   For details on the operation panel settings,refer to the following manual.

GT Designer3 (GOT2000) Help

Click the [OK] button when settings are completed.

POINT

(1) Communication interface setting by the Utility
The communication interface setting can be changed on the Utility's [Communication setting] after writing [Communication Settings] of project data.
For details on the Utility, refer to the following manual.

GOT2000 Series User's Manual (Utility)

(2) Precedence in communication settings
When settings are made by GT Designer3 or the Utility, the latest setting is effective.

7.5 Precautions

■ External I/O function setting on GT Designer3

Before using the operation panel, make the operation panel setting.

For details, refer to the following manual.

☞ GT Designer3 (GOT2000) Help


MEMO

8

BAR CODE READER CONNECTION

8.1 Connectable Model List . . . . . 8 - 2
8.2 System Configuration . . . . . 8 - 2
8.3 GOT Side Settings . . . . . 8 - 3
8.4 System Configuration Examples . . . . . 8 - 5
8.5 Precautions . . . . . 8 - 7

8. BAR CODE READER CONNECTION

8.1 Connectable Model List

For connectable bar code readers and system equipment, refer to the following Technical News.

☞ List of valid devices applicable for GOT2000 series (GOT-A-0064)

8.2 System Configuration

8.2.1 Connecting to bar code reader



Bar code reader	Connection cable 1)	Connection cable 2)	GOT		PLC	Number of connectable equipment
			Option device	Model		
*1	*1	-	- (Built into GOT)	GT27 GT23 GS	For the system configuration between the GOT and PLC, refer to each chapter.	1 bar code reader for 1 GOT
	*1	-	GT15-RS2-9P	GT27 GT23 GS		

*1 For connectable bar code readers, system equipment, available bar code types and connection cables, refer to the following Technical News.

☞ List of valid devices applicable for GOT2000 series (GOT-A-0064)

POINT

When using the RS-232 communication unit

Use the RS-232 communication unit of the GOT for connecting to a barcode reader.
However, when the RS-232 communication unit is used, the power cannot be supplied to a bar code reader from the GOT.

HINT

System configuration between the GOT and PLC

For the system configuration between the GOT and PLC, refer to each chapter.

☞ Mitsubishi Products
☞ Non-Mitsubishi Products 1, Non-Mitsubishi Products 2
☞ Microcomputer, MODBUS Products, Peripherals

8.3 GOT Side Settings

8.3.1 Setting communication interface

■ Controller setting

Set the channel of the equipment to be connected to the GOT.



1. Select [Common] → [Controller Setting] from the menu.
2. The Controller Setting window is displayed. Select the channel to be used from the list menu.
3. Set Manufacturer, Controller Type, I/F, and Driver according to the connected equipment to be used.
4. The detailed setting is displayed after Manufacturer, Controller Type, I/F, and Driver are set.
   Make the settings according to the usage environment.

Click the [OK] button when settings are completed.

POINT

The settings of connecting equipment can be set and confirmed in [I/F Communication Setting]. For details, refer to the following.

1.1.2 I/F communication setting

■ Bar code reader setting



1. Select [Common] → [Peripheral Setting] → [Bar Code] from the menu.
2. Set the interface to which the bar code reader is connected.
3. Check the [Use Bar Code] to set the function. For details on the function setting, refer to the following manual.

   GT Designer3 (GOT2000) Help
4. Clicking the detail setting button displays the Communication Detail Settings dialog box for each communication driver.Make the settings according to the usage environment.

   8.3.2 Communication detail settings

Click the [OK] button when settings are completed.

POINT

(1) Communication interface setting
When Channel No.8 is used, the following external devices, which use Channel No.8, cannot be connected at the same time.
- RFID controller that uses the external authentication
- RFID controller that requires the power supply

When connecting the above-mentioned devices at the same time, set [Bar Code] to Channels No. 5 to 7.

(2) Setting for the driver
To Channels No. 5 to 8, multiple [Bar Code] cannot be set.

8.3.2 Communication detail settings

Make the settings according to the usage environment.



Item	Description	Range
Transmission Speed	Set this item when change the transmission speed used for communication with the connected equipment. (Default: 9600bps)	4800bps, 9600bps, 19200bps, 38400bps, 57600bps, 115200bps
Data Bit	Set this item when change the data length used for communication with the connected equipment. (Default: 8bits)	7bits/8bits
Stop Bit	Specify the stop bit length for communications. (Default: 1bit)	1bit/2bits
Parity	Specify whether or not to perform a parity check, and how it is performed during communication. (Default: Even)	None Even Odd

POINT

(1) Communication interface setting by the Utility
The communication interface setting can be changed on the Utility's [Communication setting] after writing [Communication Settings] of project data.
For details on the Utility, refer to the following manual.

☞ GOT2000 Series User's Manual (Utility)

(2) Precedence in communication settings
When settings are made by GT Designer3 or the Utility, the latest setting is effective.

8.4 System Configuration Examples

A system configuration example for bar code reader connection is shown below.

■ System configuration



*1 The GOT and QCPU (Q mode) are connected through a bus.
For bus connection, refer to the following manual.
☞ GOT1000 Series Connection Manual (Mitsubishi Products) for GT Works3

1. The bar code is read with the bar code reader.
☞ ■ Bar code reader setting

2. The GOT receives the data sent from the bar code reader.
☞ ■ Setting of [Controller Setting] of GT Designer3

3. The received data are written to the PLC CPU.
☞ ■ Setting of [Bar Code] of GT Designer3

4. The data read with the bar code reader are written into the PLC CPU devices.
☞ ■ Confirmation on PLC side

■ Bar code reader setting

The bar code reader shall be configured as shown below.

Item	Set value
Transmission Speed	9600bps
Data Bit	8bit
Stop Bit	1bit
Parity	Even
Header	None
Terminator	CR

POINT

Bar code reader setting

For the bar code reader setting, refer to the following manual.

☞ User's Manual of the bar code reader

■ Setting of [Controller Setting] of GT Designer3

(1) Controller setting



(2) Communication detail settings

Keep consistency with the bar code reader setting.

Item	Setting (Use default value.)
Transmission Speed	9600bps
Data Bit	8bit
Stop Bit	1bit
Parity	Even

POINT

[Controller Setting] of GT Designer3

For the setting method of [Controller Setting] of GT Designer3, refer to the following.

☞ 8.3.1Setting communication interface

■ Setting of [Bar Code] of GT Designer3



Item	Set value
Read Data Direct Input to Object	No
Device	D0
Device Points	6
Header*1	None
Terminator*1	CR
Writing Byte Order	Low → High
Fills a blank when Imported data is not filled in Writing Points	Check (Filling Data is available)
Filling Data	Space (020)

*1 Keep consistency with the bar code reader setting.

POINT

[Bar Code] of GT Designer3

For the [Bar Code] setting in GT Designer3, refer to the following manual.

☞ GT Designer3 (GOT2000) Help

■ Confirmation on PLC side

Connect GX Developer to the QCPU (Q-mode) and check if the data, which has been read with the bar code reader, are written in D0 to D5.

For the GX Developer operation method, refer to the following manual.

☞ GX Developer Version□ Operating Manual

(1) Confirming the device values of D0 to D5 (when using GX Developer Version 8)

Startup procedure

GX Developer → [Online] → [Monitor] → [Device batch]



ASCII codes are hexadecimals. Specify [HEX] for [Value] of the GX Developer and confirm the read data.

8.5 Precautions

■ Bar code function setting on GT Designer3

Before connecting the bar code reader, make the bar code function and system data settings.

For details, refer to the following manual.

☞ GT Designer3 (GOT2000) Help

■ Controller setting

When using the barcode reader, which requires the power supply from the GOT, set Channel No. 8 using the standard interface.

With Channels No. 5 to 7 of the extension interface, the power cannot be supplied.


MEMO

9

PC REMOTE CONNECTION

9.1 Connectable Model List . . . . . 9 - 2
9.2 Serial Connection . . . . . 9 - 3
9.3 Ethernet Connection . . . . . 9 - 8

9. PC REMOTE CONNECTION

9.1 Connectable Model List

The RGB display is used for the remote personal computer operation connection.
The following GOT models support the remote personal computer operation connection.

Connection type	GOT model
Serial connection	GT27 GT23 GS
Ethernet connection	GT27 GT23 GS

9.2 Serial Connection

9.2.1 System Configuration



Personal computer	Connection cable 1)*2		GOT		PLC	Number of connectable equipment
	Cable model	Max. distance	Option device	Model		
To be selected by the user.	GT01-C30R2-9S or User preparing RS232 connection diagram 1)	15m	- (Built into GOT)	GT27 GT23 GS	For the system configuration between the GOT and PLC, refer to each chapter.	1 personal computer for 1 GOT
			GT15-RS2-9P	GT27 GT23 GS		
	Connection cable 2)*2		GOT			
	Cable model	Max. distance	Option device	Model		
	GT15-C50VG or User preparing Analog RGB connection diagram 1)	*1	GT27-R2-Z	GT27 GT23 GS		
			GT27-V4R1-Z	GT27 GT23 GS		

*1 The cable length differs depending on the specification of the personal computer to be used. Use the cable that is compatible with the personal computer to be used.

*2 The connection cable 1) (RS-232 cable) and the connection cable 2) (analog cable) should be connected between the personal computer and the GOT.

HINT

System configuration between the GOT and PLC

For the system configuration between the GOT and PLC, refer to each chapter.

- Mitsubishi Products
- Non-Mitsubishi Products 1, Non-Mitsubishi Products 2
- Microcomputer, MODBUS Products, Peripherals

9.2.2 Connection Diagram

When using a 3m or longer RS-232 cable for connecting a GOT to a personal computer, the cable must be prepared by the user.
The following shows each cable connection diagram.

■ RS-232 cable

(1) Connection diagram

RS232 connection diagram 1)



(2) Precautions when preparing a cable

(a) Cable length
The length of the RS-232 cable must be 15m or less.

(b) GOT side connector
For the GOT side connector, refer to the following.

☞ 1.4.1 GOT connector specifications

(c) Personal computer side connector
Use a connector compatible with the personal computer to be used.

■ Analog RGB cable

(1) Connection diagram

Analog RGB connection diagram 1)



(2) Precautions when preparing a cable

(a) Cable length
The cable length differs depending on the specification of the personal computer to be used. Create a cable under the specifications of the personal computer.

(b) GOT side connector
Use the following as the video/RGB input unit and the RGB input unit connectors.
For the GOT side connector and connector cover of the analog RGB cable, use the ones applicable to the GOT connector.

GOT	Connector type	Connector type	Manufacturer
GT16M-R2	17HE-R13150-73MC2	D-Sub 15 pin (female)	DDK Ltd. (DDK)
GT16M-V4R1			
GT15V-75R1			
GT15V-75V4R1			

(c) Personal computer side connector
Use a connector compatible with the personal computer to be used.

9.2.3 GOT Side Settings

■ Setting communication interface (Communication settings)

Set the channel of the equipment to be connected to the GOT.



1. Select [Common] → [Controller Setting] from the menu.
2. The Controller Setting window is displayed. Select the channel to be used from the list menu.
3. Set Manufacturer, Controller Type, I/F, and Driver according to the connected equipment to be used.
4. The detailed setting is displayed after Manufacturer, Controller Type, I/F, and Driver are set.
   Make the settings according to the usage environment.

Click the [OK] button when settings are completed.

POINT

The settings of connecting equipment can be set and confirmed in [I/F Communication Setting]. For details, refer to the following.

1.1.2 I/F communication setting

9.2.4 Communication detail settings

(1) Serial connection

Make the settings according to the usage environment.



Item	Description	Range
Video Input Signal*1	Set the video input signal. (Default: NTSC)	NTSC, PAL
Video Resolution	Set the video resolution. (Default: 640×480)	640×480, 720×480, 768×576

*1 When NTSC format is selected, the resolution is fixed to 640×480.

POINT

(1) Communication interface setting

When Channel No.8 is used, the following external devices, which use Channel No.8, cannot be connected at the same time.

- RFID controller that uses the external authentication
- Barcode reader and RFID controller that require the power supply

When connecting the above-mentioned devices at the same time, set [PC Remote Operation] to Channels No. 5 to 7.

(2) Communication interface setting by the Utility

The communication interface setting can be changed on the Utility's [Communication setting] after writing [Communication Settings] of project data.

For details on the Utility, refer to the following manual.

GOT2000 Series User's Manual (Utility)

(3) Precedence in communication settings

When settings are made by GT Designer3 or the Utility, the latest setting is effective.

■ Settings for the remote personal computer operation


2.
PC Remote Operation
PC Remote Operation (Ethernet)
*Setting of the following items are required for the use of PC Remote Operation (Ethernet).
- Setting of Ethernet driver
Description...
- Setting of a switch (special function)
- License registration in GOT
Use PC Remote Operation (Ethernet)
*The overlap window allocated as system window will be used for remote screen display.
Mouse Cursor Display:
GOT and server PC
GOT Only
PC Remote Operation (Serial)
Destination I/F:
Standard I/F(RS232)
*Setting of RGB Input is required for the use of PC Remote Operation (Serial).
OK
Cancel
Click!

1. Select [Common] → [Peripheral Setting] → [PC Remote Operation] from the menu.
2. Set the interface to which the personal computer is connected for the [Connecting I/F] of [PC Remote Operation (serial)].

Click the [OK] button when settings are completed.

■ Settings for the video/RGB equipment



1. Select [Common] → [Peripheral Setting] → [Video/RGB Input] from the menu.
2. Set the interface to which the video/RGB equipment is connected.
3. Check the [Use Video/RGB Input] to set the function. For details on the function setting, refer to the following manual.

   GT Designer3 (GOT2000) Help
4. Clicking the detail setting button displays the Communication Detail Settings dialog box for each communication driver.Make the settings according to the usage environment.

   9.2.4 Communication detail settings

Click the [OK] button when settings are completed.

POINT

Setting for the driver

To Channels No. 5 to 8, multiple [PC Remote Operation] cannot be set.

9.2.5 Installing and setting up computer remote operation driver.

Install and set up the remote personal computer operation driver to the personal computer.

For installing and setting up the remote personal computer operation driver, refer to the following manual.

☞ GT Designer3 (GOT2000) Help

9.2.6 Precautions

■ Personal computer side setting

Before using the remote personal computer operation function, install the remote personal computer operation driver on the personal computer.

After the driver installation, check that the driver is correctly installed.

For details of the remote personal computer operation driver, refer to the following manual.

☞ GT Designer3 (GOT2000) Help

9.3 Ethernet Connection

9.3.1 System Configuration



Personal computer	Connection cable*1*2	Maximum segment length*3	GOT		PLC	Number of connectable equipment
			Option device	Model		
To be selected by the user.	• 100BASE-TX Shielded twisted pair cable (STP) or unshielded twisted pair cable (UTP) of category 5 or higher • 10BASE-T Shielded twisted pair cable (STP) or unshielded twisted pair cable (UTP) of category 3 or higher	100m	- (Built into GOT)	GT27 GT23 GS	For the system configuration between the GOT and PLC, refer to each chapter.	1 personal computer for 1 GOT

*1 The destination connected with the twisted pair cable varies with the configuration of the applicable Ethernet network system.
Connect to the Ethernet module, hub, transceiver, wireless LAN adapter (NZ2WL-JPA or NZ2WL-JPS), or other system equipment corresponding to the applicable Ethernet network system.
Use cables, connectors, and hubs that meet the IEEE802.3 10BASE-T/100BASE-TX standard.
For the controllers that can be connected to the wireless LAN adapters and how to set the wireless LAN adapter, refer to the manual of the wireless LAN adapter used.

*2 A straight cable is available.
When connecting the GOT and PC directly with Ethernet cable, remember that the by cross cable is available.

*3 A length between a hub and a node.
The maximum distance differs depending on the Ethernet device to be used.
The following shows the number of the connectable nodes when a repeater hub is used.
- 10BASE-T: Max. 4 nodes for a cascade connection (500m)
- 100BASE-TX: Max. 2 nodes for a cascade connection (205m)

When switching hubs are used, the cascade connection between the switching hubs has no logical limit for the number of cascades.
For the limit, contact the switching hub manufacturer.

HINT

System configuration between the GOT and PLC
For the system configuration between the GOT and PLC, refer to each chapter.

☞ Mitsubishi Products
☞ Non-Mitsubishi Products 1, Non-Mitsubishi Products 2
☞ Microcomputer, MODBUS Products, Peripherals

9.3.2 GOT Side Settings

■ Setting communication interface (Communication settings)

Set the channel of the equipment to be connected to the GOT.



1. Select [Common] → [Controller Setting] from the menu.
2. The Controller Setting window is displayed. Select the channel to be used from the list menu.
3. Set Manufacturer, Controller Type, I/F, and Driver according to the connected equipment to be used.
4. The detailed setting is displayed after Manufacturer, Controller Type, I/F, and Driver are set.
   Make the settings according to the usage environment.

Click the [OK] button when settings are completed.

POINT

The settings of connecting equipment can be set and confirmed in [I/F Communication Setting]. For details, refer to the following.

1.1.2 I/F communication setting

■ Settings for the PC remote operation


3.
PC Remote Operation
PC Remote Operation (Ethernet)
*Setting of the following items are required for the use of PC Remote Operation (Ethernet).
- Setting of Ethernet driver
Description...
- Setting of a switch (special function)
- License registration in GOT
Use PC Remote Operation (Ethernet)
*The overlap window allocated as system window will be used for remote screen display.
Mouse Cursor Display:
GOT and server PC
GOT Only
PC Remote Operation (Serial)
Destination I/F:
Not connected
*Setting of RGB Input is required for the use of PC Remote Operation (Serial).
OK
Cancel
Click!
2.

1. Select [Common] → [Peripheral Setting] → [PC Remote Operation] from the menu.
2. Set [Connecting I/F] of [PC Remote Operation] to [Disconnect].
3. Check the [Use PC Remote Operation (Ethernet)] of [PC Remote Operation (Ethernet)] to set. For details on the settings, refer to the following manual.

   GT Designer3 (GOT2000) Help

Click the [OK] button when settings are completed.

9.3.3 Install and setting the required software

Install and set the required software according to the system configuration.

For the settings, refer to the following manual.

GT Designer3 (GOT2000) Help

9.3.4 Precautions

■ Ethernet system driver

Before using the PC remote operation function (Ethernet), install an Ethernet system communication driver to the GOT.

Set the Ethernet system communication driver for the controller setting or peripheral setting.

For the settings, refer to the following manual.

GT Designer3 (GOT2000) Help


MEMO

10

VNC(R) SERVER CONNECTION

10.1 Connectable Model List . . . . . 10 - 2
10.2 System Configuration . . . . . 10 - 2
10.3 GOT Side Settings . . . . . 10 - 3
10.4 Setting in Personal Computer . . . . . 10 - 4

10. VNC(R) SERVER CONNECTION

10.1 Connectable Model List

The VNC® server can be connected to the following VNC® client.

CPU	Software
PC	Ultra VNC

10.2 System Configuration



Personal computer (VNC® client)	Connection cable*1*2	Maximum segment length*3	GOT (VNC® server)		PLC	Number of connectable equipment
			Option device	Model		
To be selected by the user.	• 100BASE-TX Shielded twisted pair cable (STP) or unshielded twisted pair cable (UTP) of category 5 or higher • 10BASE-T Shielded twisted pair cable (STP) or unshielded twisted pair cable (UTP) of category 3 or higher	100m	- (Built into GOT)	GT27 GT23 GS	For the system configuration between the GOT and PLC, refer to each chapter.	1 personal computer for 1 GOT

*1 The destination connected with the twisted pair cable varies with the configuration of the applicable Ethernet network system. Connect to the Ethernet module, hub, transceiver, wireless LAN adapter (NZ2WL-JPA or NZ2WL-JPS), or other system equipment corresponding to the applicable Ethernet network system.
Use cables, connectors, and hubs that meet the IEEE802.3 10BASE-T/100BASE-TX standard.
For the controllers that can be connected to the wireless LAN adapters and how to set the wireless LAN adapter, refer to the manual of the wireless LAN adapter used.

*2 A straight cable is available.
When connecting the GOT and PC directly with Ethernet cable, remember that the by cross cable is available.

*3 A length between a hub and a node.
The maximum distance differs depending on the Ethernet device to be used.
The following shows the number of the connectable nodes when a repeater hub is used.
• 10BASE-T: Max. 4 nodes for a cascade connection (500m)
• 100BASE-TX: Max. 2 nodes for a cascade connection (205m)
When switching hubs are used, the cascade connection between the switching hubs has no logical limit for the number of cascades.
For the limit, contact the switching hub manufacturer.

HINT

System configuration between the GOT and PLC

For the system configuration between the GOT and PLC, refer to each chapter.

☞ Mitsubishi Products

☞ Non-Mitsubishi Products 1, Non-Mitsubishi Products 2

☞ Microcomputer, MODBUS Products, Peripherals

10.3 GOT Side Settings

10.3.1 VNC(R) server function setting



1. Select [Common] → [Peripheral Setting] → [VNC Server] from the menu.
2. Check the [VNC Server] of [Use VNC Server] to set. For details on the settings, refer to the following manual.

   ☞ GT Designer3 (GOT2000) Help
3. Click the [OK] button when settings are completed.

10.3.2 Setting communication interface (Communication settings)

For using the VNC® server, Ethernet communication drivers must be set on the GOT, and set the Communication settings



1. Select [Common] → [Controller Setting] from the menu.
2. The Controller Setting window is displayed. Select the channel to be used from the list menu.
3. Set Manufacturer, Controller Type, I/F, and Driver according to the connected equipment to be used.
4. The detailed setting is displayed after Manufacturer, Controller Type, I/F, and Driver are set.
   Make the settings according to the usage environment.
   Click the [OK] button when settings are completed.

POINT

Ethernet-based driver

For using the VNC® server, any of the following Ethernet communication drivers must be set on the GOT.

- Ethernet (MELSEC), Q17nNC, CRnD-700, Gateway
- Ethernet (FX), Gateway
- Ethernet (OMRON), Gateway
- Ethernet (KEYENCE), Gateway
- Ethernet (YASKAWA), Gateway
- Ethernet (YOKOGAWA), Gateway
- EtherNet/IP (AB), Gateway
- Ethernet (SIEMENS S7), Gateway
- Ethernet (SIEMENS OP), Gateway
- MODBUS/TCP, Gateway
- Ethernet (MICROCOMPUTER)

In the peripheral setting, set [Destination I/F] in [Ethernet Download] for the [PC (Data Transfer)] dialog box.
To connect controllers including a programmable controller to the GOT by using the Ethernet connection, no setting is required.
For the details of [Ethernet Download] , refer to the following

☞ GT Designer3 (GOT2000) Help

10.4 Setting in Personal Computer

For connecting the VNC® server to the personal computer (VNC® client), it is necessary to install the VNC® client software to the personal computer to be connected and set it.
Refer to the following for details of the VNC® client software installation method and setting method.

☞ GT Designer3 (GOT2000) Help

11

VIDEO/RGB CONNECTION

11.1 Connectable Model List . . . . . 11 - 2
11.2 System Configuration . . . . . 11 - 3
11.3 Connection Diagram . . . . . 11 - 6
11.4 GOT Side Settings . . . . . 11 - 8
11.5 Precautions . . . . . 11 - 9

11. VIDEO/RGB CONNECTION

11.1 Connectable Model List

The following GOT models support the Video/RGB connection.

GOT model
GT27 GT23 GS

For the type of the video camera that can be connected, refer to the following Technical News.

☞ List of valid devices applicable for GOT2000 series (GOT-A-0064)

11.2 System Configuration

11.2.1 Displaying video image on GOT



Signal type	Video/RGB equipment	Connection cable*3	GOT		Number of connectable equipment
		Cable model Connection diagram number	Option device	Model	
NTSC/PAL	Equipment including video cameras*1 and vision sensors*2 that outputs images by using the NTSC or PAL signal	User preparing Coaxial connection diagram 1)	GT27-V4-Z GT27-V4R1-Z	GT27 GT23 GS	4 video equipment for 1 GOT
Analog RGB	Equipment including video cameras*1, vision sensors*2, and personal computers*2 that outputs images by using the RGB signal	GT15-C50VG(5m) or User preparing Analog RGB connection diagram 1)	GT27-R2-Z*4	GT27 GT23 GS	2 RGB equipment for 1 GOT
			GT27-V4R1-Z	GT27 GT23 GS	1 RGB equipment for 1 GOT

*1 For connectable video camera types, refer to the following Technical News.

List of valid devices applicable for GOT1000 series (GOT-A-0010)

*2 The user must select a vision sensor or a personal computer to be used.

*3 The cable length differs according to the specifications of the video/RGB equipment.

*4 RGB can be input with two channels. For the switching between two channels, refer to the following manual.

GT Designer3 (GOT2000) Help

POINT

(1) Power supply of video camera
Depending on the video camera type, noises from the power supply cable of the camera may cause a malfunction on the PLC or the GOT.In this case, apply the following line filter to the power line of the camera.
Recommended line filter: TDK ZHC2203-11 (or equivalent)

(2) Power supply of vision sensor
If a video camera is used via a vision sensor, a power supply module may be required depending on the vision sensor to be used.

(3) Selection of Video signal output source
Depending on the video camera or the system to be used, both the power supply module and the video camera can output video signals. If video signals are output from both the video camera and the power supply module, the voltage level of the signals become lower and the video image cannot be correctly displayed. In this case, use the output from the video camera.

(4) Power-On of video camera
Turn on the video camera simultaneously with the GOT.

(5) Distortion of the image caused by the noise
When the screen is distorted by the noise from the RGB cable, install the following ferrite core to the input part of the RGB cable.
Recommended ferrite core: TDK ZCAT3035-1330 (or equivalent)

11.2.2 Displaying GOT screen on external monitor



Extended function OS
Video/RGB input

Signal type	External monitor	Connection cable	Distance	GOT		Number of connectable equipment
	Model name	Model name		Option device	Model	
Analog RGB	For connectable external monitor types, refer to the following Technical News. List of valid devices applicable for GOT2000 series (GOT-A-0010)	GT15-C50VG(5m) or User preparing Analog RGB connection diagram 2)	*1	GT27-ROUT-Z	GT27 GT23 GS	1 for 1 GOT

*1 The cable length differs depending on the specification of the external monitor used by the user.

11.3 Connection Diagram

The coaxial cable/analog RGB cable to connect the GOT to the Video/RGB equipment must be prepared by the user.

The following shows each cable connection diagram and relevant connectors.

11.3.1 Coaxial cable

The following provides the specifications, the connectors and creation method of the coaxial cable to connect the GOT to the video output equipment.

■ Connection diagram

Coaxial connection diagram 1)

Displaying video image on GOT



Cable specification

Item	Specifications
Applicable cable	3C-2V, 5C-2V (JIS C 3501 compliant)

■ Connecting the BNC connector to the coaxial cable

For how to connect the BNC connector and coaxial cable, refer to the following.

1.4.2 Coaxial cableconnector connection method

■ Precautions when preparing a cable

(1) Cable length

The cable length differs depending on the specification of the video camera or vision sensor to be used.

Create a cable under the specifications of the video camera/vision sensor.

(2) GOT side connector

Use the following as the video input unit connector.
For the GOT side connector of the coaxial cable, use the ones compatible with the GOT connector.

GOT	Connector model	Connector type	Manufacturer
GT27-V4-Z	227161-4	BNC	Tyco International, Ltd.
GT27-V4R1-Z			

(3) Video camera/vision sensor side connector

Use a connector compatible with the video camera/vision sensor to be used.

HINT

When the coaxial cable is long

When the coaxial cable is long, video signals are attenuated by the cable.
The use of a video signal amplifier is recommended to correct the attenuated signals.
Connect a video signal amplifier in reference to the following:

- Coaxial cable: The cable length is 100m or more when 3C-2V is used.
- Coaxial cable: The cable length is 200m or more when 5C-2V is used.

11.3.2 Analog RGB cable

■ Connection diagram

(1) Analog RGB connection diagram 1)

Displaying video image on GOT



(2) Analog RGB connection diagram 2)

Displaying GOT screen on external monitor



■ Precautions when preparing a cable

(1) Cable length

The cable length differs depending on the specification of the vision sensor/PC to be used. Create a cable under the specifications of the vision sensor/PC.

(2) GOT side connector

Use the following as the video/RGB input unit, RGB input unit, and RGB output unit connectors.
For the GOT side connector and connector cover of the analog RGB cable, use the ones applicable to the GOT connector.

GOT	Connector model	Connector type	Manufacturer
GT27-R2-Z	17HE-R13150-73MC2	D-Sub 15-pin (female)	DDK Ltd. (DDK)
GT27-V4R1-Z			
GT27-ROUT-Z			

(3) Vision sensor/PC side connector

Use a connector compatible with the vision sensor/ personal computer to be used.

11.4 GOT Side Settings

11.4.1 Setting communication interface

■ Controller setting

Set the channel of the equipment to be connected to the GOT.



1. Select [Common] → [Controller Setting] from the menu.
2. The Controller Setting window is displayed. Select the channel to be used from the list menu.
3. Set Manufacturer, Controller Type, I/F, and Driver according to the connected equipment to be used.
4. The detailed setting is displayed after Manufacturer, Controller Type, I/F, and Driver are set.
   Make the settings according to the usage environment.

Click the [OK] button when settings are completed.

POINT

The settings of connecting equipment can be set and confirmed in [I/F Communication Setting]. For details, refer to the following.

1.1.2 I/F communication setting

11.4.2 Communication detail settings

Make the settings according to the usage environment.



Item	Description	Range
Video Input Signal*1	Set the video input signal. (Default: NTSC)	NTSC, PAL
Video Resolution*2	Set the video resolution. (Default: 640×480)	640×480, 720×480, 768×576

*1 When NTSC format is selected, the resolution is fixed to 640×480.
*2 For GT2710-V and GT2708-V, the resolution is fixed to 640×480.

POINT

(1) Communication interface setting by the Utility
The communication interface setting can be changed on the Utility's [Communication setting] after writing [Communication Settings] of project data.
For details on the Utility, refer to the following manual.

GOT2000 Series User's Manual (Utility)

(2) Precedence in communication settings
When settings are made by GT Designer3 or the Utility, the latest setting is effective.

■ Settings for the video/RGB equipment



1. Select [Common] → [Peripheral Setting] → [Video/RGB Input] from the menu.
2. Set the interface to which the video/RGB equipment is connected.
3. Check the [Use Video/RGB Input] to set the function. For details on the function setting, refer to the following manual.

   GT Designer3 (GOT2000) Help
4. Clicking the detail setting button displays the Communication Detail Settings dialog box for each communication driver.Make the settings according to the usage environment.

   11.4.2 Communication detail settings

Click the [OK] button when settings are completed.

11.4.3 Setting the video/RGB function

Set the video/RGB function.

For the video/RGB function setting, refer to the following manual.

GT Designer3 (GOT2000) Help

11.5 Precautions

■ Connecting to PC

When connecting to a PC, ground the earth wire of the PC.


MEMO

12

PRINTER CONNECTION

12.1 Connectable Model List . . . . . 12 - 2
12.2 System Configuration . . . . . 12 - 2
12.3 GOT Side Settings . . . . . 12 - 4
12.4 Precautions . . . . . 12 - 6

12. PRINTER CONNECTION

12.1 Connectable Model List

For connectable printers and system equipment, refer to the following Technical News.

☞ List of valid devices applicable for GOT2000 series (GOT-A-0064)

12.2 System Configuration

12.2.1 Connecting to PictBridge compatible printer



Printer	Connection cable	GOT		PLC	Number of connectable equipment
Model name	Model name	Option device	Model		
For connectable printers and system equipment, refer to the following Technical News. ☞ List of valid devices applicable for GOT2000 series (GOT-A-0064)	GT09-C30USB-5P(3m) (packed together with the printer unit)	GT15-PRN*1	GT27 GT23 GS	For the system configuration between the GOT and PLC, refer to each chapter.	1 printer for 1 GOT

*1 Communication unit between the GOT and the PictBridge compatible printer.
GOT does not support some PictBridge Compatible Printers. For the precautions for printer connection, refer to the following Technical News.

☞ List of valid devices applicable for GOT2000 series (GOT-A-0064)

HINT

System configuration between the GOT and PLC

For the system configuration between the GOT and PLC, refer to each chapter.

☞ GOT2000 Series Connection Manual (Mitsubishi Product) For GT Works3 Version1

☞ GOT2000 Series Connection Manual (Non Mitsubishi Product 1) For GT Works3 Version1

☞ GOT2000 Series Connection Manual (Non Mitsubishi Product 2) For GT Works3 Version1

☞ GOT2000 Series Connection Manual (Microcomputer, MODBUS, Products, Peripherals) For GT Works3 Version1

12.2.2 Connecting to serial printer



Printer	Connection cable 1)	Connection cable 2)	GOT		PLC	Number of connectable equipment
Model name	Model name	Model name	Option device	Model		
For connectable printers and system equipment, refer to the following Technical News. ☞ List of valid devices applicable for GOT2000 series (GOT-A-0064)	RS-232 cable*1	-	- (Built into GOT)	GT27 GT23 GS	For the system configuration between the GOT and PLC, refer to each chapter.	1 printer for 1 GOT
		-	GT15-RS2-9P	GT27 GT23 GS		

*1 The RS-232 cable differs depending on the specification of the printer to be used. Use the RS-232 cable that is compatible with the printer to be used.

HINT

System configuration between the GOT and PLC

For the system configuration between the GOT and PLC, refer to each chapter.

☞ GOT2000 Series Connection Manual (Mitsubishi Product) For GT Works3 Version1

☞ GOT2000 Series Connection Manual (Non Mitsubishi Product 1) For GT Works3 Version1

☞ GOT2000 Series Connection Manual (Non Mitsubishi Product 2) For GT Works3 Version1

☞ GOT2000 Series Connection Manual (Microcomputer, MODBUS, Products, Peripherals) For GT Works3 Version1

12.3 GOT Side Settings

12.3.1 Setting communication interface

■ Controller setting

Set the channel of the equipment to be connected to the GOT.



1. Select [Common] → [Controller Setting] from the menu.
2. The Controller Setting window is displayed. Select the channel to be used from the list menu.
3. Set Manufacturer, Controller Type, I/F, and Driver according to the connected equipment to be used.
4. The detailed setting is displayed after Manufacturer, Controller Type, I/F, and Driver are set.
   Make the settings according to the usage environment.

Click the [OK] button when settings are completed.

POINT

The settings of connecting equipment can be set and confirmed in [I/F Communication Setting]. For details, refer to the following.

1.1.2 I/F communication setting

■ Printer setting



1. Select [Common] → [Peripheral Setting] → [Printer] from the menu.
2. Select the printer type.
3. Set the interface to which the printer is connected.
4. When Serial is selected in Printer type, clicking the detail setting button displays the Communication Detail Settings dialog box for the communication driver. Make the settings according to the usage environment.
   12.3.2 Communication detail settings

Click the [OK] button when settings are completed.

POINT

(1) Setting the communication interface
When Channel No.8 is used for the serial printer, the following external devices, which use Channel No.8, cannot be connected at the same time.
• Barcode reader that requires the power supply
When connecting the above-mentioned devices at the same time, set the serial printer to Channels No. 5 to 7.

(2) Setting for the driver
Regardless of the printer type, multiple printers are cannot be set.

12.3.2 Communication detail settings

Make the settings according to the usage environment.



Item	Description	Range
Transmission Speed	Set this item when change the transmission speed used for communication with printer. (Default: 19200bps)	4800bps, 9600bps, 19200bps, 38400bps, 57600bps, 115200bps
Data Bit*1	Set this item when change the data length used for communication with printer. (Default: 8bits)	7bits/8bits
Stop Bit	Specify the stop bit length for communications. (Default: 1bit)	1bit/2bits
Parity	Specify whether or not to perform a parity check, and how it is performed during communication. (Default: None)	None Even Odd
Retry	Set the number of retries to be performed when a communication error occurs. (Default: 0times)	0 to 5times
Timeout Time	Set the time period for a communication to time out. (Default: 30sec)	3 to 90sec
Delay Time	Set this item to adjust the transmission timing of the communication request from the GOT. (Default: 0ms)	0 to 300ms
Control Method	Set this item when selecting the XON/XOFF control for the control method. (Default: XON/XOFF)	XON/XOFF None

*1 When using the hard copy function, set to 8bit.

POINT

(1) Communication interface setting by the Utility
The communication interface setting can be changed on the Utility's [Communication setting] after writing [Communication Settings] of project data.
For details on the Utility, refer to the following manual.
GOT2000 Series User's Manual (Utility)

(2) Precedence in communication settings
When settings are made by GT Designer3 or the Utility, the latest setting is effective.

12.4 Precautions

■ Connection/disconnection of USB cable during print operation

When the USB cable is disconnected during print operation, the printer hangs up depending on the model of PictBridge compatible printer. In this case, turn on the main power of the printer and then restart it.

■ When a printer cannot perform print operation

While the initialization of the printer is being carried out at boot time, some models of PictBridge compatible printers send "Print Ready" signal to GOT.If printing operation is started from GOT, an error will occur and the printing operation will be disabled.If this occurs, restart a printer with the following procedure.

1. Disconnect the USB cable from the printer.
2. Turn the power of the printer OFF.
3. Disconnect the power supply cable of the printer and stop the printer completely.
4. Connect the power supply cable to the printer.
5. Turn the power of the printer ON and wait until the initialization processing of the printer is completed.
6. Connect the USB cable to the printer.

For the handling errors occurred on the printer, refer to the following.

☞ Manual for the printer being used

13

MULTIMEDIA CONNECTION

13.1 Connectable Model List . . . . . 13 - 2
13.2 System Configuration . . . . . 13 - 2
13.3 Connection Diagram . . . . . 13 - 4
13.4 GOT Side Settings . . . . . 13 - 5
13.5 Precautions . . . . . 13 - 8

13. MULTIMEDIA CONNECTION

13.1 Connectable Model List

For the type of CF card that can be inserted or connectable video camera types, refer to the following Technical News.

☞ List of valid devices applicable for GOT2000 series (GOT-D-0064)

POINT

Before making the multimedia connection

Update the software version of the multimedia unit to the latest version.
For the version upgrade of the multimedia unit, refer to the following manual.

☞ GOT2000 Series User's Manual (Utility)

13.2 System Configuration

13.2.1 Saving video image and displaying it on GOT

Extended function OS

Multimedia



Multimedia controller	Signal type	Connection cable	Max. distance	GOT		Number of connectable equipment
				Option device	Model	
*3	NTSC/PAL	User preparing Coaxial connection diagram 1)	*1	GT27M-MMR-Z*2	GT27 GT23 GS	1 multimedia controller for 1 GOT

*1 The cable length differs depending on the specification of the video camera used by the user.

*2 For the CF card to be inserted into the multimedia unit, refer to the following.

- Type of CF card that can be inserted

☞ List of Valid Devices Applicable for GOT2000 Series (GOT-D-0064)

- Precautions for using the CF card

☞ 13.4 GOT Side Settings

*3 For the type of the video camera that can be connected, refer to the following Technical News.

☞ List of Valid Devices Applicable for GOT2000 Series (GOT-D-0064)

13.2.2 Sending video image to personal computer



Multimedia controller	Signal type	Connection cable 1)		GOT*2*3			Connection cable 2)		Personal computer *5	Number of connectable equipment
		Model name	Max. distance	Option device (Interface 1))	Model	Option device (Interface 2))	Cable model	Maximum segment length*6		
*4	NTSC /PAL	User preparing Coaxial connection diagram 1)	*1	GT27-MMR-Z*3	GT27 GT23 GS	Ethernet Interface (Built into GOT)	Twisted pair cable • 10BASE-T Shielded twisted pair cable (STP) or unshielded twisted pair cable (UTP): Category 3, 4, and 5 • 100BASE-TX Shielded twisted pair cable (STP): Category 5 and 5e	100m	To be selected by the user.	1 multimedia controller for 1 GOT
						GT27M-MMR-Z				

*1 The cable length differs depending on the specification of the video camera used by the user.

*2 The destination connected with the twisted pair cable varies with the configuration of the applicable Ethernet network system.
Connect to the Ethernet module, hub, transceiver, wireless LAN adapter (NZ2WL-JPA or NZ2WL-JPS), or other system equipment corresponding to the applicable Ethernet network system.
Use cables, connectors, and hubs that meet the IEEE802.3 10BASE-T/100BASE-TX standards.
For the controllers that can be connected to the wireless LAN adapters and how to set the wireless LAN adapter, refer to the manual of the wireless LAN adapter used.

*3 For the CF card to be inserted into the multimedia unit, refer to the following.
• Type of CF card that can be inserted
List of valid devices applicable for GOT2000 series (GOT-D-0064)
• Precautions for using the CF card
13.4 GOT Side Settings

*4 For the type of the video camera that can be connected, refer to the following Technical News.
List of valid devices applicable for GOT2000 series (GOT-D-0064)

*5 Install the multimedia interaction tool before use.
For details of the multimedia interaction tool, refer to the following manual.
GT Designer3 (GOT2000) Help

*6 A length between a hub and a node.
The maximum distance differs depending on the Ethernet device to be used.
The following shows the number of the connectable nodes when a repeater hub is used.
• 10BASE-T: Max. 4 nodes for a cascade connection (500m)
• 100BASE-TX: Max. 2 nodes for a cascade connection (205m)
When switching hubs are used, the cascade connection between the switching hubs has no logical limit for the number of cascades.
For the limit, contact the switching hub manufacturer.

POINT

Power supply of video camera
Depending on the video camera type, noises from the power supply cable of the camera may cause a malfunction on the PLC or the GOT. In this case, apply the following line filter to the power line of the camera.
Recommended line filter: TDK ZHC2203-11 (or equivalent)

13.3 Connection Diagram

The coaxial cable used for connecting the GOT to a video camera should be prepared by the user.

The following shows each cable connection diagram.

13.3.1 Coaxial cable

The following shows the connection diagrams and connector specifications of the coaxial cable used for connecting the GOT to a video camera.

■ Connection diagram

(1) Coaxial connection diagram 1)

Displaying video image on GOT



Cable specification

Item	Specifications
Applicable cable	3C-2V, 5C-2V (JIS C 3501 compliant)

■ Connecting the BNC connector to the coaxial cable

For connecting the BNC connector and coaxial cable, refer to the following.

1.4.2 Coaxial cableconnector connection method

■ Precautions when preparing a cable

(1) Cable length

The cable length differs depending on the specification of the video camera to be used.

Create a cable under the specification of the video camera.

(2) GOT side connector

Use the following as the multimedia unit connector.

For the GOT side connector of the coaxial cable, use the ones compatible with the GOT connector.

GOT	Connector model	Connector type	Manufacturer
GT16M-MMR	227161-4	BNC	Tyco International, Ltd.

(3) Video camera side connector

Use a connector compatible with the video camera to be used.

HINT

When the coaxial cable is long

When the coaxial cable is long, video signals are attenuated by the cable.

The use of a video signal amplifier is recommended to correct the attenuated signals.

Connect a video signal amplifier in reference to the following:

- Coaxial cable: The cable length is 100m or more when 3C-2V is used.
- Coaxial cable: The cable length is 200m or more when 5C-2V is used.

13.4 GOT Side Settings

13.4.1 Setting communication interface

■ Controller setting

Set the channel of the equipment to be connected to the GOT.



1. Select [Common] → [Controller Setting] from the menu.
2. The Controller Setting window is displayed. Select the channel to be used from the list menu.
3. Set Manufacturer, Controller Type, I/F, and Driver according to the connected equipment to be used.
4. The detailed setting is displayed after Manufacturer, Controller Type, I/F, and Driver are set.
   Make the settings according to the usage environment.

Click the [OK] button when settings are completed.

POINT

The settings of connecting equipment can be set and confirmed in [I/F Communication Setting]. For details, refer to the following.

☞ 1.1.2 I/F communication setting

■ Multimedia setting



1. Select [Common] → [Peripheral Setting] → [Multimedia] from the menu.
2. Set the interface to which the multimedia controller is connected.
3. Check the [Enable the setting of Multimedia] to set the function. For details on the communication settings, refer to the following manual.

   ☞ GT Designer3 (GOT2000) Help
4. Clicking the detail setting button displays the Communication Detail Settings dialog box for each communication driver.Make the settings according to the usage environment.

   ☞ 13.4.2 Communication detail settings

Click the [OK] button when settings are completed.

13.4.2 Communication detail settings

Make the settings according to the usage environment.



(1) Video Setting

Item	Description	Range
Video Input Signal*1	Set the video input signal. (Default: NTSC)	NTSC, PAL
Video Resolution*2	Set the video resolution.	640×480, 720×480, 768×576

*1 When NTSC format is selected, the resolution is fixed to 640×480.When PAL format is selected, the resolution is fixed to 768×576.

*2 For GT2710-V and GT2708-V, the resolution is fixed to 640×480.

(2) IP Address Setting for Multimedia Unit

Set the network settings for connecting from the multimedia unit via Ethernet.

Item	Description	Range
IP Address	Set the IP address of the multimedia unit. (Default: 192.168.3.51)	0.0.0.0 to 255.255.255.255
Subnet Mask	Set the subnet mask for the sub network. (Only for connection via router) If the sub network is not used, the default value is set. (Default: 255.255.255.0)	0.0.0.0 to 255.255.255.255
Default Gateway	Set the router address of the default gateway on the side to which the multimedia unit is connected. (Only for connection via router) (Default: 0.0.0.0)	0.0.0.0 to 255.255.255.255

POINT

Network settings with the utility

The network setting can be changed on the Utility's [Communication setting] after writing [Communication Settings] of project data.

For details on the Utility, refer to the following manual.

GOT2000 Series User's Manual (Utility)

13.4.3 Installing and setting multimedia interaction tool onto personal computer

Install the multimedia interaction tool onto the personal computer and set it.

For how to install and set multimedia interaction tool, refer to the following manual.

☞ GT Designer3 (GOT2000) Help

POINT

When saving a video image and displaying it on the GOT, the installation and setting of the multimedia interaction tool onto the personal computer are unnecessary.

13.4.4 Setting the multimedia function

Set the multimedia function.

For the multimedia function setting, refer to the following manual.

☞ GT Designer3 (GOT2000) Help

13.4.5 Set the gateway function

Set the gateway function for using FTP.

For the gateway function setting, refer to the following.

☞ GOT1000 Series Gateway Functions Manual for GT Works3

POINT

To save a video image and display it on the GOT

When saving a video image and displaying it on the GOT, the gateway function setting is unnecessary.

13.5 Precautions

■ When the multimedia function is used

The multimedia function and the video/RGB function are written exclusively.

Select either of them to use.

■ CF card on the multimedia unit

For the CF card that can be inserted into the multimedia unit, formatting in FAT32 is recommended.

If the CF card formatted in FAT16 is inserted, the following phenomena may occur.

- Reading, writing or saving of movie files takes time.
- When a movie file is played, the movie momentarily looks like as if it stopped.

14

RFID CONNECTION

14.1 Connectable Model List . . . . . 14 - 2
14.2 System Configuration . . . . . 14 - 2
14.3 GOT Side Settings . . . . . 14 - 4
14.4 Precautions . . . . . 14 - 6

14. RFID CONNECTION

14.1 Connectable Model List

For connectable RFID controllers and system equipment, refer to the following Technical bulletin.

☞ List of valid devices applicable for GOT2000 series (GOT-D-0064)

Visit the Mitsubishi Electric FA Equipment Information Service website (MELFANSweb) to refer to the Technical News.
http://wwwf2.mitsubishielectric.co.jp/english/index.html

14.2 System Configuration

14.2.1 Connecting to RFID



RFID controller Model name	Connection cable	GOT Option device	GOT Model	PLC	Number of connectable equipment
For connectable RFID controllers and system equipment, refer to the following Technical bulletin. ☞ List of valid devices applicable for GOT2000 series (GOT-D-0064)	Varies according to specification of RFID controllers.	- (Built into GOT)	GT27 GT23 GS	For the system configuration between the GOT and PLC, refer to each chapter.	1 RFID controller for 1 GOT
		GT15-RS2-9P	GT27 GT23 GS		

POINT

When using the RS-232 communication unit

Use the RS-232 communication unit of the GOT for connecting to an RFID controller.
However, when the RS-232 communication unit is used, the following operations cannot be supported.

(a) Using the external authentication
(b) Supplying the power to an RFID controller from the GOT

HINT

System configuration between the GOT and PLC

For the system configuration between the GOT and PLC, refer to each chapter.

☞ Mitsubishi Products

☞ Non-Mitsubishi Products 1, Non-Mitsubishi Products 2

☞ Microcomputer, MODBUS Products, Peripherals

14.3 GOT Side Settings

14.3.1 Setting communication interface

■ Controller setting

Set the channel of the equipment to be connected to the GOT.



1. Select [Common] → [Controller Setting] from the menu.
2. The Controller Setting window is displayed. Select the channel to be used from the list menu.
3. Set Manufacturer, Controller Type, I/F, and Driver according to the connected equipment to be used.
4. The detailed setting is displayed after Manufacturer, Controller Type, I/F, and Driver are set.
   Make the settings according to the usage environment.

Click the [OK] button when settings are completed.

POINT

The settings of connecting equipment can be set and confirmed in [I/F Communication Setting]. For details, refer to the following.

1.1.2 I/F communication setting

■ RFID setting



1. Select [Common] → [Peripheral Setting] → [RFID] from the menu.
2. Set the interface to which the RFID controller is connected.
3. Check the [Use RFID] to set the function. For details on the function setting, refer to the following manual.

   GT Designer3 (GOT2000) Help
4. Clicking the detail setting button displays the Communication Detail Settings dialog box for each communication driver.Make the settings according to the usage environment.

   14.3.2 Communication detail settings

Click the [OK] button when settings are completed.

POINT

(1) Communication interface setting
When Channel No.8 is used, the following external devices, which use Channel No.8, cannot be connected at the same time.
• Barcode reader that requires the power supply
When connecting the above-mentioned devices at the same time, set [RFID] to Channels No. 5 to 7.

(2) Setting for the driver
To Channels No. 5 to 8, multiple [RFID] cannot be set.

14.3.2 Communication detail settings



Item	Description	Range
Transmission Speed	Set this item when change the transmission speed used for communication with the connected equipment. (Default: 9600bps)	4800bps, 9600bps, 19200bps, 38400bps, 57600bps, 115200bps
Data Bit	Set this item when change the data length used for communication with the connected equipment. (Default: 8bits)	7bits/8bits
Stop Bit	Specify the stop bit length for communications. (Default: 1bit)	1bit/2bits
Parity	Specify whether or not to perform a parity check, and how it is performed during communication. (Default: Even)	None Even Odd
Sum Check	Set whether or not to perform a sum check during communication. (Default: Done)	Yes or No
Retry	Set the number of retries to be performed when a communication timeout occurs. When receiving no response after retries, the communication times out. (Default: 0time)	0 to 5times
Timeout Time	Set the time period for a communication to time out. (Default: 3sec)	3 to 30sec
Delay Time	Set this item to adjust the transmission timing of the communication request from the GOT. (Default: 0ms)	0 to 3000ms
Format	Select the communication format. (Default: 15) Dedicated protocol • Format 10 (LS Industrial Systems Co., Ltd. LSR) • Format 11 (MARS TECHNO SCIENCE Corp. ICU-60S) • Format 12 (MARS TECHNO SCIENCE Corp. ICU-215 (Mifare)) Nonprocedural protocol • Format 15	10/11/12/15

POINT

(1) Communication interface setting by the Utility
The communication interface setting can be changed on the Utility's [Communication setting] after writing [Communication Settings] of project data.
For details on the Utility, refer to the following manuals.
☞ User's Manual of GOT used.

(2) Precedence in communication settings
When settings are made by GT Designer3 or the Utility, the latest setting is effective.

14.4 Precautions

■ RFID function setting on GT Designer3

Before connecting the RFID controller, set the RFID function and system data.

For details, refer to the following manual.

☞ GT Designer3 (GOT2000) Help

■ Controller setting

(1) When using the external authentication

When using the external authentication on the RFID controller, set Channel No. 8 using the standard interface.

When connecting the RFID using Channels No. 5 to 7 of the extension interface, extension interface cannot be used.

For details on the external authentication, refer to the following manual.

☞ GT Designer3 (GOT2000) Help

(2) When requiring the power supply

When using the RFID controller, which requires the power supply from the GOT, set Channel No. 8 using the standard interface.

With Channels No. 5 to 7 of the extension interface, the power cannot be supplied.

■ Communication in multiple RFID readers/writers connection

When connecting multiple RFID readers/writers, some controllers may communicate with each RFID reader/writer.

For communicating the RFID controller with the each RFID reader/writer, set an interlock so that the RFID controller does not communicate with RFID readers/writers until the executing communication is completed.

15

WIRELESS LAN CONNECTION

15.1 System Configuration . . . . . 15 - 2
15.2 GOT Side Settings . . . . . 15 - 3
15.3 Precautions . . . . . 15 - 5

15. WIRELESS LAN CONNECTION

■ Wireless LAN connection precautions

Wireless LAN connection is available for use only in Japan.

15.1 System Configuration

15.1.1 Connecting to wireless LAN



Wireless LAN access point	GOT		PLC	Number of connectable equipment
Model name	Option device	Model		
For the wireless LAN access point, use the access point compatible with IEEE802.11b/g/n.	GT25-WLAN	GT27 GT23 GS	For the system configuration between the GOT and PLC, refer to each chapter.	The multiple GOTs can be connected to one wireless LAN access point.*1

*1 The number of connectable GOTs depends on the specifications of wireless LAN access point.

HINT

System configuration between the GOT and PLC

For the system configuration between the GOT and PLC, refer to each chapter.

GOT2000 Series Connection Manual (Mitsubishi Product) For GT Works3 Version1

GOT2000 Series Connection Manual (Non Mitsubishi Product 1) For GT Works3 Version1

GOT2000 Series Connection Manual (Non Mitsubishi Product 2) For GT Works3 Version1

GOT2000 Series Connection Manual (Microcomputer, MODBUS, Products, Peripherals) For GT Works3 Version1

15.2 GOT Side Settings

15.2.1 Setting communication interface (Communication settings)



1. Select [Common] → [Controller Setting] from the menu.
   Select [Communication Setting] in the [Controller Setting] window.

2. Select [Use the function of Gateway] and following items.
   - Connecting Means : wireless LAN or Standard Ethernet + wireless LAN
   - Mode : wireless LAN
   - I/F : Extended I/F(wireless LAN)
   - Driver : wireless LAN

3. The detailed setting is displayed after Connecting Means, Mode, I/F, and Driver are set.
   Make the settings according to the usage environment.
   15.2.2 Communication detail settings

Click the [OK] button when settings are completed.

POINT

The settings of connecting equipment can be set and confirmed in [I/F Communication Setting]. For details, refer to the following.

1.1.2 I/F communication setting

15.2.2 Communication detail settings

Make the settings according to the usage environment.

Property	Value
GOT Net No.	1
GOT Station	1
GOT Wireless LAN Setting	192.168.4.20

Item	Description	Range
GOT Net No.	Set the network No. of the GOT. (Default: 1)	1 to 239
GOT Station	Set the station No. of the GOT. (Default: 1)	1 to 64
GOT wireless LAN Setting	Displays the set GOT IP address in the [GOT Wireless LAN I/F Setting] dialog. 15.2.3 GOT wireless LAN I/F setting	-

POINT

(1) Communication interface setting by Utility
The communication interface setting can be changed on the Utility's [Communication Settings] after writing [Communication Settings] of project data.
For details on the Utility, refer to the following manual.

GOT2000 Series User's Manual (Utility)

(2) Precedence in communication settings
When settings are made by GT Designer3 or the Utility, the latest setting is effective.

15.2.3 GOT wireless LAN I/F setting


GOT Wireless LAN I/F Setting
Reflect GOT wireless LAN I/F setting in the GOT
This setting is shared by other Ethernet driver settings.
GOT IP Address:
192 . 168 . 4 . 20
Select from GOT Setting List:
List...
Subnet Mask:
255 . 255 . 255 . 0
Default Gateway:
0 . 0 . 0 . 0
Peripheral S/W Communication Port No.:
5015
Transparent Port No.:
5014
OK
Cancel

Item	Description	Range
GOT IP Address	Set the IP address of the GOT. (Default: 192.168.4.20)	0.0.0.0 to 255.255.255.255
Select from GOT Setting List	Select the set GOT in the [GOT Setting List] dialog. ☞GT Designer3 (GOT2000) Help	-
Subnet Mask	Set the subnet mask for the sub network. (Only for connection via router) If the sub network is not used, the default value is set. (Default: 255.255.255.0)	0.0.0.0 to 255.255.255.255
Default Gateway	Set the router address of the default gateway where the GOT is connected. (Only for connection via router) (Default: 0.0.0.0)	0.0.0.0 to 255.255.255.255
Peripheral S/W Communication Port No.	Set the GOT port No. for the S/W communication. (Default: 5015)	1024 to 65534 (Except for 5011 to 5014 and 49153 to 49170)
Transparent Port No.	Set the GOT port No. for the transparent function. (Default: 5014)	5014 (fixed)
Automatically enable wireless LAN connection	Select this item to automatically connect the wireless LAN to the wireless LAN access point after the GOT is powered on.	-
Time to Automatic Disconnect	Set the time for the wireless LAN communication to automatically disconnect. (Default: 0)	0 to 360

15.3 Precautions

When connecting to multiple GOTs

Do not use the IP address "192.168.3.18" when using multiple GOTs.
A communication error may occur on the GOT with the IP address.

When setting IP address

Do not use "0" and "255" at the end of an IP address.

(Numbers of *.*.*.0 and *.*.*.255 are used by the system)

The GOT may not monitor the controller correctly with the above numbers.

Consult with the administrator of the network before setting an IP address to the GOT and controller.


MEMO

REVISIONS

* The manual number is given on the bottom left of the back cover.

Print Date	* Manual Number	Revision
Sep., 2013	SH(NA)-081200ENG-A	Compatible with GT Works3 Version1.100E
Nov., 2013	SH(NA)-081200ENG-B	Compatible with GT Works3 Version1.104J • Compatible with printer connection • Compatible with wireless LAN connection (To be supported soon) • Changing the icons of the supported models
Jan., 2014	SH(NA)-081200ENG-C	Compatible with GT Works3 Version1.108N • Compatible with wireless LAN connection • The operation panel function is supported.

This manual confers no industrial property rights or any rights of any other kind, nor does it confer any patent licenses.
Mitsubishi Electric Corporation cannot be held responsible for any problems involving industrial property rights which may occur as a result of using the contents noted in this manual.

© 2013 MITSUBISHI ELECTRIC CORPORATION


MEMO

WARRANTY

Please confirm the following product warranty details before using this product.

1. Gratis Warranty Term and Gratis Warranty Range

If any faults or defects (hereinafter "Failure") found to be the responsibility of Mitsubishi occurs during use of the product within the gratis warranty term, the product shall be repaired at no cost via the sales representative or Mitsubishi Service Company.
However, if repairs are required onsite at domestic or overseas location, expenses to send an engineer will be solely at the customer's discretion. Mitsubishi shall not be held responsible for any re-commissioning, maintenance, or testing on-site that involves replacement of the failed module.

[Gratis Warranty Term]

The gratis warranty term of the product shall be for thirty-six (36) months after the date of purchase or delivery to a designated place.
Note that after manufacture and shipment from Mitsubishi, the maximum distribution period shall be six (6) months, and the longest gratis warranty term after manufacturing shall be forty-two (42) months. The gratis warranty term of repair parts shall not exceed the gratis warranty term before repairs.

[Gratis Warranty Range]

(1) The customer shall be responsible for the primary failure diagnosis unless otherwise specified.
If requested by the customer, Mitsubishi Electric Corporation or its representative firm may carry out the primary failure diagnosis at the customer's expence.
The primary failure diagnosis will, however, be free of charge should the cause of failure be attributable to Mitsubishi Electric Corporation.

(2) The range shall be limited to normal use within the usage state, usage methods and usage environment, etc., which follow the conditions and precautions, etc., given in the instruction manual, user's manual and caution labels on the product.

(3) Even within the gratis warranty term, repairs shall be charged for in the following cases.
1. Failure occurring from inappropriate storage or handling, carelessness or negligence by the user. Failure caused by the user's hardware or software design.
2. Failure caused by unapproved modifications, etc., to the product by the user.
3. When the Mitsubishi product is assembled into a user's device, Failure that could have been avoided if functions or structures, judged as necessary in the legal safety measures the user's device is subject to or as necessary by industry standards, had been provided.
4. Failure that could have been avoided if consumable parts designated in the instruction manual had been correctly serviced or replaced.
5. Replacing consumable parts such as the battery, backlight and fuses.
6. Failure caused by external irresistible forces such as fires or abnormal voltages, and Failure caused by force majeure such as earthquakes, lightning, wind and water damage.
7. Failure caused by reasons unpredictable by scientific technology standards at time of shipment from Mitsubishi.
8. Any other failure found not to be the responsibility of Mitsubishi or that admitted not to be so by the user.

2. Onerous repair term after discontinuation of production

(1) Mitsubishi shall accept onerous product repairs for seven (7) years after production of the product is discontinued.
Discontinuation of production shall be notified with Mitsubishi Technical Bulletins, etc.

(2) Product supply (including repair parts) is not available after production is discontinued.

3. Overseas service

Overseas, repairs shall be accepted by Mitsubishi's local overseas FA Center. Note that the repair conditions at each FA Center may differ.

4. Exclusion of loss in opportunity and secondary loss from warranty liability

Regardless of the gratis warranty term, Mitsubishi shall not be liable for compensation to damages caused by any cause found not to be the responsibility of Mitsubishi, loss in opportunity, lost profits incurred to the user by Failures of Mitsubishi products, special damages and secondary damages whether foreseeable or not, compensation for accidents, and compensation for damages to products other than Mitsubishi products, replacement by the user, maintenance of on-site equipment, start-up test run and other tasks.

5. Changes in product specifications

The specifications given in the catalogs, manuals or technical documents are subject to change without prior notice.

6. Product application

(1) In using the Mitsubishi graphic operation terminal, the usage conditions shall be that the application will not lead to a major accident even if any problem or fault should occur in the graphic operation terminal device, and that backup and fail-safe functions are systematically provided outside of the device for any problem or fault.

(2) The Mitsubishi graphic operation terminal has been designed and manufactured for applications in general industries, etc.
Thus, applications in which the public could be affected such as in nuclear power plants and other power plants operated by respective power companies, and applications in which a special quality assurance system is required, such as for Railway companies or Public service purposes shall be excluded from the graphic operation terminal applications.
In addition, applications in which human life or property that could be greatly affected, such as in aircraft, medical applications, incineration and fuel devices, manned transportation equipment for recreation and amusement, and safety devices, shall also be excluded from the graphic operation terminal range of applications.
However, in certain cases, some applications may be possible, providing the user consults the local Mitsubishi representative outlining the special requirements of the project, and providing that all parties concerned agree to the special circumstances, solely at our discretion.
In some of three cases, however, Mitsubishi Electric Corporation may consider the possibility of an application, provided that the customer notifies Mitsubishi Electric Corporation of the intention, the application is clearly defined and any special quality is not required.

GOT is a registered trademark of Mitsubishi Electric Corporation.
Microsoft, Windows, Windows NT, Windows Server, Windows Vista, and Windows 7 are registered trademarks or trademarks of Microsoft Corporation in the United States and other countries.
Adobe and Adobe Reader are registered trademarks of Adobe Systems Incorporated.
Pentium and Celeron are registered trademarks of Intel Corporation in the United States and other countries.
Ethernet is a trademark of Xerox Corporation in the United States.
MODBUS is a trademark of Schneider Electric SA.
VNC is a registered trademark of RealVNC Ltd. in the United States and other countries.
Other company and product names herein are either trademarks or registered trademarks of their respective owners.

SH(NA)-081200ENG-C

GOT2000 Series Connection Manual (Microcomputer, MODBUS Products, Peripherals)

For GT Works3 Version1

MODEL	GOT2000-CON4-SW1-E
MODEL CODE	————
SH(NA)-081200ENG-C(1401)MEE	

When exported from Japan, this manual does not require application to the Ministry of Economy, Trade and Industry for service transaction permission.

MITSUBISHI ELECTRIC CORPORATION

HEAD OFFICE : TOKYO BUILDING, 2-7-3 MARUNOUCHI, CHIYODA-KU, TOKYO 100-8310, JAPAN
NAGOYA WORKS : 1-14 , YADA-MINAMI 5-CHOME , HIGASHI-KU, NAGOYA , JAPAN

Specifications subject to change without notice. Printed in Japan, January 2014.